

# 2010 Recharge Master Plan Update

*Volume I – Final Report*



*Prepared for*

**Chino Basin Watermaster  
Chino Basin Water Conservation District  
Inland Empire Utilities Agency**

June 2010

*Prepared by*

Wildermuth Environmental Inc.  
Black & Veatch Corporation  
Wagner & Bonsignore  
Sierra Water Group

# **2010 Recharge Master Plan Update**

## **Volume I – Final Report**

*Prepared for*  
Chino Basin Watermaster  
Chino Basin Water Conservation District  
Inland Empire Utilities Agency

*Prepared by*  
Wildermuth Environmental, Inc.  
Black & Veatch Corporation  
Wagner & Bonsignore  
Sierra Water Group

**June 2010**

# Table of Contents

<b>Section 1 – Introduction</b>	<b>1-1</b>
<b>Section 2 – Planning Criteria</b>	<b>2-1</b>
2.1 Introduction	2-1
2.2 Legal Requirements	2-1
2.2.1 Chino Basin Judgment	2-1
2.2.2 Peace Agreement	2-2
2.2.3 Peace II Agreement	2-3
2.2.4 Special Referee’s December 2007 Report, Sections VI (Assurances Regarding Recharge), VII (Declining Safe Yield), and VIII (New Equilibrium)	2-5
2.3 Design Criteria for Wells Spreading Basins, Conveyance, and Treatment Facilities	2-6
2.3.1 New ASR Wells	2-6
2.3.2 New Injection Wells	2-7
2.3.3 Recharge Basins	2-7
2.3.4 Treatment	2-7
2.3.4.1 SWP Water	2-7
2.3.4.2 CRA Water	2-8
2.3.4.3 Recycled Water	2-9
2.4 Cost Methodology and Financial Criteria	2-9
2.4.1 Cost Methodology	2-9
2.4.2 Construction Cost Criteria	2-10
2.4.3 Annual O&M Cost Criteria	2-10
2.4.4 General Financial Criteria	2-10
<b>Section 3 – Safe Yield</b>	<b>3-1</b>
3.1 Introduction	3-1
3.2 Safe Yield	3-1
3.2.1 Carroll’s Estimate of the Safe Yield of the Chino Basin	3-2
3.2.2 Methodology to Compute Safe Yield	3-3
3.2.3 Base Period Considerations	3-5
3.2.4 Storage Considerations	3-6
3.2.5 Areal Considerations	3-6
3.2.6 Recommended Method to Estimate Safe Yield	3-10
3.3 Why Has the Safe Yield Changed Over Time?	3-6
3.3.1 Landuse Change	3-6
3.3.2 Changes in Drainage	3-8
3.3.3 Predicted Decline in Safe Yield from the Peace II Engineering Work in 2007	3-9
3.3.4 Mitigation of the Loss of Safe Yield	3-9
3.4 Baseline Stormwater Recharge with Existing Recharge Facilities in 2010	3-11
3.5 Recharge Master Plan Update Implementation Items	3-11
3.5.1 Recomputation of the Safe Yield	3-11
3.5.2 Mitigation of the Projected Loss of Safe Yield	3-12
<b>Section 4 – Integrated Review of Water Supply Plans</b>	<b>4-1</b>
4.1 Water Supply Plans for All Entities That Use the Chino Basin	4-1
4.2 Projection of Chino Basin Groundwater Production and Replenishment	4-3
4.3 Recharge Master Plan Implementation Items	4-4

<b>Section 5 – Storm Water Recharge Enhancement Opportunities .....</b>	<b>5-1</b>
5.1 Introduction.....	5-1
5.2 Existing Storm Water Management and Recharge.....	5-2
5.2.1 Existing Regional Storm Water Recharge Facilities and Policies Related to Storm Water Management and Recharge.....	5-3
5.2.1.1 General Operations for Recharge Basins .....	5-3
5.2.1.2 General Operations for Recharge Basins .....	5-6
5.2.1.2.1 San Antonio Creek System .....	5-6
5.2.1.2.2 West Cucamonga Channel System.....	5-7
5.2.1.2.3 Riverside Drive Drain .....	5-8
5.2.1.2.4 Cucamonga/Deer Creek Channels System.....	5-9
5.2.1.2.5 Day Creek Channel System .....	5-9
5.2.1.2.6 Etiwanda and San Sevaine Channels System .....	5-10
5.2.1.2.7 West Fontana Channel System.....	5-11
5.2.1.2.8 Declez Channel System .....	5-11
5.2.2 Local Storm Water Recharge Facilities and Policies Related to Storm Water Management and Recharge .....	5-12
5.2.2.1 Storm Water Recharge Facilities Identified by Chino Basin Entities.....	5-13
5.2.2.1.1 Best Management Practices (BMPs).....	5-13
5.2.2.1.2 Identified Recharge Facilities.....	5-17
5.2.2.2 Evaluation of Local Retention Facilities.....	5-21
5.3 Potential Storm Water Recharge Projects.....	5-23
5.3.1 Potential Storm Water Recharge Projects .....	5-24
5.3.1.1 Potential New Recharge Basins .....	5-24
5.3.1.2 Brooks Basin Enlargement .....	5-24
5.3.1.3 Whispering Lakes Golf Course.....	5-25
5.3.2 Potential Local Storm Water Recharge Projects .....	5-25
5.3.3 Potential Changes in Storm Water Management Policy to Increase Recharge.....	5-25
5.3.3.1 Increase Divertible Runoff .....	5-26
5.3.3.2 First Flush Bypass.....	5-29
5.4 Reconnaissance Level Evaluation of Improvements to Potential Storm Water Recharge .....	5-30
5.4.1 Potential Stream System Improvements .....	5-31
5.4.1.1 San Antonio Creek System.....	5-31
5.4.1.2 Cucamonga Creek System .....	5-32
5.4.1.3 Day Creek System.....	5-33
5.4.1.4 San Sevaine System .....	5-33
5.4.1.5 Declez Creek System.....	5-34
5.4.2 Estimated Recharge for Potential Stream System Improvements .....	5-34
5.4.2.1 San Antonio Creek System.....	5-34
5.4.2.2 Cucamonga Creek System .....	5-35
5.4.2.3 Day Creek System.....	5-35
5.4.2.4 San Sevaine System.....	5-36
5.4.2.5 Declez Creek System.....	5-36
5.4.3 Implementation Barriers for Potential Stream System Improvements .....	5-37
5.4.3.1 San Antonio Creek System.....	5-37
5.4.3.2 Cucamonga Creek System .....	5-37
5.4.3.3 Day and San Sevaine Creek Systems .....	5-38
5.4.3.4 Declez Creek System.....	5-38

5.4.4	Policy Changes .....	5-38
5.4.5	Review of Preliminary Evaluation of Stream System Improvements.....	5-38
5.5	Conceptual Regional Recharge Distribution System.....	5-39
5.5.1	Existing Condition.....	5-40
5.5.2	Evaluated Alternative.....	5-40
5.5.3	Phase I Development.....	5-41
5.5.3.1	Potential Recharge Increase.....	5-41
5.5.3.2	Potential Cost.....	5-41
5.5.4	Phase II Development.....	5-42
5.5.4.1	Potential Recharge Increase.....	5-42
5.5.4.2	Potential Cost.....	5-43
5.5.5	Phase III Development.....	5-44
5.5.5.1	Potential Recharge Increase.....	5-44
5.5.5.2	Potential Cost.....	5-45
5.5.6	Phase IV Development.....	5-45
5.5.6.1	Potential Recharge Increase.....	5-46
5.5.6.2	Potential Cost.....	5-47
5.5.7	Phase V Development.....	5-48
5.5.7.1	Potential Recharge Increase.....	5-49
5.5.7.2	Potential Cost.....	5-51
5.5.8	Phased Development Discussion.....	5-52
5.5.9	Distribution Power Requirements and Cost.....	5-52
5.5.10	Operation and Maintenance Costs .....	5-53
5.5.11	Total Annualized Cost .....	5-53
5.6	Potential Improvement Projects .....	5-54
5.6.1	Wineville Basin .....	5-54
5.6.1.1	Existing Condition .....	5-54
5.6.1.2	Proposed Improvement Alternatives.....	5-55
5.6.1.3	Evaluated Alternatives.....	5-55
5.6.1.3.1	Potential Recharge Increase .....	5-56
5.6.1.3.2	Potential Cost .....	5-57
5.6.1.3.3	Discussion .....	5-58
5.6.2	Lower Day Basin.....	5-58
5.6.2.1	Existing Condition .....	5-58
5.6.2.2	Proposed Improvement Activities.....	5-59
5.6.2.3	Evaluated Alternatives.....	5-59
5.6.2.3.1	Potential Recharge Increase .....	5-60
5.6.2.3.2	Potential Cost .....	5-61
5.6.2.3.3	Discussion .....	5-61
5.6.3	Jurupa Basin.....	5-61
5.6.3.1	Existing Condition .....	5-61
5.6.3.2	Proposed Improvement Alternatives.....	5-62
5.6.3.3	Evaluated Alternatives.....	5-62
5.6.3.3.1	Potential Recharge Increase .....	5-63
5.6.3.3.2	Potential Cost .....	5-64
5.6.3.3.3	Discussion .....	5-67
5.6.4	RP3 Basin.....	5-67
5.6.4.1	Existing Condition .....	5-67

5.6.4.2	Proposed Improvement Alternatives.....	5-68
5.6.4.3	Evaluated Alternatives.....	5-68
5.6.4.3.1	Potential Recharge Increase .....	5-69
5.6.4.3.2	Potential Cost .....	5-70
5.6.4.3.3	Discussion .....	5-70
5.6.5	Vulcan Pit.....	5-70
5.6.5.1	Existing Condition .....	5-70
5.6.5.2	Proposed Improvement Alternatives.....	5-70
5.6.5.3	Evaluated Alternatives.....	5-71
5.6.5.3.1	Potential Recharge Increase .....	5-71
5.6.5.3.2	Potential Cost .....	5-71
5.6.5.3.3	Discussion .....	5-72
5.6.6	Lower Cucamonga Basin .....	5-72
5.6.6.1	Existing Condition .....	5-72
5.6.6.2	Proposed Improvement Alternatives.....	5-72
5.6.6.3	Evaluated Alternatives.....	5-73
5.6.6.3.1	Potential Recharge Increase .....	5-75
5.6.6.3.2	Potential Cost .....	5-75
5.6.6.3.3	Discussion .....	5-76
5.6.7	Lower San Sevaine Basin .....	5-77
5.6.7.1	Existing Condition .....	5-77
5.6.7.2	Proposed Improvement Alternatives.....	5-77
5.6.7.3	Evaluated Alternatives.....	5-77
5.6.7.3.1	Potential Recharge Increase .....	5-78
5.6.7.3.2	Potential Costs .....	5-78
5.6.7.3.3	Discussion .....	5-79
5.6.8	Declez Basin.....	5-80
5.6.8.1	Existing Condition .....	5-80
5.6.8.2	Proposed Improvement Alternatives.....	5-80
5.6.8.3	Evaluated Alternatives.....	5-80
5.6.8.3.1	Potential Recharge Increase .....	5-81
5.6.8.3.2	Potential Cost .....	5-81
5.6.8.3.3	Discussion .....	5-82
5.6.9	Turner Basin Expansion/Gausti Park.....	5-83
5.6.10	Pumping and Conveyance Systems .....	5-83
5.6.10.1	Existing Condition .....	5-83
5.6.10.2	Proposed Improvement Alternatives.....	5-83
5.6.10.3	Evaluated Alternatives.....	5-83
5.6.10.4	Potential Cost.....	5-84
5.6.10.5	Discussion .....	5-85
5.6.11	Project Evaluation .....	5-85
5.6.11.1	Cost Evaluations .....	5-85
5.7	Conclusions and Recommendations.....	5-87
<b>Section 6 – Supplemental Water Recharge Enhancement Opportunities .....</b>		<b>6-1</b>
6.1	Introduction.....	6-1
6.2	Replenishment Requirement.....	6-2
6.3	Existing Supplemental Recharge Capacity.....	6-3
6.3.1	Spreading Basins .....	6-3
6.3.2	Aquifer Storage and Recovery Wells .....	6-5

6.3.3	In-Lieu Recharge Capacity.....	6-5
6.3.4	Supplemental Water Recharge Capacity Requirements.....	6-5
6.4	Existing Supplemental Water Sources .....	6-6
6.4.1	Metropolitan Water District of Southern California .....	6-6
6.4.1.1	State Water Project.....	6-6
6.4.1.2	SWP Delivery Reliability.....	6-8
6.4.1.3	Colorado River Aqueduct (CRA) .....	6-9
6.4.1.4	Metropolitan as a Source of Water for Replenishment.....	6-10
6.4.2	IEUA Recycled Water.....	6-11
6.5	Other Supplemental Water .....	6-12
6.5.1	Imported Water .....	6-12
6.5.2	Other Water Sources.....	6-14
6.6	Replenishment Water Supply Portfolio .....	6-15
6.7	New Supplemental Water Recharge Improvement Projects.....	6-15
6.7.1	New Local Supplemental Water Sources.....	6-17
6.7.1.1	RIX Facility Connection to the IEUA's Recycled Water Distribution System.....	6-17
6.7.1.2	WRCRWAP Connection to the IEUA's Recycled Water Distribution System.....	6-18
6.7.2	Increase in Supplemental Recharge Capacity.....	6-19
6.7.2.1	Cucamonga Valley Water District (CVWD) Aquifer Storage and Recovery (ASR) Wells.....	6-19
6.7.2.2	Jurupa Community Services District (JCSD) Aquifer Storage and Recovery (ASR) Wells .....	6-20
6.7.2.3	City of Ontario Aquifer Storage and Recovery (ASR) Wells.....	6-22
6.7.2.4	Current Need for ASR Wells for Replenishment.....	6-23
6.7.3	Increase in Supplemental Water Delivery Capacity .....	6-23
6.7.3.1	Turnout to San Sevaine Basin No. 1 via the Azusa Devil Canyon (ADC) or Etiwanda Pipelines .....	6-23
6.7.3.2	Turnout to San Antonio Channel via the Azusa Devil Canyon (ADC) Pipeline.....	6-24
6.8	Master Plan Implementation Items .....	6-25
<b>Section 7 – Recharge Master Plan Update.....</b>		<b>7-1</b>
7.1	Local Stormwater Management and Mitigation of the Loss of Safe Yield .....	7-1
7.2	Regional Stormwater Recharge Facilities .....	7-2
7.3	Supplemental Water for Replenishment.....	7-3
7.4	Supplemental Water Recharge Facilities .....	7-4
7.5	Future RMPU Process .....	7-5
<b>Section 8 – References .....</b>		<b>8-1</b>
<b>Appendix A – Public Outreach and Process</b>		
<b>Appendix B – IEUA Technical Memoranda Regarding the Water Demand and Supply Plan for the Chino Basin Area</b>		
<b>Appendix C – Summary of the R4 Model for the Chino Basin</b>		
<b>Appendix D – Sierra Water Group Task Report for Supplemental Water Sources</b>		
<b>Appendix E – Black and Veatch Task Report for Supplemental Water Recharge Projects</b>		
<b>Appendix F – Comments and Responses on Draft RMPU</b>		

## List of Tables

- 2-1 ASR Well Design Criteria
- 2-2 Injection Well Design Criteria
- 2-3 Recharge Basin Design Criteria
- 2-4 General Criteria/Information for Chino Basin Water Treatment Plants
- 2-5 Potential Sources of Recycled Water
- 2-6 Summary of Unit Construction Cost Criteria
- 2-7 Summary of Unit O&M Cost Criteria
- 2-8 Injection Well Design Criteria
- 3-1 Components of Safe Yield Adopted in the Chino Basin Judgment
- 3-2 Historical Landuse in the Chino Basin Area
- 3-3 Imperviousness and Irrigation Properties
- 3-4 Time History of Total Imperviousness of the Land Surface in the Chino Basin Area
- 3-5 Estimated Deep Infiltration of Precipitation and Applied Water
- 3-6 Water Budget for Chino North, Chino East, Chino South, and Prado Basin Management Zones – Peace II Alternative
- 3-7 Stormwater Recharge from Future Development from Compliance with the 2010 MS4 Permits and Potential New Recharge if the Same Requirements Were Applied to the Current Developed Areas
- 3-8 Expected Theoretical Stormwater Recharge at CBFIP Facilities
- 4-1 Projected Groundwater Production and Production Rights, Based on August 2008 IEUA/Watermaster Estimates
- 4-2 Projected Groundwater Production and Production Rights
- 5-1 Existing Regional Conservation Basin Parameters
- 5-2 Existing Regional Multi-Purpose Basin Parameters
- 5-3 Existing Regional Flood Control Basin Parameters
- 5-4 Information on Rubber Dam Automation Within the Chino Basin Boundary
- 5-5 City of Chino Storm Water Recharge
- 5-6 City of Fontana Storm Water Recharge
- 5-7 City of Montclair Storm Water Recharge
- 5-8 City of Ontario Storm Water Recharge
- 5-9 City of Rancho Cucamonga Storm Water Recharge
- 5-10 Potential Recharge Basins
- 5-11 First Flush Opportunities Based on Reported Discharge Measured at USGS 11073300 San Antonio Creek at Riverside Drive near Chino CA, Excluding Contributions from the OC-59 turnout



## List of Tables

- 5-12 Estimated San Antonio Creek Discharge at Montclair Basin Inlet During First Flush Opportunities Based on Reported Discharge Measured at USGS 11073300 San Antonio Creek at Riverside Drive near Chino CA, Excluding Contributions from the OC-59 turnout
- 5-13 Estimated San Antonio Creek Discharge at Montclair Basin Inlet During First Flush Opportunities Based on Wildermuth Environmental, Inc. Modeled Discharge
- 5-14 Cost Estimate for Conceptual Project Evaluation of RP3 Basin (No Excavation)
- 5-15 Cost Estimate for Conceptual Project Evaluation of RP3 Basin (With Excavation)
- 6-1 Projected Watermaster Recharge Obligation and an Example of Meeting the Recharge Obligation with Temporally Variable Supplemental Water Supplies and Preemptive Replenishment
- 6-2 Calculation of the Availability of Spreading Basins for Supplemental Water Recharge Based on Precipitation Records at the Montclair/Claremont Gage Composite (1034 and 1137)
- 6-3 Supplemental Water Recharge Capacity Estimates
- 7-1 Comparison of the Court's RMPU Requirements and How Those Requirements are Addressed in the RMPU

## List of Figures

- 3-1 Legal and Hydrologic Boundaries of the Chino Basin
- 3-2a 1933 Land Use in the Chino Basin Area
- 3-2b 1949 Land Use in the Chino Basin Area
- 3-2c 1957 Land Use in the Chino Basin Area
- 3-2d 1963 Land Use in the Chino Basin Area
- 3-2e 1975 Land Use in the Chino Basin Area
- 3-2f 1984 Land Use in the Chino Basin Area
- 3-2g 1990 Land Use in the Chino Basin Area
- 3-2h 2000 Land Use in the Chino Basin Area
- 3-2i 2006 Land Use in the Chino Basin Area
- 3-2j Projected 2025 Land Use in the Chino Basin Area
- 3-3 Time History of Deep Infiltration of Precipitation and Applied Water for the Chino Basin
- 3-4 Recharge past the Root Zone and Recharge at the Water Table
- 3-5 Time History of Channel Lining
- 3-6 Streambed Infiltration by Creek in the Chino Basin
- 3-7a Comparison of Santa Ana River Discharge over the Chino Basin and Santa Ana River Streambed Recharge into the Chino Basin
- 3-7b Projected Santa Ana River Streambed Recharge into the Basin
- 3-8 Comparison of Safe Yield Estimates for the Calibration and Peace II Periods
- 4-1 Water Service Areas
- 4-2 Projected Groundwater Production in the Chino Basin for the 2008 IEUA/Watermaster Production Projection
- 4-3 Existing and Planned Production Wells
- 5-1 Existing Regional Basins
- 5-2 Identified Storm Water Management BMPs
- 5-3 City of Chino Storm Water Recharge
- 5-4 City of Fontana Storm Water Recharge
- 5-5 City of Montclair Storm Water Recharge
- 5-6 City of Ontario Storm Water Recharge
- 5-7 City of Rancho Cucamonga Storm Water Recharge
- 5-8 Potential Recharge Basin Locations
- 5-9 Upland and Montclair (1-4) Basin Positive Flow by Percentile – October 1949 through December 2006

## List of Figures

- 5-10 Approximate Drainage Area Boundaries below San Antonio Dam for USGS 11073300 and Montclair Basins
- 5-11 Estimated Discharge of San Antonio Creek at Montclair Basins and Potential Montclair Basin Diversions Water Year 2006
- 5-12 Estimated Discharge of San Antonio Creek at Montclair Basins and Potential Montclair Basin Diversions Water Year 2007
- 5-13 Estimated Discharge of San Antonio Creek at Montclair Basins and Potential Montclair Basin Diversions Water Year 2008
- 5-14 Increase in Capturable Runoff Resulting from Increased Inlet Capacity and/or Storage Capacity – Montclair Basins 1 through 4 – Based on Data Modeled by Wildermuth Environmental, Inc.
- 5-15 Increase in Capturable Runoff Resulting from Increased Storage Capacity – Turner Basins 1 through 4 – Based on Daily Cucamonga Creek and Deer Creek Runoff Modeled by Wildermuth Environmental, Inc.
- 5-16 Estimated Discharge Potentially Foregone in San Antonio Creek System for Each First Flush Opportunity from April 2005 through June 2009 Based on San Antonio Creek Flow Estimated at the Montclair Basin Inlet
- 5-17 Estimated Total Water Year Discharge of Storm Events Occurring on Days Corresponding to First Flush Opportunities Based on San Antonio Creek Flow Estimated at Montclair Basin Inlet
- 5-18 Map Showing USGS 11073300 and USGS 11073495
- 5-19 Conceptual Off-Channel Storage Reservoir Project Schematic
- 5-20 Measured Seasonal Discharge – USGS 11073300 San Antonio Creek at Riverside Dr. near Chino, CA Excluding Contributions from OC-59 Releases
- 5-21 Lower Cucamonga and Chris Basins Enhancement Options
- 5-22 Measured Seasonal Discharge – USGS 11073495 Cucamonga Creek near Mira Loma, CA
- 5-23 Total Inflow to Wineville Basin (NDY13) Positive Flow Daily Frequency Distribution – October 1949 through September 1999
- 5-24 Seasonal Wineville Basin Inflow Based on Runoff Modeled by Wildermuth Environmental, Inc.
- 5-25 Inflow to Jurupa Basin (NSS72) Positive Flow Daily Frequency Distribution – October 1949 through September 1999
- 5-26 Seasonal Jurupa Basin Inflow Based on Runoff Modeled by Wildermuth Environmental, Inc.
- 5-27 RP3 Basin Enhancement Options
- 5-28 Declaz Channel at Diversion to RP3 Basin (NSS82) Positive Flow Daily Frequency Distribution – October 1949 through September 1999
- 5-29 Seasonal Flow in Declaz Channel at RP3 Diversion Based on Runoff Modeled by Wildermuth Environmental, Inc.

## List of Figures

- 5-30 Conceptual Project Evaluation of Recharge Distribution System – Phase I
- 5-31 Recharge Distribution System Pumping Schematic – Phase I
- 5-32 Conceptual Project Evaluation of Recharge Distribution System – Phase II
- 5-33 Recharge Distribution System Pumping Schematic – Phase II
- 5-34 Conceptual Project Evaluation of Recharge Distribution System – Phase III
- 5-35 Recharge Distribution System Pumping Schematic – Phase III
- 5-36 Conceptual Project Evaluation of Recharge Distribution System – Phase IV
- 5-37 Recharge Distribution System Pumping Schematic – Phase IV
- 5-38 Conceptual Project Evaluation of Recharge Distribution System – Phase V
- 5-39 Recharge Distribution System Pumping Schematic – Phase V
- 5-40 Conceptual Project Evaluation for Wineville Basin – Sheet 1
- 5-41 Conceptual Project Evaluation for Wineville Basin – Sheet 2
- 5-42 DSOD – Dam Jurisdictional Size Chart
- 5-43 Wineville Basin Evaluated Alternative Schematic
- 5-44 Conceptual Project Evaluation for Lower Day Basin – Sheet 1
- 5-45 Conceptual Project Evaluation for Lower Day Basin – Sheet 2
- 5-46 Lower Day Basin Evaluated Alternative Schematic
- 5-47 Jurupa Basin Evaluated Alternative Schematic
- 5-48 Conceptual Project Evaluation for RP3 Basin – Sheet 1
- 5-49 Conceptual Project Evaluation for RP3 Basin – Sheet 2
- 5-50 RP3 Basin Evaluated Alternative Schematic
- 5-51 Vulcan Pit Evaluated Alternative Schematic
- 5-52 Conceptual Project Evaluation for Lower Cucamonga Basin – Sheet 1
- 5-53 Conceptual Project Evaluation for Lower Cucamonga Basin – Sheet 2
- 5-54 Lower Cucamonga Basin Evaluated Alternative Schematic
- 5-55 Conceptual Project Evaluation for Lower San Sevaine Basin – Sheet 1
- 5-56 Conceptual Project Evaluation for Lower San Sevaine Basin – Sheet 2
- 5-57 Lower San Sevaine Basin Evaluated Alternative Schematic
- 5-58 Conceptual Project Evaluation for Declez Basin
- 5-59 Declez Basin Evaluated Alternative Schematic
- 6-1 Projected Replenishment Water Deliveries for the Chino Basin
- 6-2a Projected Groundwater Replenishment Obligation and CURO for the Baseline Scenario
- 6-2b Projected Groundwater Replenishment Obligation and CURO for the Peace II Scenario

## List of Figures

- 6-3 Groundwater Recharge and Imported Water Facilities
- 6-4 Existing and Proposed Aquifer Storage and Recovery Wells
- 6-5a SWP Table A Delivery Probability Under Current Conditions
- 6-5b SWP Table A Delivery Probability Under Future Conditions
- 6-6 RIX Recycled Water Connection to IEUA Distribution System
- 6-7 WRCRWAP Recycled Water Connection to IEUA Distribution System
- 6-8 Cucamonga Valley Water District ASR Wells
- 6-9 Jurupa Community Services District ASR Wells
- 6-10 City of Ontario ASR Wells
- 6-11 Turnout to San Sevaine Basin No.1 via ADC or Etiwanda Pipelines
- 6-12 Turnout to San Antonio Channel via ADC

## Acronyms, Abbreviations, and Initialisms

ac	acre
acre-ft/yr	acre-feet per year
ACR	Application for Capacity Right
ADC	Azuza-Devil Canyon
ASR	Aquifer Storage and Recovery
Authority	San Bernardino Regional Tertiary & Water Reclamation Authority
B&V	Black & Veatch
BMP	Best Management Practice
BOR	Bureau of Reclamation
CASQA	California Storm Water Quality Association
CBFIP	Chino Basin Facilities Improvement Program
CBWCD	Chino Basin Water Conservation District
CBWL	Chino Basin Wastewater Line
cfs	cubic feet per second
CURO	cumulative unmet replenishment obligation
CRA	Colorado River Aqueduct
CVP	Central Valley Project
CVWD	Cucamonga Valley Water District
Delta	Sacramento-San Joaquin River Delta
DOT	US Department of Transportation
DSOD	CA Department of Water Resources Division of Safety of Dams
DWR	CA Department of Water Resources
EPA	US Environmental Protection Agency
ft	feet
GRCC	Groundwater Recharge Coordinating Committee
IEUA	Inland Empire Utilities Agency
IID	Imperial Irrigation District
IX	ion exchange
JCSD	Jurupa Community Services District
LACSD	Los Angeles County Sanitation District
LMWTP	Lloyd W. Michael Water Treatment Plant
Metropolitan	Metropolitan Water District of Southern California
MS4	Municipal Separate Storm Sewer System

## Acronyms, Abbreviations, and Initialisms

msl	mean sea level
MVWD	Monte Vista Water District
MZ1	Management Zone 1
NOAA	National Oceanic and Atmospheric Administration
NPDES	National Pollutant Discharge Elimination System
NRW	Non-Reclaimable Waste
O&M	operations and maintenance
OCS	Orange County Sanitation District
POC	Pollutants of Concern
QSA	Quantification Settlement Agreement
R4	Rainfall, Runoff, Router, and Rootzone Model
RC	Riverside-Corona
RWQCB	Regional Water Quality Control Board
RIX	Rapid Infiltration Extraction Treatment Plant
RMPU	Recharge Master Plan Update
ROM	Chino Basin Recharge Facilities Operations Procedures Manual
RP	Regional Plant
RO	reverse osmosis
SARI	Santa Ana Regional Interceptor
SBCFCD	San Bernardino County Flood Control District
SBMWD	San Bernardino Municipal Water Department
SCADA	supervisory control and data acquisition
SCE	Southern California Edison
SDCWA	San Diego County Water Authority
SGVMWD	San Gabriel Valley Municipal Water District
Stantec	Stantec Consulting Inc.
SWG	Sierra Water Group
SWP	State Water Project
TDS	total dissolved solids
USGS	United States Geological Survey
VOC	Volatile Organic Compound
WBE	Wagner & Bonsignore Consulting Civil Engineers
Watermaster	Chino Basin Watermaster

## **Acronyms, Abbreviations, and Initialisms**

WFA	Water Facilities Authority
WTP	water treatment plant
WEI	Wildermuth Environmental, Inc.
WMWD	Western Municipal Water District
WQMP	Water Quality Management Plan
WRCRWAP	Western Riverside County Regional Wastewater Authority Plant



## Section 1 – Introduction

---

In September 2000, the Superior Court of the State of California approved the Peace Agreement and authorized the implementation of the Chino Basin Optimum Basin Management Program. The Peace Agreement required the preparation of a recharge master plan update every five years starting in 2000. The Parties to the Peace Agreement started a process in 2005 to revise the Peace Agreement and the Judgment. This revision process was completed in late 2007 (hereafter the Peace II Agreement) and was approved by the Superior Court on December 21, 2007. The Court’s approval contained nine conditions subsequent that must be satisfied time certain for the revisions to be effective. Condition Subsequent 8 requires that a recharge master plan update be completed and submitted to the Court by July 1, 2010. This report documents the Chino Basin Watermaster’s 2010 Recharge Master Plan Update and fulfills Watermaster’s obligation to the Court when filed prior to July 1, 2010.

The scope of work and contents of the 2010 Recharge Master Plan Update (RMPU) are, in part, based on the December 21, 2007 Court Order and the requirements of the Watermaster. Pursuant to Condition Subsequent 5—which reads, “By July 1, 2008 Watermaster shall prepare and submit to the Court a detailed outline and scope and content of its first Recharge master Plan Update, [...]”—Watermaster, working with the Chino Basin Water Conservation District, the Inland Empire Utilities Agency and the Judgment parties, developed a detailed report outline for the 2010 RMPU. The Court subsequently approved this outline and Watermaster started developing the RMPU. The outline of the RMPU, as described herein, was changed slightly to reflect how the investigation actually proceeded, but the content has remained faithful to the outline that was submitted to Court. This report includes the following sections:

Section	Title	Description
1	Introduction	
2	Planning Criteria	Describes the investigation requirements and planning assumptions used in the 2010 Chino Basin Recharge Master Plan Update
3	Safe Yield	Describes how safe yield was historically estimated, why it is projected to decline, and what actions can be taken to mitigate the loss of safe yield
4	Integrated Review of Water Supply Plans	Describes the global water supply for water agencies that use the Chino Basin and projected groundwater production in the Chino Basin through 2030
5	Stormwater Recharge Enhancement Opportunities	Describes the existing stormwater recharge capacity and structural opportunities to increase stormwater recharge

Section	Title	Description
6	Supplemental Water Recharge Enhancement Opportunities	Describes the existing supplemental water recharge capacity, sources of supplemental water, the need for additional supplemental water recharge, and recharge capacities
7	Recharge Master Plan Update	Describes the recommended future recharge plan for Watermaster
8	References	

The RMPU was developed through a stakeholder process. Watermaster convened several workshops over the course of developing the RMPU. At these workshops, the important assumptions and interim work products of the RMPU were presented. Two of those workshops were dedicated solely to the *Draft – 2010 Chino Basin Recharge Master Plan Update* (WEI, 2010c). Appendix A lists these workshops and their content. The technical presentations of these workshops were posted on the RMPU website and are available for download (<http://rmp.wildermuthenvironmental.com>). As part of the stakeholder process, the development of RMPU was open to comments by all, and all comments were responded to and/or addressed. Appendix F contains the comments and responses.

This report was written for managers and decisions makers. The science and engineering support for the RMPU has been provided in recent past reports and reports that were commissioned specifically for the RMPU—the latter have been included as appendices to this report. The final section of this report (Section 8 – References) cites the investigations that were used in preparing the RMPU. Some of the more important investigations have been posted on the RMPU website (<http://rmp.wildermuthenvironmental.com>).

This report was written and prepared by Wildermuth Environmental, Inc., with the exception of Section 5, and is based on their work and the work of other consultants, including the Black & Veatch Corporation (supplemental water recharge projects), the Sierra Water Group (supplemental water supplies), and Wagner & Bonsignore Consulting Civil Engineers (stormwater recharge). Section 5 was written and prepared by Wagner & Bonsignore; Wildermuth Environmental, Inc. was responsible for the modeling work used in Wagner & Bonsignore’s technical analysis. Portions of the work done by Black & Veatch and the Sierra Water Group were incorporated directly into the RMPU. The technical analyses of the Sierra Water Group and Black & Veatch have been included with this report as Appendices D and E, respectively.

The consultant team was supported by staff from the Chino Basin Watermaster (Watermaster), the Chino Basin Water Conservation District (CBWCD), and the Inland empire Utilities Agency (IEUA), and specifically:

Ken Manning, CEO of the Watermaster

Ben Pak, Senior Project Engineer of the Watermaster

Danni Mauruzio, Senior Engineer of the Watermaster

Eunice Ulloa, General Manager of the CBWCD

Marv Shaw, former Manager of Planning & Water Resources of the IEUA

Chris Berch, Manager of Planning & Water Resources of the IEUA

Andy Campbell, Groundwater Recharge Coordinator for the IEUA

Ryan Shaw, Associate Engineer of the IEUA

## Section 2 – Planning Criteria

---

### 2.1 Introduction

This section articulates the investigation requirements and planning assumptions used in the 2010 Chino Basin RMPU. These criteria include those from the Judgment, the Peace Agreement, the Peace II Agreement, the December 21, 2007 Court Order approving the Peace II Agreement, and the facility planning information and assumptions used to evaluate the new recharge projects and alternatives that were investigated and are reported on herein. The Court requires that the RMPU contain recharge estimations and summaries of projected water supply availability as well as the physical means to accomplish those recharge projections. The RMPU reflects an appropriate schedule for planning, design, and physical improvements—as required—to provide the replenishment capability sufficient to meet the reasonable projected replenishment obligations. The investigation requirements and planning criteria were reported to the RMPU stakeholders in a task memorandum in March 2009 (B&V & WEI, 2009). The objective of the task memorandum was to record the criteria and assumptions early in the investigation such that stakeholders would have the opportunity to comment prior to the development and analysis of new recharge projects and recharge alternatives.

The first part of this section discusses the planning criteria and assumptions from the Judgment, the Peace Agreement, the Peace II Agreement, and the December 21, 2007 Court Order approving the Peace II Agreement. This is followed by facility planning, operating, and cost estimating criteria.

### 2.2 Legal Requirements

#### 2.2.1 Chino Basin Judgment

The Chino Basin Watermaster was established under a Judgment entered in the Superior Court of the State of California for the County of San Bernardino, entitled “Chino Basin Municipal Water District v. City of Chino et al.,” (originally Case No. SCV 164327, the file was transferred August 1989 by order of the Court and assigned Case No. RCV 51010). The Honorable Judge Howard B. Wiener signed the Judgment on January 27, 1978. For accounting and operations, the effective date of the Judgment is July 1, 1977.

The Chino Basin Judgment resulted from studies and discussions that began in the early 1970s and continued for several years. Safe yield is defined on page 4 of the Judgment as:

The long-term average annual quantity of ground water (excluding replenishment or stored water but including return flow to the Basin from the use of replenishment or stored water) which can be produced from the Basin under cultural conditions of a particular year without causing an undesirable result.

On page 6 of the Judgment, the safe yield of the Chino Basin is numerically defined as: “[...]”

140,000 acre-ft/yr.” The safe yield is allocated among the three producer pools as follows:

Overlying agricultural pool	82,800 acre-ft/yr
Overlying non-agricultural pool	7,366 acre-ft/yr
Appropriative pool	49,834 acre-ft/yr

A fundamental premise of the Judgment is that it allows all Chino Basin water users to pump sufficient water from the basin to meet their requirements (page 24, paragraph 42). To the extent that pumping exceeds the share of the safe yield, assessments are levied by Watermaster, and Watermaster uses these assessments to purchase supplemental water to replace overproduction.

The Judgment also provides that “Any subsequent change in the safe yield shall be debited or credited to the appropriative pool” (page 25, paragraph 44), meaning that if Watermaster determines that the safe yield has changed at some point in time after the Judgment was entered, the change would be exclusively debited or credited to members of the appropriative pool and the rights allocated to the other pools and their respective parties would remain unchanged. The overlying agricultural pool consists of all overlying producers that produce groundwater for uses other than industrial or commercial and the State of California. The overlying non-agricultural pool consists of overlying producers that produce groundwater for industrial and commercial uses. And, the appropriative pool consists of owners of appropriative rights. All parties were assigned to a pool when the Judgment was entered. The Watermaster maintains a current list of all parties and their pool assignments.

## 2.2.2 Peace Agreement

Section 5.1 (e) of the Peace Agreement contains Watermaster’s commitments regarding the recharge of supplemental water in the Chino Basin. This analysis focuses on Watermaster’s implementation of Peace Agreement Section 5.1 (e) items (i), (iii), (v), (vii), and (viii), which are stated as follows (see Peace Agreement, pages 20 and 21):

Watermaster shall exercise Best Efforts to:

- (i) protect and enhance the safe yield of the Chino Basin through Replenishment and Recharge; [...]
- (iii) direct Recharge relative to Production in each area and sub-area of the Basin to achieve long term balance and to promote the goal of equal access to groundwater in all areas and sub-areas of the Chino Basin; [...]
- (v) establish and periodically update criteria for the use of water from different sources for Replenishment purposes; [...]
- (vii) recharge the Chino Basin with water in any area where groundwater levels have declined to such an extent that there is an imminent threat of Material Physical Injury to any party to the Judgment;
- (viii) maintain long-term hydrologic balance between total Recharge and discharge in all areas and sub-areas; [...].

The *OBMP Implementation Plan* (Exhibit B of the Peace Agreement) contains language identical

to that in Peace Agreement Section 5.1 (e), but it is mostly silent as to the schedule for implementing the specific commitments listed above (see Exhibit B, paragraph 11 on page 20 and the implementation schedule on pages 22 and 23). Paragraph 9 of page 20 of the Implementation Plan includes additional recharge guidelines that Watermaster must consider regarding recharge:

9. When locating and directing physical recharge, Watermaster shall consider the following guidelines:
  - (i) provide long term hydrologic balance within the areas and sub-areas of the basin
  - (ii) protect and enhance water quality
  - (iii) improve water levels
  - (iv) the cost of recharge water
  - (v) any other relevant factors

Section 7 of the Rules and Regulations repeats the commitments of Section 5.1 (e) of the Peace Agreement and adds (see Rules and Regulations, page 37, 7.1 [b] [iv]):

- (b) Watermaster shall exercise Best Efforts to: [...]
- (iv) Make its initial report on the then existing state of Hydrologic Balance by July 1, 2003, including any recommendations on Recharge actions which may be necessary under the OBMP. Thereafter, Watermaster shall make written reports on the long term Balance in the Chino Basin every two years; [...].

### **2.2.3 Peace II Agreement**

The Peace II Agreement states that Watermaster will update and obtain Court approval of that update to the Recharge Master Plan to address how the Chino Basin will be managed to secure and maintain hydraulic control and operated at a new equilibrium at the conclusion of the period of reoperation.

This plan must reflect an appropriate schedule for planning, design, and physical improvements—as required—to provide reasonable assurance that, following the full beneficial use of groundwater withdrawn in accordance with basin reoperation and authorized controlled overdraft, sufficient replenishment capability exists to meet the reasonable projections of Desalter Replenishment obligations. With the concurrence of the IEUA and Watermaster, the Recharge Master Plan is to be updated and amended as frequently as necessary with Court approval and not less than every five (5) years.

Peace II Article 8.4 summarizes recharge in Management Zone 1 (MZ1), specifically the 6,500 acre-ft/yr supplemental recharge to MZ1. Moreover, the Parties make the following acknowledgments regarding the 6,500 acre-ft/yr supplemental recharge:

- (a) fundamental premise of the Physical Solution is that all water users dependent upon Chino Basin will be allowed to pump sufficient waters from the Basin to meet their requirements. To promote the goal of equal access to groundwater within all areas and sub-areas of the Chino Basin, Watermaster

has committed to use its best efforts to direct recharge relative to production in each area and subarea of the Basin and to achieve long-term balance between total recharge and discharge. The Parties acknowledge that to assist Watermaster in providing for recharge, the Peace Agreement sets forth a requirement for Appropriative Pool purchase of 6,500 acre-ft/yr of Supplemental Water for recharge in Management Zone 1 (MZ1). The purchases have been credited as an addition to Appropriative Pool storage accounts. The water recharged under this program has not been accounted for as Replenishment water.

(b) Watermaster was required to evaluate the continuance of this requirement in 2005 by taking into account provisions of the Judgment, Peace Agreement and OBMP, among all other relevant factors. It has been determined that other obligations in the Judgment and Peace Agreement, including the requirement of hydrologic balance and projected replenishment obligations, will provide for sufficient wet water recharge to make the separate commitment of Appropriative Pool purchase of 6,500 acre-ft unnecessary. Therefore, because the recharge target as described in the Peace Agreement has been achieved, further purchases under the program will cease and Watermaster will proceed with operations in accordance with the provisions of paragraphs (c), (d) and (e) below.

(c) The parties acknowledge that, regardless of Replenishment obligations, Watermaster will independently determine whether to require wet-water recharge within MZ1 to maintain hydrologic balance and to provide equal access to groundwater in accordance with the provisions of this Section 8.4 and in a manner consistent with the Peace Agreement, OBMP and the Long Term Plan for Subsidence."

Watermaster will conduct its recharge in a manner to provide hydrologic balance within, and will emphasize recharge in MZ1. Accordingly, the Parties acknowledge and agree that each year Watermaster shall continue to be guided in the exercise of its discretion concerning recharge by the principles of hydrologic balance. (d) Consistent with its overall obligations to manage the Chino Basin to ensure hydrologic balance within each management zone, for the duration of the Peace Agreement (until June of 2030), Watermaster will ensure that a minimum of 6,500 acre-ft of wet water recharge occurs within MZ1 on an annual basis. However, to the extent that water is unavailable for recharge or there is no replenishment obligation in any year, the obligation to recharge 6,500 acre-ft will accrue and be satisfied in subsequent years.

1. Watermaster will implement this measure in a coordinated manner so as to facilitate compliance with other agreements among the parties, including but not limited to the Dry-Year Yield Agreements.
2. In preparation of the Recharge Master Plan, Watermaster will consider whether existing groundwater production facilities owned or controlled by producers within MZ1 may be used in connection with an aquifer storage and recovery ("ASR") project so as to enhance recharge in specific locations and to otherwise meet the objectives of the Recharge Master

Plan.

(e) Five years from the effective date of the Peace II Measures, Watermaster will cause an evaluation of the minimum recharge quantity for MZ1. After consideration of the information developed in accordance with the studies conducted pursuant to paragraph 3 below, the observed experiences in complying with the Dry Year Yield Agreements as well as any other pertinent information, Watermaster may increase the minimum requirement for MZ1 to quantities greater than 6,500 acre-ft/yr. In no circumstance will the commitment to recharge 6,500 acre-ft be reduced for the duration of the Peace Agreement.

#### **2.2.4 Special Referee’s December 2007 Report, Sections VI (Assurances Regarding Recharge), VII (Declining Safe Yield), and VIII (New Equilibrium)**

In the Final Report and Recommendations on Motion for Approval of Peace II Documents, the Special Referee stated that “A key element of the proposed Peace II Measures is that Watermaster must develop recharge capability throughout the Basin Reoperation period, to ensure that sufficient recharge capability exists at the end of the period” (Final Report, page 25, [Schneider, 2007]).

The Special Referee recommended and the Court ultimately ordered that several elements be included within the updated Plan (Motion to Approve Watermaster’s Filing in Satisfaction of Condition Subsequent 5; Watermaster Compliance with Condition Subsequent 6, August 21, 2008):

1. Baseline conditions must be clearly defined and supported by technical analysis. The baseline definition should encompass factors such as pumping, demand, recharge capacity, total Basin water demand, and availability of replenishment water.
2. Safe Yield should be estimated annually, though it is recognized that it is not to be formally recalculated until 2011. Watermaster should develop a technically defensible approach to estimating Safe Yield annually.
3. Measures should be evaluated to lessen or stop the projected Safe Yield decline. All practical measures should be evaluated in terms of their potential benefits and feasibility.
4. Evaluations and reporting of the impact of Basin Re-Operation on groundwater storage and water levels should be done on an annual basis.
5. Total demand for groundwater should be forecast for 2015, 2020, 2025, and 2030. The availability of imported water for supply and replenishment, and the availability of recycled water should be forecast on the same schedule. The schedules should be refined in each Recharge Master Plan update. Projections should be supported by thorough technical analysis.
6. The Recharge Master Plan must include a detailed technical comparison of current and projected groundwater recharge capabilities and current and projected demands for groundwater. The Recharge Master Plan should provide guidance as to what should be done if recharge capacity cannot meet



or is projected not to be able to meet replenishment needs. This guidance should detail how Watermaster will provide sufficient recharge capacity or undertake alternative measures so that Basin operation in accordance with the Judgment and the Physical Solution can be resumed at any time.

These recommendations are a reflection of the requirements described in the Peace II Measures. Peace Agreement II section 8.1 and the Amendment to Judgment Exhibit “I” section 2(b)(5) require that the updated Recharge Master Plan must:

7. Address how the Basin will be contemporaneously managed to secure and maintain Hydraulic Control and subsequently operated at a new equilibrium at the conclusion of the period of Re-Operation.
8. Contain recharge estimations and summaries of the projected water supply availability as well as the physical means to accomplish the recharge projections.
9. Reflect an appropriate schedule for planning, design, and physical improvements as may be required to provide reasonable assurance that sufficient Replenishment capacity exists to meet the reasonable projections of Desalter Replenishment obligations following the implementation of Basin Re-Operation.

Peace Agreement II section 8.4(d)(2) further requires that the Recharge Master Plan:

Consider whether existing groundwater production facilities owned or controlled by producers within MZ1 may be used in connection with an aquifer storage and recovery (“ASR”) project so as to further enhance recharge in specific locations and to otherwise meet the objectives of the Recharge Master Plan.

The Outline of the Recharge Master Plan Update report and the scope of work were designed to respond to the Special Referee’s report, as ordered by the Court on December 21, 2007. The Court subsequently approved the outline, and the stakeholders reviewed and approved the scope of work.

## **2.3 Design Criteria for Wells Spreading Basins, Conveyance, and Treatment Facilities**

This section presents the planning level design criteria for wells, conveyance, storage, and treatment facilities to enhance recharge opportunities in the Chino Basin. These facilities may be further refined and integrated into future water recharge projects to meet the following groundwater recharge goals: (1) enhance the recharge of stormwater runoff, (2) increase the recharge of recycled water, and (3) develop new facilities to capture supplemental imported water.

### **2.3.1 New ASR Wells**

ASR is a process that consists of injecting treated water down through a well for storage in a confined aquifer system and recovery through reversing operations when groundwater

production is needed. Table 2-1 shows the planning level design criteria for an ASR well. Estimates for production and injection capacities are conceptual and presented for initial basin-wide planning purposes only. The equipping of an ASR well shall be based on an above ground vertical turbine type pump with a premium efficiency motor. This type of pump/motor arrangement is commonly found on existing production wells located in the Chino Basin. Each ASR well may include a well enclosure building to accommodate the pump/motor, electric control panels, and other required components.

### **2.3.2 New Injection Wells**

Injection wells enable artificial aquifer recharge by injecting treated surplus water underground to replenish groundwater within the local aquifer. The design criteria for the proposed injection well facilities are provided in Table 2-2.

### **2.3.3 Recharge Basins**

The general design criteria for recharge basin facilities—also referred to as stormwater retention, debris, and conservation basins—are provided in Table 2-3. These criteria were developed based on a typical basin layout, utilizing a conservative percolation design rate (ft/day), as determined by previous programs implemented in the Chino Basin.

### **2.3.4 Treatment**

This section introduces the treatment facilities required to enhance recharge opportunities in the Chino Basin. Treatment concepts were developed for the following source water alternatives: (1) State Water Project (SWP) water, (2) Colorado River Aqueduct (CRA) water, and (3) recycled water sources. The specific treatment opportunities for each water source are described below.

#### **2.3.4.1 SWP Water**

SWP water is an imported water supply delivered by the Metropolitan Water District of Southern California (Metropolitan). SWP water is primarily conveyed to the Basin through the Rialto Pipeline, which flows east to west along the northern portion of the Basin; though, opportunities to use a secondary conveyance source, the San Gabriel Valley Municipal Water District (SGVMWD) Azusa-Devil Canyon (ADC) Pipeline, were also evaluated in the RMPU. The SWP water recharge plan would utilize surplus water, when available. This water would be treated at several existing surface water treatment plants, including the CVWD's Lloyd W. Michael Water Treatment Plant (LMWTP), the Water Facilities Authority (WFA) Aqua de Lejos Water Treatment Plant (WTP), and the Fontana Water Company Sandhill WTP. Table 2-4 presents general criteria and information for the Chino Basin WTPs.

The current projected availability of surplus water from Metropolitan has been substantially reduced due to drought and the uncertainty of SWP pumping operations related to protection requirements for the Delta Smelt and other environmental issues. It is assumed that surplus water would be available to Watermaster in three out of every ten years. This assumption will

impact the facilities required to handle the surplus supply during replenishment periods.

SWP water replenishment and treatment cost rates are addressed in the cost criteria section of this report (Section 2.4).

#### **2.3.4.2 CRA Water**

The CRA is a 242-mile aqueduct that diverts water from the Colorado River at Lake Havasu on the California-Arizona border west across the Mojave and Colorado Deserts to the east side of the Santa Ana Mountains. The CRA terminates at Lake Mathews in western Riverside County, where water is then distributed to Metropolitan’s member agencies via the Upper Feeder.

CRA water is essentially no longer used in the Basin due to high total dissolved solids (TDS) concentrations. CRA projected surplus availability may be increasing due to the potential supply available to Metropolitan from the unused portion of California’s normal apportionment and existing contracts in place to divert additional surplus water on an annual basis. Treatment obstacles would need to be considered such that the water quality issues associated with CRA water could be managed to maintain the salt balance in the Basin and to meet the maximum benefit based TDS objectives. Two treatment scenarios were evaluated under the CRA imported source water plan: (1) CRA without TDS reduction and (2) CRA with TDS reduction. Each scenario is discussed below.

**CRA without TDS Reduction.** This scenario is based upon the strategy to maintain an overall salt balance in the Basin. The plan incorporates conventional surface treatment of CRA water without provisions for TDS reduction. To offset the potential for additional salt loading in the Basin, it is likely that the IEUA’s regional recycled water facilities would require additional advanced treatment to further reduce the TDS concentration in recycled water. Under this scenario, CRA water could be used for direct recharge if an equivalent salt reduction from recycled water was implemented to maintain compliance under the Basin’s maximum benefit objectives.

**CRA with TDS Reduction.** This scenario includes the advanced treatment of CRA water to reduce its TDS to acceptable levels, as required by the Basin Plan objectives. The treatment process would likely include the following steps: flocculation, sedimentation, gravity filtration, sidestream reverse osmosis, and disinfection. Facilities, such as concrete basins, could be constructed utilizing conventional methods of construction, or there may be opportunities to use a more packaged type of treatment facility.

Rehabilitation of the Galvin WTP was previously identified as an opportunity for using CRA water. During the DYY Expansion, the City of Ontario expressed an interest in rehabilitating and reactivating its Galvin WTP, which was initially designed in 1958 and has been out of service for over ten years. After the CDPH implemented the Surface Water Treatment Rule in June 1993, the existing WTP could not comply with the regulatory criteria, and there was not sufficient space within the existing building for additional processes. The WTP would likely require demolition, expansion, and conversion to membrane filtration. The raw water supply for the Galvin WTP would be provided via the Upper Feeder. This project is likely more than 5 to 10 years out and is part of Ontario’s long-term planning. When completed,

this project would be capable of treating surplus CRA water to enhance replenishment opportunities in the Basin.

**Brine Disposal.** The removal of contaminants, such as TDS, via treatment (RO or IX) typically requires facilities for waste brine disposal. Waste brine can be conveyed to the Non-Reclaimable Waste (NRW) System, owned and operated by the IEUA, or to the Chino Basin Wastewater Line (CBWL), operated by the Los Angeles County Sanitation District (LACSD). Depending on the facility's location in the Chino Basin, brine would flow to the NRW System through the Upper Trunk (East Edison and West Edison Lines), the CBWL, or to Santa Ana Regional Interceptor (SARI) via the South System Chino Line. The system conveys industrial wastewater and other salt-laden water to the LACSD and Orange County Sanitation District (OCSD) wastewater plants. Waste could be delivered to the NRW System by connecting a brine line directly to it or by hauling the waste to an NRW System disposal site.

Connecting waste regenerate lines to the NRW System or the CBWL requires the completion of an Application for Capacity Right (ACR) Agreement, the purchase of hydraulic capacity in the NRW System or the CBWL, and the completion of a wastewater discharge permit application.

The availability of NRWS capacity should be determined as this is could be a critical constraint when considering treatment technologies for future projects due to the high volume of waste that is currently being conveyed by the system.

### **2.3.4.3 Recycled Water**

At the IEUA's Regional Plant (RP) sites, advanced recycled water treatment would be used to achieve a target TDS to maintain a salt balance in the Basin; in turn, more imported CRA water could be used to enhance recharge operations in the Basin. The IEUA's facilities, listed in Table 2-5, are the best potential source for advanced treatment and groundwater recharge.

## **2.4 Cost Methodology and Financial Criteria**

This section presents the cost methodology and the planning-level construction, operations and maintenance (O&M), and general financial cost criteria to be used in the development of Basin recharge facility cost opinions.

### **2.4.1 Cost Methodology**

Unit cost criteria and assumptions were developed for construction costs, annual O&M costs, and other general and financing terms. Some of the major unit costs include rolled-up costs as part of the lump sum costs. The following list identifies the components included as part of the rolled-up unit cost criteria:

#### Source Water

- ASR Wells – drilling, equipping, and well enclosure buildings
- Injection Wells – drilling, equipping, and well enclosure buildings

- Recharge Basins – mass excavation, fine grading, diversion control equipment, instrumentation, and security

#### Conveyance

- Piping – major material, trenching, and installation
- Pipeline Crossing – bridge, freeway, railroad, and storm channel
- Pump Stations – major equipment, site work, electrical, mechanical, and instrumentation

#### Treatment

- Conventional Surface Water Treatment – coagulation, flocculation, sedimentation, dual media filtration, and disinfection
- Advanced Surface Water Treatment – coagulation, flocculation, sedimentation, dual media filtration, sidestream reverse osmosis, and disinfection
- Advanced Recycled Water Treatment – sidestream microfiltration and reverse osmosis

### **2.4.2 Construction Cost Criteria**

Table 2-6 summarizes the unit construction cost criteria that were used in the development of the alternative cost estimates.

### **2.4.3 Annual O&M Cost Criteria**

Table 2-7 summarizes the unit annual O&M cost criteria that were used in the development of the alternative cost estimates.

### **2.4.4 General Financial Criteria**

Table 2-8 summarizes the financing and general unit cost criteria that were used in the development of the cost opinions. A 25-percent contingency has been applied to all costs, which is reflective of the planning level of detail. A 15-percent markup has been applied to all costs to account for engineering and administration activities. And, a 7-percent markup has been included to account for construction management. The financing and amortization period and discount rate used to develop the annualized cost are also provided in Table 2-8.

**Table 2-1  
ASR Well Design Criteria**

Facility Component	Design Criteria
Production capacity (varies), gpm	1,100 - 3,400
Assumed injection capacity: low (varies), gpm <sup>1</sup>	550 - 1,700
Assumed injection capacity: high (varies), gpm <sup>2</sup>	1,100 - 3,400
Well Depth	TBD
Pump type	Vertical deep well
Well enclosure building (if used)	Single story structure w/ CMU block wall (or) pre-fab type structure
Required land, sf	2,500 - 5,000

**Table 2-2  
Injection Well Design Criteria**

<b>Facility Component</b>	<b>Design Criteria</b>
Estimated injection capacity (varies), gpm <sup>1</sup>	550 - 3,400
Well enclosure building (if used)	Single story structure w/ CMU block wall (or) pre-fab type structure
Required land, sf	2,500 - 5,000

**Table 2-3  
Recharge Basin Design Criteria**

Facility Component	Design Criteria
Percolation design rate, feet/day	1.0 - 2.0, or per WEI
Total basin usable area (usable perc./total area), %	90, or Site Dependent
Typical basin layout	
Aspect ratio (length : width)	1.5 : 1, or Site Dependent
Basin wall slope (horizontal : vertical)	3:1 Waterside
Basin depth, ft	8-16, per WEI Model or Highwater
Perimeter driveway width, ft	16
Fine grading depth, ft	1
Perimeter fencing	Chain link
Spillway / overflow	Concrete lined or large rock lined
Diversion design	Drop inlet structure, rubber dam, or other
Flow control gates	Gate flow control devise
Instrumentation & control	RTU, radio system, security system



**Table 2-4  
General Criteria/Information for Chino Basin Water Treatment Plants**

Description	LMWTP	WFA WTP	Sandhill WTP
Owner	Cucamonga Valley Water District	Water Facilities Authority	Fontana Water Company
Plant Location	Rancho Cucamonga, California	Upland, California	Rialto, California
Capacity	60 MGD (expanded in yr 2003)	88 MGD	20 MGD (ultimate 30 MGD)
Treatment Process	Conventional surface water treatment	Conventional surface water treatment	Conventional surface water treatment
Water Source	State Water Project, local surface water	State Water Project	State Water Project, local surface water
Source Water Purveyor(s)	Metropolitan Water District	Metropolitan Water District	Metropolitan Water District, San Bernardino Valley Municipal Water District
Distribution Users	CVWD service area (Rancho Cucamonga)	City of Upland, City of Ontario, City of Chino, City of Chino Hills, Monte Vista Water District	Fontana Water Company service area (Fontana, Rialto)

**Table 2-5  
Potential Sources of Recycled Water**

Agency	Facility
LA Sanitation District	Pomona Water Reclamation Plant
IEUA	Regional Plant No. 1
	Regional Plant No. 2
	Regional Plant No. 4
	Regional Plant No. 5
	Carbon Canyon Water Reclamation Plant
California Institute for Men at Chino	CIM Water Reclamation Plant
WMWD	West Riverside Regional

**Table 2-6  
Summary of Unit Construction Cost Criteria**

Item	Unit Cost
<b>Conveyance Facilities</b>	
Pipelines installed, \$/in-dia/lf	\$ 15
Distribution system booster pump station, \$/HP	\$ 5,000
<b>Crossings</b>	
Bridge supported, \$/lf	\$ 900
Freeway crossing (microtunnel), \$/lf	\$ 1,100
Railroad crossing (auger boring), LS	\$ 200,000
Storm channel crossing (auger boring), LS	\$ 150,000
<b>Turnouts &amp; Miscellaneous connections</b>	
Transmission pipeline turnout, LS	\$ 750,000
Connection to storm channel, LS	\$ 100,000
Valve & Metering, LS	\$ 25,000
<b>Well Facilities</b>	
New ASR Well, LS	\$ 2,800,000
New Injection Well, LS	\$ 1,300,000
Well Rehabilitation/ASR Conversion, LS	\$ 900,000
<b>Treatment Facilities</b>	
New conventional Surface WTP \$/gal	\$ 2.50
New Advanced Surface WTP, \$/gal	\$ 3.00
Advanced Recycled WTP (retrofit), \$/gal	\$ 4.50
<b>Land</b>	
Undeveloped	\$ 500,000
<b>Recharge Basin Facilities</b>	
Mass Excavation, \$/CY	\$ 10
Fine Grading, \$/CY	\$ 15
Perimeter Fence, \$/LF	\$ 15
Instrumentation, LS	\$ 100,000

**Table 2-7  
Summary of Unit O&M Cost Criteria**

Item	Unit Cost
<b>Conveyance Facilities</b>	
Pipelines - general, \$/mile	\$ 4,000
Pump Stations - general, % construction cost	2 percent
<b>Well Facilities</b>	
Misc. well maintenance, \$/year/well	\$ 25,000
<b>Surface Water and Treatment Facilities</b>	
SWP and CRA replenishment rate, \$/AF <sup>1</sup>	\$ 365
Surface WTP surcharge, \$/AF <sup>2</sup>	\$ 75
Advanced Surface WTP surcharge, \$/AF <sup>3</sup>	\$ 100
Advanced recycled WTP surcharge, \$/AF <sup>4</sup>	\$ 250
<b>Recharge Basin Facilities</b>	
Misc. basin maintenance, \$/year/basin	\$ 50,000

Notes:

1 -- Metropolitan projected rate effective 1/1/2010. Rates are expected to increase to \$398/AF and \$438/AF in years 2011 and 2012, respectively.

**Table 2-8**  
**Summary of Unit Construction Cost Criteria**

Item	Criteria
Contingency, %	25
Engineering, Administration, %	15
Construction Management, %	7
Energy, \$/kwh	0.14
Project life (amortization period), years	30
Interest Rate, %	5

### 3.1 Introduction

Safe yield is a term used in groundwater management to articulate, subject to assumptions and constraints, the amount of groundwater that can be produced on an annual basis without persistent lowering of groundwater levels and without undesirable effects. Safe yield is a sustainable level of groundwater production. This section of the report describes the safe yield of the Chino Basin as developed for the 1978 Judgment, safe yield as a concept and the information needed to compute it, why safe yield was projected to change during the Peace II engineering work in 2007, and the recommended methodology to compute safe yield in the future. This section specifically addresses the RMPU requirements set forth in items 2 and 3 of the November 2007 Special Referee’s report to the Court:

2. Safe Yield should be estimated annually, though it is recognized that it is not to be formally recalculated until 2011. Watermaster should develop a technically defensible approach to estimating Safe Yield annually.
3. Measures should be evaluated to lessen or stop the projected Safe Yield decline. All practical measures should be evaluated in terms of their potential benefits and feasibility.

### 3.2 Safe Yield

The Stipulated Agreement for the Chino Basin defines safe yield as “the long-term average annual quantity of groundwater (excluding replenishment or stored water but including return flow to the basin from the use of replenishment or stored water) which can be produced from the Basin under cultural conditions of a particular year without causing an undesirable result” (Judgment, Section I Introduction, Paragraph 4 Definitions). The definition also ties the safe yield to the cultural conditions of a specific year, presumably a near current year if cultural conditions are changing. The Judgment declares the safe yield to be 140,000 acre-ft (Judgment, Section II Declaration of Rights, Part A Hydrology, Paragraph 6 Safe Yield).

Undesirable results commonly listed in published literature include the depletion of groundwater reserves, intrusion of water of undesirable quality, contravention of existing water rights, excessive increases in production costs, streamflow depletion, and subsidence (Freeze & Cherry, 1979). In the Chino Basin, the depletion of groundwater reserves is the primary undesirable result that limits the safe yield. The groundwater management plans provided in the Judgment and the Optimum Basin Management Program limit the undesirable results listed above through the implementation of localized management programs. The Judgment requires that production in excess of the safe yield be mitigated by replenishment by Watermaster. Watermaster assesses the parties that produce groundwater in excess of their production rights, pursuant to the Judgment, to fund the purchase of replenishment water. The Peace Agreement requires that Watermaster use its discretion when recharging

supplemental water to balance recharge and discharge in every area and subarea.

### **3.2.1 Carroll's Estimate of the Safe Yield of the Chino Basin**

The safe yield of the Chino Basin was established in the 1978 Judgment to be 140,000 acre-ft/yr. The basis for this estimate was described by William J. Carroll in his testimony on December 19 and 20, 1977 during the Chino Basin adjudication process. Table 3-1 lists the hydrologic components developed by Carroll to estimate the safe yield of the Chino Basin. These components were developed for the 1965 to 1974 period, a period that Carroll referred to as the base period. The hydrologic components listed in Table 3-1 are described below.

Deep Percolation of Precipitation and Surface Inflow – consists of the deep percolation of precipitation and streamflow. Carroll developed the estimate of 47,500 acre-ft/yr based on an extrapolation of the early Chino Basin modeling results from the DWR.

Deep Percolation of Artificial Recharge – consists of the percolation of local runoff in spreading basins. Carroll estimated the local runoff recharged in SBCFCD-controlled facilities to be about 2,800 acre-ft/yr during the base period. The Etiwanda Water Company also recharged about 1,000 acre-ft/yr of water to the Chino Basin from Deer and Day Creeks during the base period.

Deep Percolation of Chino Basin Groundwater Used for Irrigation (Domestic and Agricultural) – defined as the fraction of water applied for irrigation that percolates through the soil and recharges underlying groundwater. Carroll estimated that about 15 percent of the water used for domestic irrigation would percolate to groundwater and about 45 percent of the water used for agricultural irrigation would percolate to groundwater. Carroll estimated the volume of percolation of Chino Basin groundwater used for irrigation over the base period to be about 61,700 acre-ft/yr.

Deep Percolation of Imported Water Used for Irrigation (Domestic and Agricultural) – same as deep percolation of Chino Basin groundwater except the water used for irrigation is imported to and used over the Chino Basin. Carroll estimated the volume of percolation of imported water used for irrigation over the base period to be about 7,000 acre-ft/yr.

Recharge of Sewage – defined as the percolation in ponds of wastewater discharged by municipal wastewater treatment plants. This component almost completely ceased during the base period and was known to be eliminated as a recharge source when the safe yield was estimated. The volume of sewage recharge over the base period was about 18,200 acre-ft/yr. The inclusion of sewage recharge as a component of the safe yield was therefore not hydrologically consistent with how the Basin was to be operated post-Judgment.

Subsurface Inflow – defined as the groundwater inflow to the Chino Basin from adjacent groundwater basins and mountain fronts, including:

Subsurface Source	Annual Inflow (acre-ft/yr)
Bloomington Divide	3,500
San Gabriel Mountain Front	2,500
Colton Rialto Basin	500
Cucamonga Basin	100
Claremont and Pomona Basins	100
Jurupa Hills	500
Total	7,200

Subsurface Outflow – defined as groundwater that rises to the ground surface in the Prado Basin to become Santa Ana River flow. Estimates of subsurface outflow were based on studies by the DWR, United States Geological Survey (USGS), and Carroll. Carroll estimated the subsurface outflow to average about 6,800 acre-ft/yr over the base period.

Extractions – defined as groundwater extractions from the Chino Basin. Carroll estimated groundwater extractions to average about 180,000 acre-ft/yr during the base period.

In addition to these components, Carroll estimated the change in storage over the base period to be about -40,000 acre-ft/yr, which equates to a decline in the volume of groundwater in storage of about 400,000 acre-ft during the base period. Carroll estimated the safe yield to be equal to the average production over the base period plus the average annual change in storage during the base period:

$$\begin{aligned}
 \text{Safe Yield} &= \text{Production} + \text{Change in Storage} \\
 &= 180,000 - 40,000 \\
 &= 140,000 \text{ acre-ft/yr}
 \end{aligned}$$

This safe yield estimate is approximately equal to the total average inflow to the basin (145,500 acre-ft/yr) minus non-production outflow (7,200 acre-ft/yr). This 140,000 acre-ft/yr safe yield estimate was incorporated into the Judgment and is the current safe yield used by Watermaster.

### 3.2.2 Methodology to Compute Safe Yield

Safe yield is estimated one of two ways: it can be established by negotiation among interested parties with little or no science or it can be estimated based on hydrologic principles. The following discussion describes the basic methodology used to estimate safe yield from hydrologic principles.

For the Chino Basin, the safe yield—with deference to the Judgment and the requirements of the Peace Agreement—can be estimated as the average net inflow to the basin excluding the direct recharge of supplemental water. There are two ways to compute safe yield under this



concept, both of which can be derived from the continuity equation. The continuity equation is:

$$\text{Change in Storage } (\Delta S) = [\text{Inflow (I)} - \text{Outflow (O)}] * \Delta t \quad (1)$$

Where:

- $S^t$  is the storage at time  $t$ ,
- $\Delta S$  is the change in storage calculated as  $S^{t+1}$  minus  $S^t$ ,
- $I$  is the total inflow to the basin over the period  $t$  to  $t+1$  and is equal to the sum of Streambed Recharge ( $I_{sr}$ ) + Deep Infiltration of Precipitation ( $I_p$ ) + Subsurface Inflow ( $I_{ssi}$ ) + Artificial Recharge of Supplemental Water ( $I_{ar}$ ) + Irrigation Return Flows ( $I_{rf}$ ),
- $O$  is the total outflow from the basin over the period  $t$  to  $t+1$  and is equal to the sum of Groundwater Pumping ( $O_p$ ) + Subsurface Outflow ( $O_{ss}$ ) + Discharge to Surface Water ( $Q_{rw}$ ) + Evapotranspiration ( $Q_{ev}$ ), and
- $\Delta t$  is the length of the time period used to compute the balance and is equal to the time at  $t+1$  minus the time at  $t$ .

The inflow and outflow terms listed above have dimensions of  $L^3/T$ . If expanded using the hydrologic terms listed above, the continuity equation becomes:

$$\Delta S = [I_{sr} + I_p + I_{ssi} + I_{ar} + I_{rf} - O_p - O_{ss} - O_{rw} - O_{ev}] * \Delta t \quad (2)$$

For certain idealized conditions, the safe yield can be estimated from:

$$\text{Safe Yield} = [\Sigma I_{sr} + \Sigma I_p + \Sigma I_{ssi} + \Sigma I_{rf} - \Sigma O_{ss} - \Sigma O_{rw} - \Sigma O_{ev}] / \Delta t \quad (3)$$

The summation ( $\Sigma$ ) in equation 3 for each term covers the contiguous time series over a common base period. Idealized conditions include: the time history of inflow and outflow terms are known for sufficiently long periods of time and under representative hydrologic and cultural conditions, and there exists enough storage capacity in the aquifer to buffer wet periods and dry periods. It is common practice to define a base period that is assumed to be hydrologically representative of long term conditions and to estimate the inflow and outflow terms each year over that base period. The safe yield is then estimated using the base period average of the inflow and outflow terms. Another more pragmatic approach to estimating safe yield is to simplify equation (2), rewriting it as:

$$\text{Safe Yield} = \Delta S / \Delta t + O_p - I_{ar} \quad (4)$$

Where  $O_p$  and  $I_{ar}$  are the mean groundwater pumping and the mean supplemental water recharge over the base period. Mathematically, equations 4 and 3 are identical; though, equation 4 is usually easier to solve.

Carroll attempted to apply both approaches when estimating safe yield, using hydrologic methods and data available in the mid 1970s to estimate the inflow and outflow terms and the change in storage. Carroll's testimony and working papers clearly indicate that some of the inflow terms and groundwater production were not well known. In addition, it was not appropriate to include the recharge of recycled water in the safe yield: it is supplemental water

and was phased out after 1973. Removing the recycled water recharge reduces Carroll's estimate of safe yield from 140,000 acre-ft/yr to about 122,000 acre-ft/yr. Groundwater level time histories throughout the basin have suggested that the basin is in state of dynamic equilibrium and that the safe yield has been at least 140,000 acre-ft/yr from 1977-78 to the present.

### **3.2.3 Base Period Considerations**

Carroll assumed a ten-year base period. This assumption was made by agreement and has no hydrologic basis. Common practice is to select a base period from precipitation records that span a reasonably long period of time and contain wet periods and dry periods over which the average precipitation equals the long-term average precipitation. The availability of data for estimating the inflow, outflow, and storage terms can also factor into base period selection.

The watershed surface that is tributary to and overlies the groundwater basin and related water management practices have changed dramatically over the last 70 years. The landuse, water management, and drainage conditions that are tributary to and overlie the Basin at a specific time are herein referred to collectively as the cultural condition of the basin at that time. The landuse transition from native or natural conditions to agricultural uses and subsequently to developed urban uses radically changed the amount of recharge to the Basin. Furthermore, irrigation practices change over time in response to agricultural economics (demand for various agricultural products), the availability of water, regulatory requirements, and the cost of water. Urbanization increases the amount of imperviousness—decreasing irrigable area and the permeable area that allows irrigation return flows and precipitation to infiltrate the soil—and increases the amount of stormwater produced on the land surface. Drainage improvements associated with the transition from natural to agricultural and urban uses reduce the recharge of stormwater: channels and streams are lined to move stormwater efficiently through the watershed overlying the groundwater basin. Changes in landuse, water management, and drainage over time produce inflow and outflow time histories that are not stationary; that is, the relationship of the inflow and outflow terms to precipitation and other hydrologic and management drivers change over time. Thus, the selection of a representative base period that satisfies the traditional criteria for a safe yield analysis that is representative of today's cultural conditions is not possible using the actual historical record. The impacts of changes in landuse, water management, and drainage on safe yield over time will be subsequently demonstrated.

Precipitation has long been considered statistically stationary for planning purposes. Analysis of temperature and precipitation records suggests that this may not have been correct. The affects of climate change have clearly been demonstrated: monotonic temperature increases over the last century, receding glaciers, and temporal change in the runoff pattern of the Sierra Nevada Mountains, to name a few (DWR, 2009). Advances in climate change science have produced global climate models that have demonstrated reasonably accurate hindcasting capabilities and subsequent forecasts through the year 2100, based on several future scenarios of economic development and greenhouse gas emissions.

### **3.2.4 Storage Considerations**

The availability of water in storage at the beginning of the base period and the availability of operational storage during the base period must be such that production at the estimated safe yield can be maintained. There must be enough storage space available to store recharge in excess of the safe yield during wet years so that it can be available in years when the recharge is less than the safe yield.

### **3.2.5 Areal Considerations**

The safe yield is determined for a geographically defined groundwater basin. The recharge and discharge of the basin occur within or on the boundaries of the basin. The Chino Basin has two boundaries: the legal boundary, as defined in the Judgment, and the hydrologic boundary, which more accurately reflects the location of physical barriers to groundwater movement and basin recharge. Figure 3-1 shows the location of these boundaries. The primary differences in the boundaries can be observed in the northern part of the basin and its boundary with the Cucamonga Basin. Carroll's estimate, prepared in 1978, was based on the legal boundary. Subsequent estimates by Watermaster have been prepared based on the hydrologically defined boundary.

## **3.3 Why Has the Safe Yield Changed Over Time?**

The Peace II engineering work completed in 2007 (WEI, 2007b) contained a conclusion that the safe yield, as defined using equation 4 above, is projected to decline. This decline is projected to occur due to land use changes and associated changes in water use and stormwater management practices that, when combined, will reduce recharge to the Chino Basin. Below, changes in landuse and stormwater management decisions and their projected impacts on safe yield are discussed.

### **3.3.1 Landuse Change**

Figures 3-2a through 3-2i illustrate landuse in the Chino Basin for 1933, 1949, 1957, 1963, 1975, 1984, 1990, 2000, and 2006 (WEI, 2007b). Years 1933 through 1984 were based on landuse maps that were prepared by the DWR; landuses were aggregated into the categories listed on each figure. Year 2000 landuse information was obtained from SAWPA; these data were aggregated into the same landuse categories developed for the earlier maps. Year 2006 landuse was based on the 2000 landuse map and was updated with information from 2006 air photos. Table 3-2 summarizes landuse from 1933 through 2006. Figure 3-2j shows estimated landuses for build-out conditions, based on the year 2000 landuse map and the general plans of the land use planning agencies in the study area.

Landuse changes result in changes in imperviousness. With few exceptions, as land is converted from natural undeveloped conditions to human uses, it becomes more impervious and produces more stormwater runoff. Historically, when landuse converted from natural or agricultural uses to urban uses, the imperviousness increased from near zero to between 60

and 100 percent, depending on the specific land use. Drainage improvements that were incorporated into the urban landscape were historically designed to convey stormwater rapidly, safely, and efficiently from the land surface through urban developments, and to discharge stormwater away from urbanized areas. There was little or no thought as to value of the stormwater; essentially, it was thrown away.

In an undeveloped state, most of the precipitation from most storms that fell on the watershed tributary to and over the Chino Basin would have been absorbed into the soils overlying the watershed. This water would have either been consumed by native vegetation or lost to evaporation. The overlying soils would have become wet near the surface and completely dry before the next winter. Infrequent large storms would have produced significant runoff, some of which would have recharged the underlying groundwater basin through streambed infiltration.

When precipitation falls on paved urban areas, most of it becomes runoff, which is essentially a new source of water. In the urban landscape, permeable areas are covered with vegetation that is carefully irrigated and cultivated or left unplanted and not irrigated. The soil underlying irrigated vegetation is maintained in a moist state and never completely dries out. The significance being that when soil is continuously moist, some of the irrigation water and precipitation can infiltrate beyond the root zone and recharge the underlying groundwater basin.

Each landuse type has specific water use and drainage characteristics that can change over time. Table 3-3 shows the water use characteristics that were assumed in the 1960 through 2006 calibration period of the 2007 Chino Basin Watermaster Groundwater Model. Table 3-4 shows the approximate changes in basin imperviousness associated with landuse changes. This table shows the impervious area for each landuse, based on the landuse time history listed in Table 3-2 and the total impervious area listed in Table 3-3. Moreover, Table 3-4 shows the total imperviousness as function of aggregated agricultural and urban uses and as a percentage of the total basin surface area. The total imperviousness was about 10 percent in 1949, increased to 24 percent by 1975, and reached about 46 percent by 2006.

Note that the while the groundwater model is calibrated from July 1960 through June 2006, the recharge hydrology is estimated from 1933 through 2006 because of the lag time between the deep infiltration of precipitation and applied water passing through the root zone and reaching the water table. Table 3-5 and Figure 3-3 show the estimated time history of the deep infiltration of precipitation and applied water that was developed for the calibration of the 2007 Watermaster Groundwater Model (WEI, 2007b). During the 1965 through 1974 base period that Carroll used to estimate safe yield, the deep infiltration of precipitation and applied water averaged about 113,000 acre-ft/yr. Carroll's estimate for the same period is 116,000 acre-ft/yr. During the last ten years of the calibration period, 1997 through 2006, the deep infiltration of precipitation and applied water averaged about 87,000 acre-ft/yr, a decline of about 26,000 acre-ft/yr. The increase in the deep infiltration of precipitation and applied water contribution from urban landuse has not offset the decrease in the deep infiltration of precipitation and applied water contribution from agricultural landuse. Due to the lag time associated with recharge leaving the root zone and reaching the water table, some of this

decrease in recharge has not been realized in the groundwater system. Figure 3-4 illustrates the time history of the deep infiltration of precipitation and applied water at the root zone and at the water table. Also, note the significance of the deep infiltration of precipitation and applied water contribution from agricultural landuse that occurred in the period before 1957.

### 3.3.2 Changes in Drainage

Figure 3-5 shows the stream systems that start in the San Gabriel Mountains and flow from the north to the south, crossing the Chino Basin. From about 1957 to present, the drainage areas overlying the valley floor have almost completely converted to urban uses, and all the streams have been converted from unlined to lined channels. The lining of these channels has almost completely eliminated stormwater recharge in the Chino Basin. Prior to the Chino Basin Facilities Improvement Program (CBFIP), there was some incidental recharge in stormwater retention basins. Figure 3-5 also shows the decades in which these stream channels were lined. Figure 3-6 shows the estimated recharge in these channels from 1933 through 2006. These estimates were prepared with the Rainfall, Runoff, Router, and Rootzone (R4) Model<sup>1</sup> (see Appendix C *Summary of the R4 Model for the Chino Basin*) for the development and calibration of the 2007 Chino Basin Watermaster Groundwater Model (WEI, 2007b). The decline in stormwater recharge spanning the period of 1959 through roughly the present correlates to channel lining. Using the 26-year period prior to 1959 as a baseline, the average stormwater recharge declined from about 16,000 acre-ft/yr to zero. Because stormwater recharge is highly concentrated in time and area, it generally reaches the groundwater table within a year. Note that during the base period for the Chino Basin safe yield determination, 1965 through 1974, stormwater recharge averaged about 12,000 acre-ft/yr.

While stormwater recharge declined from the Santa Ana River tributaries that cross the Chino Basin, the recharge of the Santa Ana River to the Chino Basin increased due to the increased stormwater and non-stormwater discharge carried by the River. Analysis of the annual reports of the Santa Ana River Watermaster, engineering working papers for the development of the Santa Ana River Judgment (Albert Web and Associates, 1969; Joint Engineering Committee, 1969) and the recent Santa Ana River White Paper prepared by SAWPA (WEI, 2010a) clearly demonstrates that stormwater and non-stormwater discharge in the reach of the Santa Ana River within the Chino Basin has increased significantly from the late 1970s to the present. This increase is largely due to urbanization, which has generated more stormwater discharge and recycled water discharges to the River. Figure 3-7a shows the time history of Santa Ana River discharge just below the Riverside Narrows at the point where the City of Riverside discharges to the River and the discharge at just below Prado Dam. The estimated recharge in the Santa Ana River is fairly consistent from year to year due to the recycled water discharged to the River with some large recharge years corresponding to large volumes of stormwater runoff (1978, 1980, 1983, 1993, 1998, and 2005). Figure 3-7b shows the projected time history of Santa Ana River recharge for the period of 2007 through 2030. The increase in

---

<sup>1</sup> The rainfall, runoff, and router modules of the R4 Model have been reported on in the literature as the Wasteload Allocation Model or WLAM. With the addition of the rootzone module the code was renamed R4.

Santa Ana River recharge is caused by the Chino Desalters and Watermaster's use of reoperation water for desalter replenishment.

### **3.3.3 Predicted Decline in Safe Yield from the Peace II Engineering Work in 2007**

Table 3-6 shows the hydrologic budget and estimated safe yield of the Chino Basin, based on the 2007 Chino Basin Watermaster Model simulation of the Peace II Alternative (WEI, 2009b). The estimated safe yield is shown graphically in Figure 3-8 for the calibration period and the Peace II projection period. The safe yield is estimated to change from about 145,000 acre-ft/yr during Carroll's 1965 through 1974 base period to about 143,000 acre-ft/yr in 1997 through 2006 and to about 131,000 acre-ft/yr in 2030. The future safe yield estimates presented herein are based on the methodology described in the next section.

### **3.3.4 Mitigation of the Loss of Safe Yield**

The analysis of the Peace II Agreement did not take the MS4 permit compliance of various cities and counties into account. The known compliance measures as of June 1, 2009 were compiled in the RMPU process and are listed in Section 5. In 2010, the Regional Water Quality Control Board (RWQCB) issued new MS4 permits to the Santa Ana Watershed parts of the Counties of Riverside and San Bernardino and the cities within the Santa Ana Watershed. These permits contain stormwater management requirements for stormwater that is generated from new development and will increase recharge in the Chino Basin.

Essentially, the new permits require that all stormwater generated from new development from a 24-hour, 85<sup>th</sup> percentile storm be detained and recharged on site if recharge is feasible; if recharge is not feasible, the stormwater must be detained and treated and subsequently discharged. In the Chino Basin, this roughly corresponds to 1 inch over 24 hours. The specific technologies for detention and recharge are to be developed by the landuse control entities. The landuse control entities are responsible for the inspection and maintenance of these new stormwater management facilities. The recharge facilities could include detention and sedimentation basins, recharge basins, dry wells, and managed swales.

As part of this investigation, projections of new stormwater recharge from the implementation of the 2010 MS4 permits were prepared. The land area that would be subject to the 2010 MS4 permits was estimated by comparing the ultimate land use map (Figure 3-2j) to the 2006 landuse map (Figure 3-2i). The R4 Model was used to estimate the increase in stormwater recharge from new development by applying the stormwater management criteria from the new MS4 permit for two conditions: (1) all of the stormwater managed pursuant to the MS4 permit is recharged and (2) half of the stormwater managed pursuant to the MS4 permit is recharged. No assumptions were made as to the specific new stormwater management facilities used to comply with the permits. Table 3-7 shows the new stormwater recharge that is projected to occur at build-out due to the implementation of the new MS4 permit. The table shows, by landuse control entity, the new recharge for the Chino Basin area watershed and the land overlying the Chino Basin. The new stormwater recharge created through permit

compliance is estimated to range from about 6,300 acre-ft/yr if half of the stormwater managed pursuant to the MS4 permit is recharged to about 12,600 acre-ft/yr if all of the stormwater managed pursuant to the MS4 permit is recharged. Implementation of the new MS4 permit will offset some of the lost recharge from landuse and drainage changes.

The R4 Model was also used to estimate the increase in stormwater recharge if the new MS4 permit were applied to the developed parts of the Chino Basin. These results are shown in Table 3-7. If applied to the developed areas, the new stormwater recharge created through permit compliance is estimated to range from about 19,000 acre-ft/yr if half of the stormwater managed pursuant to the MS4 permit is recharged to about 38,000 acre-ft/yr if all of the stormwater managed pursuant to the MS4 permit is recharged.

### 3.4 Recommended Method to Estimate Safe Yield

There is no period in the last 70 years where there is a hydrology representative of long term hydrologic and cultural conditions. The hydrology and safe yield have changed over time in response to the changes in landuse, drainage, and other water management practices. Therefore, to calculate safe yield, Watermaster needed to create a long-term stationary time series for recharge that is representative of the long-term hydrology as well as present and future cultural conditions. This was accomplished in the Peace II engineering work through the development of an expected value hydrology for year 2006 and year 2030 landuses, drainage, and water management practices. The Peace II engineering procedure consisted of the following steps:

- For each planning year (2006 and 2030), a 57-year (1959 to 2006) daily precipitation time history was used to estimate the deep infiltration of precipitation and applied water, runoff, stormwater recharge in Chino Basin recharge facilities, and recharge in the Santa Ana River.
- The expected or average recharge from each planning year was used for the planning years, and the recharge was linearly interpolated for intervening years.
- The projected groundwater production and supplemental water recharge was assigned to each year from 2006 through 2030 pursuant to planning projections and the replenishment requirements of the Judgment.
- The 2007 Chino Basin Groundwater Model was used to simulate the basin response to expected value hydrology, projected groundwater production, and projected supplemental water recharge.
- The safe yield was estimated using the modified Carroll method of equation 4 and a ten-year base period.

Table 3-6 and Figure 3-8 show the results of this process for the Peace II Alternative planning assumptions, which were originally reported in *2007 CBWM Model Documentation and Evaluation of the Peace II Project Description* (WEI, 2007b) and subsequently revised in *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b). This approach to estimating safe yield can be used by Watermaster to evaluate impacts on safe yield that result

from changes in groundwater management strategies, including varying the amount of groundwater production, varying the location of production, varying the magnitude and operating concepts for conjunctive use programs, and varying the location and magnitude of recharge.

Watermaster should also apply equation 4 to historical data as a verification of the modeling approach outlined above. Watermaster already collects groundwater production data and supplemental water recharge estimates. Computing the change in storage can be done based on groundwater elevation maps created at the beginning and end of the base period and comparable ground elevation maps for areas that are undergoing subsidence. Pursuant to Watermaster's Rules and Regulations, Watermaster staff will use this approach in fiscal year 2010-11 to do the first re-computation of safe yield.

### **3.5 Baseline Stormwater Recharge with Existing Recharge Facilities in 2010**

A 2010 estimate of stormwater recharge was developed to compare against the stormwater recharge estimates developed for the CBFIP projects prior to their construction and as a baseline to measure recharge improvements for the projects evaluated in Section 5 of this report. This baseline recharge estimate is the long-term average annual stormwater recharge from existing stormwater management facilities, including the CBFIP facilities constructed as part of the implementation of the OBMP. Recharge estimates were prepared for each recharge facility using the 57-year daily precipitation record that was used in the 2007 Peace II engineering work (WEI, 2007b) and the R4 Model. These estimates are based on the *2006 Chino Basin Recharge Facilities Operation Procedures Manual* (GRCC, 2006) with some operating procedure modifications, provided by the IEUA. The results are summarized in Table 3-8 for current conditions and build-out. The long-term average annual stormwater recharge with the recharge facilities existing in 2009-10 is estimated to be about 13,600 acre-ft/yr, and this recharge will increase slightly over time due to new stormwater generated by development that is not captured in the local recharge facilities required to comply with the 2010 MS4 permit.

Table 3-8 also shows the interrelationship of the new recharge created by compliance with the 2010 MS4 permit and recharge at the regional stormwater recharge facilities. Note that the stormwater recharge created through compliance with the 2010 MS4 permit actually reduces the future stormwater recharge that would otherwise occur at the regional stormwater recharge facilities in the absence of the 2010 MS4 permit, and thus the net new recharge created by the MS4 permit is reduced slightly to about 5,300 acre-ft/yr if half of the stormwater managed pursuant to the MS4 permit is recharged and about 10,500 acre-ft/yr if all of the stormwater managed pursuant to the MS4 permit is recharged.

### **3.6 Recharge Master Plan Update Implementation Items**

#### **3.6.1 Recomputation of the Safe Yield**

Watermaster should use the methodology described in Section 3.4 to recompute safe yield in



2010-11 and should apply this method every five years thereafter. The revised safe yield estimates can then be used by the water purveyors in the Chino Basin to prepare UWMPs and by Watermaster to complete Recharge Master Plan updates.

### **3.6.2 Mitigation of the Projected Loss of Safe Yield**

Section 3.3.4 describes the range of new stormwater recharge that could result from implementing the 2010 MS4 permit. Based on the requirements of the permit, the expected new stormwater recharge could range from about 5,300 acre-ft/yr (if 50 percent of the stormwater that is required to be managed by the permit is recharged) to about 10,600 acre-ft/yr (if 100 percent of the stormwater that is required to be managed by the permit is recharged).

Section 3.3.4 also describes the new recharge potential of existing developed areas. Applying the same criteria from the MS4 permit to developed areas yields, on average, between 19,000 acre-ft/yr and 38,000 acre-ft/yr of new recharge. Watermaster, working with the landuse control entities, should encourage development practices that will maximize the capture and recharge of stormwater. New recharge, as used herein, means the net new recharge created by the project.

The following should be implemented by the CBWCD, the IEUA, the Watermaster, and other stakeholders.

1. Watermaster should allocate new yield that is created by new recharge above that required by MS4 permit compliance to the owners of those projects that create new recharge. This will require the development of (a) new agreements involving Watermaster, project owners, and others; and (b) the development of new practices and procedures that can quantify new recharge during project development and subsequently verify that the new recharge is occurring during the project lifetime.
2. Watermaster, working with the Parties, should encourage the construction of local recharge projects in developed areas that will increase the capture and recharge of stormwater. The recommendations for local stormwater recharge projects in developed areas are the same as those for newly developed areas, articulated above.
3. In implementing the above, Watermaster should form a committee—consisting of itself, the landuse control entities, the County Flood Control Districts, the CBWCD, the IEUA, and others—to develop the monitoring, reporting, and accounting practices that will be required to estimate local project stormwater recharge and new yield. This committee should be formed immediately, and the monitoring, reporting, and accounting practices should be developed as soon as possible.

**Table 3-1  
Components of Safe Yield  
Adopted in the Chino Basin Judgment**

Hydrologic Component <sup>1</sup>	Annual Average	
	(acre-ft/yr)	(%)
<b><i>Inflows to the Chino Basin</i></b>		
Deep Percolation		
Precipitation and Surface Inflow	47,500	33%
Imported Water	7,000	5%
Irrigation		
Domestic	9,800	7%
Agriculture	51,900	36%
Artificial Recharge	3,900	3%
Recharge of Sewage	18,200	13%
Subsurface Inflow	7,200	5%
Total Inflow	<u>145,500</u>	100%
<b><i>Outflows from the Chino Basin</i></b>		
Subsurface Outflow	7,200	4%
Extractions	180,000	96%
Total Outflow	<u>187,200</u>	100%
<b><i>Hydrologic Balance</i></b>		
Estimated Annual Average Change in Storage 1965-1974	-40,000	
Safe Yield (equal to average annual extraction plus annual average change in storage)	<u>140,000</u>	

**Table 3-2**  
**Historical Landuse in the Chino Basin Area**  
(acres unless indicated otherwise)

Land Use Type	1933	1949	1957	1963	1975	1984	1990	2000	2006
Non-Irrigated Field Crops, Pasture, Fruits and Nuts	39,348	39,347	4,577	769	1,529	1,153	461	445	444
Irrigated Field Crops, Pasture, Fruits and Nuts	37,004	37,004	27,885	27,107	22,062	19,809	19,943	16,069	14,112
Irrigated and Non-Irrigated Citrus	18,206	18,179	9,460	4,562	2,100	2,205	607	706	402
Irrigated Vineyard	2,022	2,022	8,879	21,545	11,422	7,646	3,614	906	1,081
Non-Irrigated Vineyard	109	109	95	0	0	0	180	138	129
Dairies and Feedlots	226	224	4,604	5,097	7,846	8,074	8,523	7,921	7,865
Medium and High Density Urban Residential	7,926	7,930	9,972	19,818	22,544	24,730	30,532	35,272	38,020
Low Density Urban Residential	2,159	2,159	2,471	5,602	5,596	8,057	11,687	11,884	11,717
Commercial	2,072	2,072	3,550	4,728	5,660	6,976	8,790	15,340	15,330
Industrial	2,267	2,267	2,573	2,693	5,832	8,888	8,850	9,940	9,980
Special Impervious	992	992	1,013	1,136	1,208	5,063	5,800	7,480	7,500
Native Vegetation	4,662	4,662	7,381	6,143	6,060	6,018	5,326	5,274	5,290
Undeveloped	20,408	20,435	54,991	38,259	45,613	38,786	33,091	26,022	25,533
<b>Totals</b>	<b>137,402</b>	<b>137,402</b>	<b>137,450</b>	<b>137,459</b>	<b>137,474</b>	<b>137,405</b>	<b>137,403</b>	<b>137,398</b>	<b>137,403</b>
Aggregated by Landuse Group (acres)									
Agricultural	96,915	96,885	55,499	59,081	44,959	38,887	33,328	26,185	24,034
Urban	15,416	15,420	19,579	33,976	40,841	53,714	65,659	79,916	82,547
Undeveloped + Native Vegetation	25,070	25,097	62,372	44,402	51,673	44,804	38,416	31,297	30,822
<b>Total</b>	<b>137,402</b>	<b>137,402</b>	<b>137,450</b>	<b>137,459</b>	<b>137,474</b>	<b>137,405</b>	<b>137,403</b>	<b>137,398</b>	<b>137,403</b>
Aggregated by Landuse Group (percent of total)									
Agricultural	71%	71%	40%	43%	33%	28%	24%	19%	17%
Urban	11%	11%	14%	25%	30%	39%	48%	58%	60%
Undeveloped + Native Vegetation	18%	18%	45%	32%	38%	33%	28%	23%	22%
<b>Total</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>

Source: 2007 CBWM Groundwater Model Documentation and Evaluation of the Peace II Project Description (WEI, 2007)

**Table 3-3  
Imperviousness and Irrigation Properties**

Land Use Type	Total Imperviousness (%)	Evapotranspiration (ft/yr)	Irrigation Efficiency <sup>1</sup> (%)	Applied Water (ft/yr)	Irrigation Return (ft/yr)
Non-Irrigated Field Crops, Pasture, Fruits and Nuts	2	2.38	na	na	na
Irrigated Field Crops, Pasture, Fruits and Nuts	2	2.38	55 - 75	4.33 3.18	1.95 0.79
Irrigated and Non-Irrigated Citrus	2	2.53	60 - 80	4.22 3.16	1.69 0.63
Irrigated Vineyard	2	2.07	60 - 75	3.45 2.76	1.38 0.69
Non-Irrigated Vineyard	2	1.75	na	na	na
Dairies and Feedlots	10	na	na	na	na
Medium and High Density Urban Residential	75	3.06	75 - 75	4.08 4.08	1.02 1.02
Low Density Urban Residential	30	3.06	75 - 75	4.08 4.08	1.02 1.02
Commercial	90	3.50	75 - 75	4.67 4.67	1.17 1.17
Industrial	90	3.06	75 - 75	4.08 4.08	1.02 1.02
Special Impervious	95	na	na	na	na
Native Vegetation	2	0.74 to 3.50	na	na	na
Undeveloped	2	1.44	na	na	na

1. Irrigation efficiency corresponds to the current period for urban uses and to the period of time in which crops were principally grown. For example, citrus was flood irrigated when it was cultivated in the northern part of the Chino Basin area and, thus, has a low irrigation efficiency, whereas modern citrus cultivation utilizes drip irrigation with a much greater irrigation efficiency. Irrigation of turf and ornamental plants is assumed to occur by sprinkler irrigation, which is assumed to have an irrigation efficiency of 75 percent.

**Table 3-4**  
**Time History of Total Imperviousness of the Land Surface in the Chino Basin Area**  
**(acres unless indicated otherwise)**

Land Use Type	1933	1949	1957	1963	1975	1984	1990	2000	2006
Non-Irrigated Field Crops, Pasture, Fruits and Nuts	787								
Irrigated Field Crops, Pasture, Fruits and Nuts	740	740	558	542	441	396	399	321	282
Irrigated and Non-Irrigated Citrus	364	364	189	91	42	44	12	14	8
Irrigated Vineyard	40	40	178	431	228	153	72	18	22
Non-Irrigated Vineyard	2	2	2	0	0	0	4	3	3
Dairies and Feedlots	23	22	460	510	785	807	852	792	787
Medium and High Density Urban Residential	5,944	5,947	7,479	14,863	16,908	18,547	22,899	26,454	28,515
Low Density Urban Residential	648	648	741	1,681	1,679	2,417	3,506	3,565	3,515
Commercial	1,864	1,864	3,195	4,255	5,094	6,278	7,911	13,806	13,797
Industrial	2,040	2,040	2,316	2,423	5,249	8,000	7,965	8,946	8,982
Special Impervious	943	943	962	1,079	1,148	4,810	5,510	7,106	7,125
Native Vegetation	93	93	148	123	121	120	107	105	106
Undeveloped	408	409	1,100	765	912	776	662	520	511
<b>Totals</b>	<b>13,110</b>	<b>13,113</b>	<b>17,327</b>	<b>26,763</b>	<b>32,608</b>	<b>42,349</b>	<b>49,899</b>	<b>61,652</b>	<b>63,652</b>
Imperviousness as a Percent of Total Basin Surface	10%	10%	13%	19%	24%	31%	36%	45%	46%
Aggregated by Landuse Group (acres)									
Agricultural	1,169	1,169	1,387	1,574	1,496	1,401	1,339	1,148	1,101
Urban	11,440	11,443	14,693	24,301	30,078	40,052	47,791	59,877	61,934
Undeveloped + Native Vegetation	501	502	1,247	888	1,033	896	768	626	616
<b>Total</b>	<b>13,110</b>	<b>13,113</b>	<b>17,327</b>	<b>26,763</b>	<b>32,608</b>	<b>42,349</b>	<b>49,899</b>	<b>61,652</b>	<b>63,652</b>
Aggregated by Landuse Group (percent of total)									
Agricultural	9%	9%	8%	6%	5%	3%	3%	2%	2%
Urban	87%	87%	85%	91%	92%	95%	96%	97%	97%
Undeveloped + Native Vegetation	4%	4%	7%	3%	3%	2%	2%	1%	1%
<b>Total</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>

**Table 3-5**  
**Estimated Deep Infiltration of Precipitation and Applied Water**  
(acre-ft)

Year	Deep Infiltration of Precipitation and Applied Water					Year	Deep Infiltration of Precipitation and Applied Water				
	Aggregated Agricultural Landuse	Aggregated Urban Landuse	Undeveloped and Native Vegetation	Total Infiltration	Ten-Year Average Total Infiltration		Aggregated Agricultural Landuse	Aggregated Urban Landuse	Undeveloped and Native Vegetation	Total Infiltration	Ten-Year Average Total Infiltration
1933	117,144	8,001	4,781	129,926		1970	53,647	25,005	11,579	90,231	110,798
1934	129,287	9,842	7,408	146,537		1971	50,844	23,751	13,293	87,888	113,169
1935	128,925	11,618	7,294	147,837		1972	49,420	23,612	13,885	86,917	109,407
1936	128,717	9,801	8,628	147,147		1973	62,671	35,562	25,896	124,128	113,445
1937	162,944	15,995	16,678	195,617		1974	47,691	28,156	16,558	92,405	113,378
1938	150,389	13,556	12,084	176,028		1975	42,203	26,400	14,422	83,025	111,798
1939	131,628	10,797	8,159	150,584		1976	40,998	23,263	11,159	75,420	106,103
1940	126,982	11,067	8,077	146,127		1977	40,397	30,857	14,933	86,187	100,030
1941	176,095	18,402	19,006	213,503		1978	84,107	67,299	55,649	207,055	110,846
1942	106,491	8,388	3,599	118,478	157,178	1979	58,359	42,953	26,861	128,173	106,143
1943	154,485	13,991	12,481	180,957	162,281	1980	69,562	62,625	44,325	176,511	114,771
1944	145,079	12,005	11,873	168,957	164,523	1981	34,850	27,324	8,424	70,598	113,042
1945	127,084	10,386	8,751	146,221	164,362	1982	45,100	40,825	22,002	107,927	115,143
1946	121,479	9,066	6,724	137,269	163,374	1983	66,066	65,429	44,809	176,304	120,360
1947	129,569	9,695	7,926	147,190	158,531	1984	34,799	28,969	11,543	75,312	118,651
1948	104,957	7,238	2,721	114,916	152,420	1985	37,068	30,539	9,967	77,574	118,106
1949	108,219	7,472	4,680	120,370	149,399	1986	38,162	38,116	12,165	88,443	119,408
1950	117,609	9,826	7,150	134,585	148,245	1987	26,752	31,159	3,511	61,422	116,932
1951	90,174	7,156	2,286	99,616	136,856	1988	30,027	36,504	5,612	72,142	103,441
1952	139,053	16,756	24,986	180,794	143,088	1989	27,978	34,741	8,365	71,084	97,732
1953	86,472	9,159	8,163	103,794	135,371	1990	22,737	32,312	4,891	59,940	86,075
1954	88,183	12,200	13,206	113,589	129,834	1991	26,823	46,120	14,702	87,645	87,779
1955	74,924	10,527	10,449	95,901	124,802	1992	32,125	55,110	19,053	106,288	87,615
1956	71,504	11,356	13,399	96,259	120,701	1993	47,846	88,586	33,177	169,609	86,946
1957	56,528	10,283	11,678	78,489	113,831	1994	20,547	34,926	5,282	60,755	85,490
1958	100,242	24,918	46,400	171,559	119,496	1995	33,130	70,628	22,814	126,572	90,390
1959	52,560	11,440	5,603	69,603	114,419	1996	23,147	43,295	9,745	76,187	89,164
1960	57,724	14,293	7,025	79,042	108,865	1997	28,928	53,399	15,003	97,330	92,755
1961	49,339	12,530	2,311	64,180	105,321	1998	32,243	75,380	25,374	132,998	98,841
1962	81,060	25,679	17,794	124,533	99,695	1999	15,064	28,158	1,298	44,521	96,185
1963	57,112	20,462	6,178	83,752	97,691	2000	21,584	46,147	9,279	77,009	97,892
1964	61,365	23,304	8,403	93,072	95,639	2001	20,197	47,484	8,614	76,295	96,757
1965	64,597	22,231	12,001	98,829	95,932	2002	14,236	25,187	352	39,775	90,105
1966	79,112	32,276	20,976	132,365	99,542	2003	22,185	62,982	13,690	98,857	83,030
1967	83,863	38,984	24,077	146,924	106,386	2004	17,672	40,750	6,236	64,658	83,420
1968	61,772	25,337	11,778	98,888	99,119	2005	33,391	102,146	32,483	168,019	87,565
1969	91,340	45,855	38,012	175,207	109,679	2006	14,843	43,450	10,155	68,448	86791.0994

**Table 3-6**  
**Water Budget for Chino North, Chino East, Chino South, and Prado Basin Management Zones**  
**Peace II Alternative**  
(acre-ft)

	Inflows								Outflows					Change in Storage	Cumulative Change in Storage	Safe Yield
	Boundary Inflow	Temescal to PBMZ	Deep Percolation of Precipitation and Applied Water	Stream Recharge	Artificial Recharge			Subtotal Inflows	Production	PBMZ to Temescal	ET	Rising Groundwater	Subtotal Outflow			
					Storm	Imported Water	Recycled Water <sup>1</sup>									
2006	32,703	6,294	86,301	25,502	11,646	24,759	2,980	190,185	151,206	2,069	14,799	15,663	183,737	6,448	6,448	140,000
2007	32,703	6,355	82,094	28,349	11,646	0	2,340	163,486	174,244	2,058	14,469	14,283	205,053	-41,567	-35,119	140,000
2008	32,703	5,925	83,013	30,165	11,646	0	5,000	168,452	167,173	2,013	14,335	13,868	197,389	-28,937	-64,056	140,000
2009	32,703	5,418	83,671	31,743	11,646	0	5,000	170,181	181,868	1,986	14,132	13,299	211,285	-41,104	-105,160	140,000
2010	32,703	5,566	82,150	33,576	11,646	0	10,000	175,641	188,574	2,235	13,944	12,462	217,216	-41,575	-146,735	140,000
2011	32,703	5,509	81,850	34,952	11,646	0	10,500	177,159	186,659	2,305	13,835	12,006	214,806	-37,647	-184,382	134,127
2012	32,703	5,263	79,177	35,988	11,646	0	11,000	175,776	184,744	2,310	13,720	11,692	212,465	-36,689	-221,072	134,545
2013	32,703	4,987	78,267	36,703	11,646	0	11,500	175,806	182,828	2,304	13,614	11,453	210,198	-34,392	-255,464	134,844
2014	32,703	4,710	77,834	37,934	11,646	12,000	12,000	188,826	187,393	2,297	13,429	10,958	214,076	-25,250	-280,714	135,211
2015	32,703	4,441	77,243	39,030	11,646	77,556	12,500	255,119	185,477	2,289	13,243	10,498	211,507	43,612	-237,102	135,593
2016	32,703	4,181	76,196	39,207	11,646	77,056	13,000	253,989	186,953	2,284	13,148	10,337	212,721	41,268	-195,834	136,418
2017	32,703	3,937	75,761	39,045	11,646	76,556	13,500	253,148	188,429	2,278	13,109	10,312	214,128	39,020	-156,814	137,123
2018	32,703	3,709	74,232	38,761	11,646	76,056	14,000	251,107	189,905	2,273	13,101	10,352	215,631	35,476	-121,338	137,332
2019	32,703	3,499	73,531	38,551	11,646	0	14,500	174,430	191,380	2,268	13,108	10,416	217,172	-42,742	-164,080	137,170
2020	32,703	3,305	71,573	38,807	11,646	0	15,000	173,034	192,856	2,265	13,109	10,407	218,637	-45,603	-209,682	136,695
2021	32,703	3,123	71,111	39,222	11,646	0	15,900	173,705	195,925	2,262	13,090	10,346	221,624	-47,919	-257,601	136,055
2022	32,703	2,953	70,147	39,853	11,646	0	16,800	174,102	198,994	2,260	13,043	10,200	224,497	-50,395	-307,997	135,529
2023	32,703	2,792	68,772	40,458	11,646	72,356	17,700	246,427	202,064	2,257	12,979	10,023	227,323	19,104	-288,893	134,947
2024	32,703	2,643	67,887	40,762	11,646	71,456	18,600	245,696	205,133	2,256	12,926	9,903	230,218	15,478	-273,415	134,188
2025	32,703	2,501	66,934	41,110	11,646	70,556	19,500	244,949	208,202	2,254	12,880	9,797	233,133	11,816	-261,599	133,281
2026	32,703	2,369	66,058	41,464	11,646	69,656	20,400	244,295	210,632	2,247	12,824	9,684	235,387	8,908	-252,690	132,413
2027	32,703	2,243	65,444	41,819	11,646	68,756	21,300	243,911	213,062	2,239	12,765	9,558	237,623	6,288	-246,402	131,603
2028	32,703	2,122	64,550	42,301	11,646	36,000	22,200	211,521	215,492	2,232	12,715	9,440	239,879	-28,358	-274,760	130,964
2029	32,703	2,009	64,037	43,098	11,646	0	23,100	176,594	217,922	2,226	12,654	9,267	242,069	-65,475	-340,236	130,485
2030	32,703	1,906	63,215	43,919	11,646	0	24,000	177,388	220,852	2,221	12,581	9,081	244,735	-67,347	-407,583	130,210
Total	817,567	97,759	1,851,046	942,320	291,150	732,765	352,320	5,084,927	4,827,967	55,686	333,549	275,308	5,492,510	-407,583		
Average	32,703	3,910	74,042	37,693	11,646	29,311	14,093	203,397	193,119	2,227	13,342	11,012	219,700	-16,303		
Maximum	32,703	6,355	86,301	43,919	11,646	77,556	24,000	255,119	220,852	2,310	14,799	15,663	244,735	43,612		
Minimum	32,703	1,906	63,215	25,502	11,646	0	2,340	163,486	151,206	1,986	12,581	9,081	183,737	-67,347		

1 -- These recycled water recharge projections predate the IEUA May 2010 Recycled water recharge estimates.

**Table 3-7**  
**Stormwater Recharge from Future Development from Compliance with the 2010 MS4 Permits and Potential New**  
**Recharge if the Same Requirements Were Applied to the Current Developed Areas**  
 (acre-ft)

Landuse Control Entity	Undeveloped Area <sup>1</sup>		Developed Area <sup>2</sup>	
	100% Recharge	50% Recharge	100% Recharge	50% Recharge
Claremont	3	2	84	42
Montclair	82	41	1,638	819
Upland	210	105	2,377	1,189
Rancho Cucamonga	1,721	861	6,692	3,346
Fontana	1,616	808	5,018	2,509
Rialto	145	72	862	431
Ontario	3,934	1,967	9,840	4,920
Chino	1,787	893	3,358	1,679
Chino Hills	33	16	223	111
Pomona	38	19	566	283
San Bernardino County	589	294	3,731	1,866
Riverside County	2,423	1,212	3,735	1,867
Others	0	0	0	0
<b>Total</b>	<b>12,581</b>	<b>6,290</b>	<b>38,126</b>	<b>19,063</b>


1 -- Represents a range of recharge that is expected to occur through implementation of the 2010 MS4 permit

2 -- Represents a theoretical estimate of what might be possible if the 2010 MS4 permit were applied to all existing developed areas



**Table 3-8  
Expected Theoretical Stormwater Recharge at CBFIP Facilities**

Basins	Recharge with 2006 Land Use Condition  (acre-ft)	Average Annual Future Stormwater Recharge at CBFIP Facilities for Buildout Conditions and Varying Amounts of New Runoff Management Pursuant the MS4 Permits		
		No New Recharge  (acre-ft)	50% Recharge  (acre-ft)	100% Recharge  (acre-ft)
Brooks	672	713	697	680
College Heights	0	0	0	0
Montclair #1	290	325	312	300
Montclair #2	118	130	127	125
Montclair #3	274	276	275	274
Montclair #4	341	345	343	342
8th St	785	789	787	785
7th St	438	445	441	438
Upland	479	637	582	528
Ely	1,366	1,411	1,390	1,368
Etiwanda Debris	883	1,617	1,369	1,105
Hickory	213	231	224	213
Lower Day	555	637	603	568
San Sevaine #1	903	1,048	993	935
San Sevaine #2	117	161	149	139
San Sevaine #3	652	747	714	659
San Sevaine #4	68	93	84	73
San Sevaine #5	1,124	1,926	1,683	1,448
Turner 1&2	752	814	784	756
Turner 3&4	733	772	754	735
Victoria	561	937	812	674
Grove	259	268	264	260
Banana	445	483	465	445
Decléz	912	995	960	912
RP3	444	466	466	466
Wineville	239	296	274	252
<b>Total</b>	<b>13,625</b>	<b>16,562</b>	<b>15,555</b>	<b>14,480</b>
MS4 Decision Impact on CBFIP Facilities		0	-1,007	-2,081
Estimated Recharge at New MS4 Facilities			6,290	12,581
Net MS4 Recharge Due to Reduction at Existing Facilities			5,283	10,499



- Chino Basin Hydrologic Boundary
  - Adjudicated Chino Basin
  - OBMP Management Zone Boundary
- ### Geology
- Water-Bearing Sediments**
- Quaternary Alluvium
- Consolidated Bedrock**
- Undifferentiated Pre-Tertiary to Early Pleistocene Igneous, Metamorphic, and Sedimentary Rocks
- Faults**
- Location Certain
  - Location Uncertain
  - Location Approximate
  - Location Concealed
  - Approximate Location of Groundwater Barrier
- ### Other Features
- Existing Chino 1 Desalter Well
  - Existing Chino 2 Desalter Well
  - Proposed Chino Creek Well
  - Groundwater Divides
  - Flood Control/Conservation Basins
  - Streams, Rivers, and Channels

Produced by:  
**WILDERMUTH**  
 ENVIRONMENTAL INC.  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB  
 Date: 20100412  
 File: Figure\_3-1.mxd



2010 Recharge Master Plan Update

## Legal and Hydrologic Boundaries of the Chino Basin

Figure 3-1



- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2a.mxd



  
 2010 Recharge Master Plan Update

1933 Land Use in the Chino Basin Area

Figure 3-2a




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2b.mxd



  
 2010 Recharge Master Plan Update

1949 Land Use in the Chino Basin Area

Figure 3-2b




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2c.mxd



  
 2010 Recharge Master Plan Update

1957 Land Use in the Chino Basin Area

Figure 3-2c



- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2d.mxd



  
 2010 Recharge Master Plan Update

1963 Land Use in the Chino Basin Area

Figure 3-2d




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2e.mxd



  
 2010 Recharge Master Plan Update

1975 Land Use in the Chino Basin Area

Figure 3-2e




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2f.mxd




  
 2010 Recharge Master Plan Update

1984 Land Use in the Chino Basin Area

Figure 3-2f





- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2g.mxd



  
 2010 Recharge Master Plan Update

1990 Land Use in the Chino Basin Area

Figure 3-2g



- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2h.mxd



  
 2010 Recharge Master Plan Update

2000 Land Use in the Chino Basin Area

Figure 3-2h




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
**WILDERMUTH**  
 ENVIRONMENTAL INC.  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: FIB/MJC  
 Date: 20100412  
 File: Figure\_3-2i.mxd



2010 Recharge Master Plan Update

2006 Land Use in the Chino Basin Area

Figure 3-2i




- ### Land Use
- Non-Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated Field Crops, Pasture, Fruit and Nuts
  - Irrigated and Non-Irrigated Citrus
  - Irrigated Vineyard
  - Non-Irrigated Vineyard
  - Dairies and Feedlots
  - Urban Residential
  - Special Impervious
  - Native Vegetation
  - Low Density Urban Residential
  - Commercial
  - Industrial

- ### Other Features
- Chino Basin Hydrologic Boundary
  - Rivers, Creeks, and Flood Control Channels



Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: FIB  
 Date: 20100412  
 File: Figure\_3-2j.mxd




2010 Recharge Master Plan Update


Projected 2025 Land Use in the Chino Basin Area


Figure 3-2j

**Figure 3-3**  
**Time History of Deep Infiltration of Precipitation and Applied Water for the Chino Basin**



**Figure 3-4**  
**Recharge past the Root Zone and Recharge at the Water Table**





**Time Periods in Which Channel Segments Were Lined**

- 1950 - 1959
- 1960 - 1969
- 1970 - 1979
- 1980 - 1989
- 1990 - 1999

**Other Features**

- Chino Basin Hydrologic Boundary
- Rivers, Creeks, and Flood Control Channels
- Flood Control/Conservation Basins
- Drainage Area Contributing to the Chino Basin



Produced by:  
**WILDERMUTH**  
 ENVIRONMENTAL INC.  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: FIB  
 Date: 20100412  
 File: Figure\_3-5.mxd




2010 Recharge Master Plan Update

**Time History of Channel Lining**


**Figure 3-5**

**Figure 3-6**  
**Streambed Infiltration by Creek in the Chino Basin**







**Figure 3-7a**  
**Comparison of Santa Ana River Discharge over the Chino Basin and Santa Ana River**  
**Streambed Recharge into the Basin**



**Figure 3-7b**  
**Projected Santa Ana River Streambed Recharge into the Basin**



**Figure 3-8**  
**Comparison of Safe Yield Estimates for the Calibration and Peace II Periods**



## Section 4 – Integrated Review of Water Supply Plans

---

The objectives of the work described herein are to produce future groundwater production projections and associated replenishment requirements for the Chino Basin parties that use the Chino Basin for all or part of their water supply. In the OBMP planning that was conducted in the late 1990s and in the Peace Agreement, which was approved in 2000, it was assumed that the Watermaster parties and others would construct recharge capacity to meet all of Watermaster’s replenishment needs through “wet” water recharge. The first step in this process is to develop projected water demand and supply plans for each party. These water demands include aggregated demands as well as individual draws on the various water supplies available to the parties. The annual replenishment requirement is estimated from aggregated Chino Basin production projections, the production rights contained in the Chino Basin Judgment, and amendments thereto. This section specifically addresses the RMPU requirements set forth in items 1 and 5 of the November 2007 Special Referee’s report to the Court, which read as follows:

1. Baseline conditions must be clearly defined and supported by technical analysis. The baseline definition should encompass factors such as pumping, demand, recharge capacity, total Basin water demand, and availability of replenishment water.
5. Total demand for groundwater should be forecast for 2015, 2020, 2025, and 2030. The availability of imported water for supply and replenishment, and the availability of recycled water should be forecast on the same schedule. The schedules should be refined in each Recharge Master Plan update. Projections should be supported by thorough technical analysis.

In this section, item 1, with the exception of recharge capacity and the availability of replenishment water, is fully addressed. For item 5, the projected groundwater production (demand), recycled water recharge, and replenishment requirements are developed and discussed. The availability of recycled water and imported water for replenishment is discussed in detail in Section 6.

### 4.1 Water Supply Plans for All Entities That Use the Chino Basin

Several municipal and private water purveyors and private users in the Chino Basin area depend in part or completely on Chino Basin groundwater. Figure 4-1 shows the service areas of Chino Basin area water purveyors. The IEUA consulted with the major water service purveyors and, in 2008, developed a basin wide water demand and supply plan for all municipal water purveyors that produce Chino Basin groundwater (IEUA, 2008). The IEUA-developed water supply plans and groundwater production plan were vetted through the Watermaster process during the summer of 2008 and accepted by the appropriators in September 2008. Watermaster developed similar projections for smaller groundwater producers. These projections were used by the IEUA in the environmental documentation for the proposed Dry Year Yield program expansion and the environmental documentation

for the Peace II Agreement. The table below contains the aggregate water demand and supply projection prepared by the IEUA and Watermaster.

**Macro Water Demand and Supply Plan for the Chino Basin**  
(acre-ft/yr)

Water Sources	2009-10 <sup>1</sup>	2014-15	2019-20	2024-25	2029-30
Chino Basin Groundwater	145,811	188,878	192,127	207,864	220,514
Non Chino Groundwater	33,200	33,200	33,200	33,200	33,200
Local Surface Water	16,918	16,490	16,990	17,990	17,990
Imported Water from Metropolitan	84,578	83,449	84,449	84,449	84,449
Recycled Water for Direct Reuse	18,800	33,870	34,520	34,570	34,570
<b>Total Demand</b>	<b>299,307</b>	<b>355,887</b>	<b>361,286</b>	<b>378,073</b>	<b>390,723</b>

Source: 2008 IEUA Water Supply Plan (attached as Appendix B) for large agencies and the *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009) for small agencies, small water companies and private well owners

1 -- 2009-10 Chino Basin groundwater production is actual 2009-09 production.

The total water demand is projected to grow about 91,000 acre-ft/yr through the planning period with most of the growth in demand projected to occur in the early part of planning period. With the exception of Chino Basin groundwater production and recycled water, the supply sources—non Chino Basin groundwater, local surface water, and imported water from Metropolitan for direct use—were assumed to be constant over the planning period. Chino Basin groundwater production increases about 75,000 acre-ft/yr over the planning period, resulting in a total increase of about 52 percent. Recycled water for direct reuse increases by about 15,000 acre-ft/yr during the early part of the planning period and then levels off after 2020, resulting in a total increase of about 84 percent.

The IEUA had stated that certain factors in its 2008 water demand and supply projections may reduce future water demands. These factors, updated to 2010, include:

- The continued slowdown of the housing market, which will delay increases in water demand and, thus, the need for additional water supplies;
- Enhanced regional conservation efforts and programs in response to continued statewide dry conditions and environmental restrictions on Sacramento-San Joaquin River Delta (Delta) pumping; and
- The SB-7 requirement for a statewide 10-percent reduction in water use by 2015 and a 20-percent reduction by 2020.

The water demands projected by the IEUA and Watermaster are probably higher than will actually occur. Reductions in water demand from conservation generally reduce the use of the most expensive water supply(s) available to a water purveyor, which has, in the past, been imported water that is served for municipal and industrial uses. Thus, it's possible that even with new conservation efforts, the groundwater production projections used herein could be

representative of future conditions. That said, it is also possible that the cost of replenishment may be the most expensive water use in the future due to the scarcity of low cost replenishment water and the cost to recharge.

## **4.2 Projection of Chino Basin Groundwater Production and Replenishment**

Watermaster recharges supplemental water into the Chino Basin pursuant to the Judgment and the Peace Agreement. Total annual replenishment is calculated based on projected groundwater production, recharge facility capacity, and the following assumptions:

- The safe yield is 140,000 acre-ft/yr through 2010 and the 2007 Watermaster Model-calculated safe yield (WEI, 2009b) thereafter.
- The Judgment allows a 5,000 acre-ft/yr controlled overdraft of the Chino Basin through 2017.
- Reoperation water is allocated to the replenishment of CDA desalter production as provided for in the Peace II Agreement and updated in the report prepared to satisfy Condition Subsequent No. 7 (WEI, 2008). Reoperation water is completely used up by 2030.
- The 6,500 acre-ft/yr supplemental water recharge commitment to MZ1 pursuant to the Peace II Agreement.
- Recycled water recharge was assumed to occur pursuant to Watermaster and the IEUA's recharge permit (Order R8-2007-0039) as amended in October 2009 (Order R8-2009-0057) and as projected by the IEUA (IEUA, 2010).
- Post 2010 increase in stormwater recharge due to new development and redevelopment that is captured in existing stormwater recharge facilities and as a result of compliance with the 2010 Municipal Separate Storm Sewer System (MS4) Permit.

Table 4-2 contains the projected groundwater production from Table 4-1, the various components of production rights and total production rights, the projected replenishment obligation, and the cumulative replenishment obligation. Total production rights are about 187,000 acre-ft/yr in 2010 and generally decrease over time to about 159,000 acre-ft/yr through 2035. The decrease is due to the declining yield, the exhaustion of controlled overdraft in 2017, the programmatic decline in reoperation water, the exhaustion of reoperation water in 2030, and an assumed termination of the 6,500 acre-ft/yr supplemental water recharge commitment to MZ1. Watermaster's replenishment obligation was estimated using the following assumptions:

- Water in storage accounts at the start of fiscal year 2009-10 is not used to meet future replenishment obligations. This is a conservative assumption that reserves discretion regarding the use of this water to individual storing parties.
- On a go forward basis, under-producers will transfer un-pumped rights to over-producers each year; that is, there is an efficient market that moves unused production

rights from under-producers to over-producers.

For this investigation, the average annual replenishment obligation was assumed to be equal to the greater of zero and the difference between actual production and production rights. The replenishment obligation for the 2008 IEUA/Watermaster groundwater production scenario is projected to be zero in 2009-10 through 2012-13, jump to about 3,000 acre-ft/yr in 2013-14 as the amount of reoperation water starts to ratchet down to 10,000 acre-ft/yr, increase steadily to about 45,000 acre-ft/yr by 2029-30, jump to 55,000 acre-ft/yr in 2030-31, and increase very slightly thereafter due to a small decline in projected safe yield. This assumes that under-producers will transfer un-used production rights to over-producers each year; as previously stated, there is an efficient market that moves unexercised rights from under-producers to over-producers. This assumption will underestimate the replenishment obligation for some years. Though, over the long term, this assumption is valid because the appropriator parties cannot store unused production rights indefinitely, and the demand for replenishment water will provide financial incentives for unused production rights to be sold to over-producers. Figure 4-2 shows the projected groundwater production for the 2008 IEUA/Watermaster groundwater production projection as a stacked bar chart that consists of the production rights and replenishment obligations for each year in the planning period. The cumulative replenishment obligation is projected to be negative through 2021-22, implying that under-production and the MZ1 recharge mandated by the Peace II Agreement are being stored in appropriator storage accounts and subsequent replenishment obligations are being met from unused production rights via the efficient market assumption. After 2021-22, the cumulative replenishment obligation becomes positive and grows as the unused production rights are not sufficient to meet the replenishment obligation. In theory, this means that Watermaster could go ten years without purchasing imported water for replenishment if an efficient market for unused production rights exists.

### **4.3 Recharge Master Plan Implementation Items**

The December 21, 2007 Court order requires the completion of this RMPU by July 1, 2010 and, at a minimum, every five years thereafter. The RMPU process is very sensitive to projected groundwater production. By statute, groundwater production projections are prepared for UWMPs every five years and in years ending in “0” or “5.” Watermaster, the CBWCD, and the IEUA should review the groundwater production projections from the retail water purveyors’ 2010 UWMPs after their completion in June 2011<sup>2</sup> to update the groundwater production projections included herein and revise the conclusions and recommendations of the 2010 RMPU to comport with the 2010 UWMPs. Conclusions in Section 6 regarding the acquisition of supplemental water for replenishment and new supplemental water recharge facilities should be updated in fiscal 2011-12. Decisions regarding the acquisition of supplemental water for replenishment and new supplemental water recharge facilities should be deferred until that time.

---

<sup>2</sup> The deadline for completing the 2010 UWMPs for retail water agencies was extended by special legislation to June 30, 2010 for the 2010 UWMP. Subsequent UWMPs are required to be submitted to the DWR by December 31 of year due.

The next complete RMPU should be completed no later than December 2016, and subsequent RMPUs should be completed, at a minimum, every five years thereafter. This will ensure that the most up-to-date groundwater production estimates are included in future RMPUs.



**Table 4-1**  
**Projected Groundwater Production for the Chino Basin**  
**Based on August 2008 IEUA/Watermaster Estimates<sup>1</sup>**  
**(acre-ft/yr)**

Producer	Production Projection					
	2009/10 <sup>2</sup>	2014/15	2019/20	2024/25	2029/30	2034/35
<b>Overlying Agricultural Pool</b>						
Combined total Agricultural Pool Production	32,143	18,577	5,010	5,010	5,010	5,010
<b>Overlying Non-Agricultural Pool</b>						
San Bernardino County (Chino Airport)	94	94	94	94	94	94
California Steel Industries Inc	1,126	1,126	563	563	563	563
Swan Lake Mobile Home Park	36	36	36	36	36	36
Vulcan Materials Company	5	5	5	5	5	5
Space Center Mira Loma Inc.	94	94	94	94	94	94
Angelica Textile Service	31	31	31	31	31	31
Sunkist Growers Inc	43	43	43	43	43	43
Praxair Inc	113	113	0	0	0	0
General Electric Company	10	10	10	10	10	10
California Speedway	505	505	505	505	505	505
RRI Etiwanda	536	536	268	268	268	268
<i>Subtotal Overlying Non-Agricultural Pool Production</i>	<i>2,593</i>	<i>2,593</i>	<i>1,649</i>	<i>1,649</i>	<i>1,649</i>	<i>1,649</i>
<b>Appropriative Pool</b>						
Arrowhead Mountain Spring Water Company	350	350	350	350	350	350
Chino Desalter Authority	26,356	39,400	39,400	39,400	39,400	39,400
City of Chino	2,244	10,844	11,811	14,900	14,900	14,900
City of Chino Hills	1,990	4,823	4,823	4,823	4,823	4,823
City of Norco	0	0	0	0	0	0
City of Ontario	13,222	27,211	32,360	37,508	42,658	42,658
City of Pomona	11,731	13,000	13,000	13,000	13,000	13,000
City of Upland	1,021	2,140	2,140	2,140	2,140	2,140
Cucamonga Valley Water District	11,006	21,229	26,729	32,229	37,729	37,729
Fontana Union Water Company	0	0	0	0	0	0
Fontana Water Company	13,202	10,000	11,000	11,500	12,000	12,000
Jurupa Community Services District	17,160	18,123	21,616	21,616	21,616	21,616
Inland Empire Utilities Agency	0	0	0	0	0	0
Marygold Mutual Water Company	142	142	142	142	142	142
Metropolitan Water District of Southern California	0	0	0	0	0	0
Monte Vista Irrigation Company	0	0	0	0	0	0
Monte Vista Water District	9,519	17,000	18,500	20,000	21,500	21,500
Niagara	1,210	1,210	1,210	1,210	1,210	1,210
San Antonio Water Company	992	1,149	1,282	1,282	1,282	1,282
San Bernardino County (Olympic Facility)	22	22	22	22	22	22
Santa Ana River Water Company	160	318	335	335	335	335
Golden State Water Company	748	748	748	748	748	748
West End Consolidated Water Company	0	0	0	0	0	0
West Valley Water District	0	0	0	0	0	0
<i>Subtotal Appropriators</i>	<i>111,075</i>	<i>167,709</i>	<i>185,468</i>	<i>201,205</i>	<i>213,855</i>	<i>213,855</i>
<b>Total Production</b>	<b>145,811</b>	<b>188,878</b>	<b>192,127</b>	<b>207,864</b>	<b>220,514</b>	<b>220,514</b>

1 -- IEUA developed estimates for the Appropriative Pool and Watermaster developed estimates for the other two pools.

2 -- 2009/10 production estimates are based on actual 2008/09 production reported in the FY 2008/09 Watermaster Annual Report and excluding Dry Year Yield Program production

**Table 4-2**  
**Projected Groundwater Production and Production Rights**  
 (acre-ft)

Fiscal Year	Projected Groundwater Production 2008 IEUA / Watermaster Projection per Table 4-1	Pre 2010 RMPU Production Rights								Replenishment Obligation <sup>3</sup>	Cumulative Replenishment Obligation
		Safe Yield <sup>1</sup>	Controlled Overdraft	Reoperation Water	6,500 acre-ft/yr Supplemental Water Recharge in MZ1 per Peace II <sup>5</sup>	Mid-Range Recycled Water Recharge <sup>4</sup>	Post 2010 Increase in Stormwater Recharge from Development <sup>2</sup>	Post 2010 Increase in Stormwater Recharge from 2010 MS4 Compliance	Total		
2009 - 2010	145,811	140,000	5,000	28,910	6,500	8,100	0	0	188,510	0	-33,699
2010 - 2011	154,424	134,127	5,000	31,500	6,500	14,100	150	265	191,642	0	-70,916
2011 - 2012	163,038	134,545	5,000	33,740	6,500	16,000	300	530	196,615	0	-104,494
2012 - 2013	171,651	134,844	5,000	11,909	6,500	17,800	450	795	177,298	0	-110,141
2013 - 2014	180,265	135,211	5,000	10,000	6,500	19,100	600	1,060	177,471	2,794	-107,347
2014 - 2015	188,878	135,593	5,000	10,000	6,500	20,000	750	1,325	179,168	9,710	-97,636
2015 - 2016	189,528	136,418	5,000	10,000	6,500	20,700	900	1,590	181,108	8,420	-89,216
2016 - 2017	190,178	137,123	5,000	10,000	6,500	21,000	1,050	1,855	182,528	7,649	-81,567
2017 - 2018	190,827	137,332	0	10,000	6,500	21,000	1,200	2,120	178,152	12,675	-68,892
2018 - 2019	191,477	137,170	0	10,000	6,500	21,000	1,350	2,385	178,405	13,072	-55,820
2019 - 2020	192,127	136,695	0	10,000	6,500	21,000	1,500	2,650	178,345	13,782	-42,038
2020 - 2021	195,274	136,055	0	10,000	6,500	21,000	1,650	2,915	178,120	17,154	-24,884
2021 - 2022	198,421	135,529	0	10,000	6,500	21,000	1,800	3,180	178,009	20,412	-4,472
2022 - 2023	201,569	134,947	0	10,000	6,500	21,000	1,950	3,445	177,842	23,727	19,256
2023 - 2024	204,716	134,188	0	10,000	6,500	21,000	2,100	3,710	177,498	27,218	46,474
2024 - 2025	207,864	133,281	0	10,000	6,500	21,000	2,250	3,975	177,006	30,858	77,332
2025 - 2026	210,394	132,413	0	10,000	6,500	21,000	2,400	4,240	176,553	33,841	111,173
2026 - 2027	212,924	131,603	0	10,000	6,500	21,000	2,550	4,505	176,158	36,766	147,939
2027 - 2028	215,454	130,964	0	10,000	6,500	21,000	2,700	4,770	175,934	39,520	187,459
2028 - 2029	217,984	130,485	0	10,000	6,500	21,000	2,850	5,035	175,870	42,114	229,573
2029 - 2030	220,514	130,210	0	10,000	6,500	21,000	3,000	5,300	176,010	44,504	274,077
2030 - 2031	220,514	130,010	0	0	6,500	21,000	3,000	5,300	165,810	54,704	328,781
2031 - 2032	220,514	129,810	0	0	6,500	21,000	3,000	5,300	165,610	54,904	383,685
2032 - 2033	220,514	129,610	0	0	6,500	21,000	3,000	5,300	165,410	55,104	438,789
2033 - 2034	220,514	129,410	0	0	6,500	21,000	3,000	5,300	165,210	55,304	494,093
2034 - 2035	220,514	129,210	0	0	6,500	21,000	3,000	5,300	165,010	55,504	549,596
Total	5,145,884	3,476,779	40,000	276,058	169,000	514,800	46,500	82,150	4,605,287	659,737	
Average	197,919	133,722	1,538	10,618	6,500	19,800	1,788	3,160	177,126	25,375	

1 -- Safe yield includes stormwater recharge from the CBFIP


2 -- This is the increase in stormwater recharge that will occur due to increased imperviousness from new development.

3 -- This is the net replenishment obligation based on the assumptions described in the text.

4 -- Mid-range Projection from Table 2 of the IEUA May 4, 2010 *Integrated Review of Water Supply Plans Used for the Chino Basin Recharge Master Plan Update IEUA Tech Memo No. 3* (Appendix B to this report)

5 -- Pursuant to the Peace II Agreement.

6 -- Replenishment will be required when the CURO becomes positive.




- Main Features**
- Water Service Area Boundaries
- Geology**
- Water-Bearing Sediments**
- Quaternary Alluvium
- Consolidated Bedrock**
- Undifferentiated Pre-Tertiary to Early Pleistocene Igneous, Metamorphic, and Sedimentary Rocks
- Faults**
- Location Certain
  - Location Approximate
  - Location Concealed
  - Location Uncertain
  - Approximate Location of Groundwater Barrier
- Other Features**
- Existing Chino Desalter Well
  - Proposed Chino Desalter Well
  - Groundwater Flow Model Boundary
  - Flood Control/Conservation Basins
  - Streams, Rivers, and Channels




Produced by:  
**WILDERMUTH**  
 ENVIRONMENTAL INC.  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100322  
 File: Figure\_4-1.mxd



**Figure 4-2**  
**Projected Groundwater Production in the Chino Basin**  
**For the 2008 IEUA/Watermaster Production Projection**



## Section 5 – Storm Water Recharge Enhancement Opportunities

---

### 5.1 Introduction

The CBWCD is a part of the team undertaking the RMPU. The RMPU is being coordinated by Watermaster through its engineer, WEI.

The first task of the CBWCD is in two parts: Part 1 is to identify and comment on current storm water recharge facilities and operations, and evaluate the effectiveness of local storm water facilities and policies intended to improve storm water recharge; Part 2 is to identify and perform preliminary conceptual project evaluations of potential improvements to existing facilities and new facilities located in places where there is uncaptured flow leaving the Chino Basin to determine if projects are potentially viable and warrant further consideration.

This first task analyses will determine if storm water is currently being captured and recharged by local storm water facilities that is unaccounted for in the Chino Basin Surface Water Simulation R4 model developed and operated by WEI and if there is a significant amount of available and obtainable storm water that could be directed to recharge facilities. An increase in storm water recharge in an amount greater than previously accounted for in a base period condition would represent an increase in supply to the Chino Basin, thus augmenting safe yield for the same base period condition. Additional recharge could offset overdraft as well as decrease the amount of supplemental water purchased by Watermaster to maintain hydrologic balance in the basin. The addition of new or previously unaccounted for storm water recharge would lessen the projected decline of the calculated annual safe yield.

The second task of CBWCD is to evaluate the conceptual projects identified in the first phase of project evaluations, and additional project alternatives identified with WEI, develop a regional Recharge Distribution System and estimate its capability to cost effectively improve storm water recharge in the Chino Basin.

The regional Recharge Distribution System developed with WEI is comprised of various improvements, enlargements and reoperations of existing facilities and construction of new diversion and recharge facilities to increase the amount of storm water recharge in the Chino Basin. The improvements would enable existing facilities which currently operated nearly exclusively for flood control purposes to operate in a multipurpose capacity to also divert and regulate storm water flows for transferred to other recharge facilities.

Conceptual project evaluations for alternatives and project components developed by the RMP update team are being performed to develop an economic basis for comparison of projects or project components. This evaluation will enable further discussions of project viability and ultimately lead to decisions of project implementation.

## 5.2 Existing Storm Water Management and Recharge

There is a long history of storm water recharge in the Chino Basin. The results of some previous analyses suggest that the opportunity to significantly increase recharge is limited, primarily due to the nature of the timing of precipitation and runoff. The flow in creeks and channels is usually less than the inlet capacity of the existing recharge basins, meaning that most of the time all of the flow can be captured with existing facilities. However, in large storm events some recharge basins are unable to divert all available flow because the rate of flow greatly exceeds the capacity of intake structures. Consequently recharge opportunities are lost.

The majority of data regarding current physical and operational parameters of regional basins presently utilized for the analysis of storm water recharge is readily available. The data is available primarily through WEI, San Bernardino County Flood Control District (SBCFCD), and Inland Empire Utilities Agency (IEUA), the operator of the basins. WEI prepared a “Chino Basin Recharge Facilities Operation Procedures” manual (ROM) for the Groundwater Recharge Coordinating Committee in March 2006. This document is the most complete available reference for the regional basins presently utilized for recharge. In some cases data was found in WEI documents prepared prior to the ROM. The information contained herein, discussed in section 5.2.1, is based in part on the information contained in the ROM.

Additional basins are described that were not included in the March 2006 document because they are primarily “flow through” basins that have been concluded to have poor infiltration rates and are accordingly operated for flood control purposes. Current physical and operational parameters for these basins are not as readily available. The physical parameters contained herein for non-recharge basins were primarily obtained from the SBCFCD, where available. The majority of data was gleaned from available construction drawings as well as the SBCFCD Project Systems Inventory Zone 1 Index which was completed in 1976, and personal communication with SBCFCD staff.

Local storm water recharge sites within the Chino Basin are discussed in section 5.2.2. These sites were identified by individual cities in response to a data request letter mailed in March 2009. Collection of local storm water management information proved to be difficult because such sites are largely associated with development projects and are accordingly privately owned and maintained. The cities hadn’t previously prepared inventories of such sites and in some cases still do not have the staff or the budget to prepare an inventory for the purposes of this RMP. The majority of the data contained herein was taken from portions of Water Quality Management Plans (WQMP) provided by each contributing entity. Most of the WQMP portions provided contain all relevant data regarding the physical parameters of the storm water retention facilities as well as their tributary drainage areas. Facilities identified by the various cities, that were unaccompanied by provided portions of a WQMP, were mapped using an ArcGIS program. The facility and its tributary drainage area, with contributions from city storm drains, were then delineated using ArcGIS, 2007 aerial imagery, USGS 7.5 minute quadrangles, and city storm drain atlases (when available).

## **5.2.1 Existing Regional Storm Water Recharge Facilities and Policies Related to Storm Water Management and Recharge**

Existing regional recharge basins developed for use in the Chino Basin recharge system (see Figure 5-1) are operated both for peak flood discharge attenuation as well as for the recharge of storm and supplemental water. The majority of the facilities are owned independently by either SBCFCD or CBWCD. The system is operated primarily by IEUA and is managed in order to benefit the flood control interests of SBCFCD, to recharge storm water and supplemental water for CBWCD and Watermaster in Chino Basin.

Recharge basins are served by eight main concrete lined channels and storm drains that collect storm water runoff throughout the Chino Basin. A total of 46 regional basins are classified as recharge basins to the Chino Groundwater Basin, totaling over 3,700 acre-ft of storage volume. The basins are further distinguished as either conservation or multi-purpose basins. There are 27 conservation basins operated to recharge storm water and supplemental water. The 19 multi-purpose basins are operated primarily for peak flood discharge attenuation and secondarily for the recharge of storm and supplemental water. Tables 5-1 and 5-2 identify the available physical and operational parameters for each regional recharge basin. Basins are grouped according to the water supply channel that is the primary source for the basin.

An additional 9 regional basins, with a total storage volume of over 2,600 acre-ft, are identified in Table 5-3 which are within the Chino Basin boundary, but are not operated for groundwater recharge purposes. These basins are not operated for groundwater recharge largely due to poor soil infiltration rates. These basins are primarily flow through basins that attenuate water for flood control purposes. Further study is required to determine if any improvements could be made to these basins in order to increase their recharge capabilities. According to personal communication with IEUA staff, Princeton Basin could potentially infiltrate recharge if properly maintained and operated as a recharge basin. CBWCD found that Lower Cucamonga and Chris Basins were underlain by a thick clay layer. The Wineville Basin was studied and determined to not be viable due to shallow clay lenses, however recent experience with Lower Day Basin indicates the clay lenses may result from gravel mining activity and remediation may be possible. Jurupa Basin was studied and found to percolate poorly. It is essentially used currently for water transfers to RP3 Basins, and is used to some degree as a settling basin prior to pumping to RP3. According to personal communication with SBCFCD staff, Merrill and Linden Basins are being evaluated for potential use as multi-purpose facilities. Currently they are being operated as flood control facilities.

### **5.2.1.1 General Operations for Recharge Basins**

Conservation basins are generally operated according to rule curves which define a target water surface elevation and storage for each basin throughout the year. Basin operation depths vary by season depending on the availability of supplemental and storm water, but are generally maintained at or below a maximum depth. Rule curve designations for conservation basins are shown in columns L through Q on Table 5-1.

Multi-purpose basins are operated based on storm forecasting and the goal of limiting losses

of supplemental water. Accordingly, the basins are operated to limit supplemental water losses by limiting storage to the volume of water that can be percolated out of the basin in seven days. If the total volume of a basin can percolate in seven days, the maximum allowable storage is maintained with one foot of freeboard. Rule curve designations for multi-purpose basins are shown in columns I through P on Table 5-2.

The following are current general operational practices for recharge basins:

#### Conservation Mode

- Monitor depth of water in basins either on site or remotely through SCADA.
- Monitor infiltration rates to determine delivery rate.
- Inspect diversion and inlet structures to maintain functionality.
- Monitor water depth at rubber dams for signs of clogging.
- Unclog inlet structures and rubber dams as needed.
- Reduce flow rate to match infiltration capacity as water level reaches maximum level allowed in rule curve.

#### Pre-Storm Mode

- Assess basin states and forecast storm intensity using the National Oceanic and Atmospheric Administration's (NOAA) National Weather Service website.
- If a forecast calls for measurable rainfall at 30% chance of rain or greater, 2-3 days before forecasted storm event, determine if expected storm will be significant and what actions are to be taken.
- A significant storm is considered to be 0.3 inches of rainfall per hour or 2.0 inches per 24 hours.
- Pre-Storm mode begins when potentially significant storm has been forecasted to occur within 7 days by NOAA.
- If significant storm is pending:
  - SBCFCD will contact IEUA coordinator.
  - Cease or curtail all supplemental water deliveries.
  - Cease diversions.
  - Open outlet gates at multipurpose basins to drain them and fully restore flood control capacity.

#### Storm Mode

- Rubber dams to be deflated (depending on when in the season a storm is occurring).
- Basins operated according to separate rules.
- Do not deliver supplemental water.
- When a significant storm is over or nearly over the SBCFCD will authorize transition



from Storm Mode to Conservation Mode:

- First phase
  - Inspect water turbidity for suspended mud (currently a visual observation).
  - Inspect basins, determine water level, and assess available storage.
  - Close outlets and/or open inlets at conservation basins.
- Second phase
  - Re-inflate the rubber dams

Tables 5-1 and 5-2 also include the main control elements for the transfer of water from either the channels to the basins, from basin to basin, or through a configuration of cells within a basin. The operation of each control element varies with a forecasted storm's severity. The typical settings for the first storm, non-significant storm, and significant storm are shown in columns W through Y on Table 5-1 and columns V through X on Table 5-2. Control elements are also operated based on flood control operation alert modes. The alert mode can be green, yellow, or red depending on a storm's severity. In general, the basins are operated in green and yellow alert modes during dry periods and non-significant storms. Basins are operated in red alert mode in the event of a significant storm. The control elements are operated either manually or remotely by the IEUA operator in green mode. In the yellow alert mode the control element settings are basically the same as in green mode, the yellow alert mode is essentially a signal from the IEUA operator to SBCFCD that the operator is aware of a forecasted storm and the proper measures have been taken to prepare the basins for the storm. The red alert mode signals control of the system by SBCFCD and includes a series of automatic system setting changes that are required by SBCFCD for flood control purposes.

IEUA developed automatic control settings (through the SCADA system) that are dependent on water surface elevations in order to maximize recharge during the green and yellow operational alert modes while allowing for proper flood control precautions. These settings would not function in the red alert mode. The flood control valve automation modes are described below in the more detailed descriptions of operations within the various storm channel systems. The automation modes allow automatic inlet gate operation under certain water level conditions. Prior to the development and implementation of the automation modes, the IEUA operator was required to manually change flow control valve positions using the SCADA system.

The five inflatable rubber dams also can be operated according to three mode settings. The rubber dams can be set to either maintain a desired water depth in the channel (level mode), a desired pressure on the dam (pressure mode), or manually inflated or deflated (manual mode). The result is a controlled release over the dam and/or through the inlet of a recharge basin. During a large storm event the rubber dams are set to level mode in order to maintain a desired water level. The dams have a failsafe measure in the form of an auto-deflate float switch that is designed as a control measure to deflate a dam once water overtops the depth of the float trigger. The automatic setting information for each rubber dam is shown in Table 5-

4.

Some of the basins, as indicated below, follow a procedure during particular storm events in order to limit the amount of debris, dust, dirt, and pollutants that can accumulate in channels from urban impervious areas (such as streets and parking lots) entering the recharge basins, thus minimizing maintenance. Such an event is referred to as a first flush opportunity. The rate of accumulation of debris and pollutants can vary depending on the area tributary to each basin. However, the current operating procedure for first flush opportunities is performed only in advance of the first storm event of the season or following a 30 day period lacking rainfall runoff. This is accomplished by closing inlet gates to the recharge basins for the first two hours of such an event.

### **5.2.1.2 General Operations for Recharge Basins**

#### **5.2.1.2.1 San Antonio Creek System**

The IEUA Groundwater Recharge Coordinator will be in close contact with the Army Corps of Engineers regarding the discharge of storm water from San Antonio Dam during all operational modes.

##### First Flush Opportunity

In advance of the first flush opportunity, an IEUA Operator closes the following inlet gates for the San Antonio Creek System:

- SAC-CHW-A to College Heights West.
- SAC-CHE-A to College Heights East.
- SAC-UPL-A to Upland Basin.
- SAC-MT1-A to Montclair No. 1.
- SAC-BRK-A to Brooks Street Basin.

When the IEUA Groundwater Recharge Coordinator determines that the turbidity of the storm water is acceptable (visual observation) and significant inlet clogging debris has passed the site, an IEUA Operator can divert storm water into the College Heights, Upland, Montclair, and Brooks Street Basins. The IEUA Operator will then use the SCADA system to open the aforementioned inlet gates.

##### Storm Water Capture

College Heights Basins:

- Basins are only used when water is released from San Antonio Dam by Army Corp of Engineers.

Upland Basin:

- Water is conveyed to the basin via City of Upland storm drains.

- Basin is also used for water released from San Antonio Dam by Army Corp of Engineers.

#### Montclair Basins:

- The inlet gate SAC-MT1-A from San Antonio Channel will generally remain open to divert storm water into Montclair No. 1 (MT1) until the inlet gate is closed when the water surface elevations in all four basins are equal to or greater than their spill elevation to the next basin and open when any of these are lower than its spill elevation to the next basin (Montclair No. 1: elevation 1127.6, Montclair No. 2: elevation 1102.4, Montclair No. 3: elevation 1055.46, Montclair No. 4: elevation 1037.0).

#### Brooks Basin:

- In auto-mode, inlet gate SAC-BRK-A from San Antonio Channel closes when the Brooks Basin water level sensor (LT-0208) is greater than or equal to elevation 898.5 and opens when water level sensor LT-0208 is greater than or equal to elevation 913.0, about two feet before spilling towards an adjacent property.
- In auto-mode, inlet gate from the West State Street storm drain closes when LT-0208 is greater than or equal to elevation 907.9 (the flow line elevation of the West State St Storm Drain is 907.88) and opens when LT-0208 is less than 907.8, and also opens when LT-0208 is greater than or equal to elevation 913 (allows for outflow if basin is too full from street runoff).

### **5.2.1.2.2 West Cucamonga Channel System**

#### First Flush Opportunity

Basins in the West Cucamonga Channel System are all multi-use basins (flow through), which require no special provisions for first flush opportunities. A first flush bypass is not applicable.

#### Storm Water Capture

The following are the procedures to operate the 7<sup>th</sup> and 8<sup>th</sup> Street and Ely Basins for the recharge of storm water for a storm that has a non-significant precipitation forecast:

#### 7<sup>th</sup> and 8<sup>th</sup> Street Basins:

- Close sluice gate 7TH-WCC-M. This gate should remain closed throughout the storm unless the SBCFCD directs the IEUA Operator to open it during or following the storm.
- In auto-mode, the outlet gate to 7<sup>th</sup> Street Basin 8SS-7TH-A opens when the 8<sup>th</sup> Street Basin water level sensor (LT-0501) is greater than or equal to elevation 1139.5 and closes when LT-0501 is less than or equal to elevation 1139.
- The automated outlet gate to the continuation of the West Cucamonga Creek Channel opens when the 7<sup>th</sup> Street Basin water level sensor (LT-0502) is greater than or equal

to elevation 1134.5 and closes when LT-0502 drops to elevation 1134.0 (Outlet spillway elevation = 1134.0).

Ely Basins:

- Automated outlet gate to the continuation of the West Cucamonga Creek Channel EL3-WCC-A opens when the Ely Basin No. 3 water level sensor (LT-0602) is greater than or equal to elevation 835.5 and closes when LT-0602 is less than or equal to elevation 835.0 (Outlet spillway elevation is 837.0, CBWCD and SBCFCD contract establishes elevation 835.0 as approved water surface elevation for storage and recharge).

The following are the procedures to operate the 7<sup>th</sup> and 8<sup>th</sup> Street and Ely Basins for the recharge of storm water for a storm that has a significant precipitation forecast:

7<sup>th</sup> and 8<sup>th</sup> Street Basins:

- The 8SS-7TH-A, 7TH-WCC-A, and 8SN-8SS-M gates should be opened 24 hours prior to the storm's arrival and the basins should be fully drained to restore full flood control function before the storm starts.
- Near the end of the significant storm, the IEUA Groundwater Recharge Coordinator can, through coordination with SBCFCD, close sluice gates 8SS-7TH-A and 7TH-WCC-A.

Ely Basins:

- The EL3-WCC-A gate should be opened 24 hours prior to the storm's arrival and the basins should be drained to the elevation of the gate (829 feet msl) in order to restore full flood control function before the storm starts. EL3-WCCA should be closed before the storm begins. Automated sluice gate EL3-WCC-A is programmed to open when the water level in the Ely 3 Basin (EL3) reaches elevation 835 feet msl. The SBCFCD is responsible to ensure that EL3-WCC-A is either closed or open pursuant to SBCFCD storm operations procedures.
- Near the end of the significant storm, the IEUA Groundwater Recharge Coordinator can, through coordination with SBCFCD, close sluice gate EL3-WCC-A.

### **5.2.1.2.3 Riverside Drive Drain**

#### First Flush Opportunity

There are no special provisions for a first flush opportunity.

#### Storm Water Capture

Grove Basin:

- The basin spills to the street, accordingly the outlet is kept closed for non-significant storms.
- The outlet flow control gate to Grove Ave. closes when the Basin's water level sensor

(LT-1900) is less than or equal to elevation 747.5 after being at a higher elevation. A CBWCD & SBCFCD contract establishes the bottom 5 feet as approved for storage & recharge; the floor elevation is about 742.5.

- For a significant storm SBCFCD will typically open the outlet about 6% to let the basin drain slowly without flooding the surface street.

#### **5.2.1.2.4 Cucamonga/Deer Creek Channels System**

##### First Flush Opportunity

In advance of a first flush opportunity, the IEUA Operator shall close all inlet gates to the Turner Basins (DRC-TR1-A, DRC-TR4-A, and CCC-TR1-A). When it is determined that the turbidity of the storm water is acceptable and significant inlet clogging debris has passed the site, the IEUA Groundwater Recharge Coordinator will divert storm water into the Turner Basins. The IEUA Operator will then open sluice gates DRC-TR1-A, DRC-TR4-A, and CCC-TR1-A.

##### Storm Water Capture

Turner Basins:

- Open inlet gate from the Cucamonga Creek Channel CCC-TR1-A. In auto-mode, this gate is automated to close when the Turner Basin No. 1 water level sensor (LT-1100) is greater than or equal to elevation 999.0 (about one foot the below concrete spillway to Turner Basin No. 2).
- Inflate the rubber dam in Cucamonga Creek.
- Open DRC-TR1-A and/or DRC-TR4-A, inlet gates from the Deer Creek Channel, (depending on the storage space available for storm water recharge in Turner Basin 1 and Turner Basins 3 and 4, respectively).
- DRC-TR1-A is automated to close when the Turner Basin No. 1 water level sensor (LT-0208) is greater than or equal to elevation 981.0 (Deer Creek channel floor).
- DRC-TR4-A is automated to close when the Turner Basin No. 4 water level sensor (LT-1200) is greater than or equal to elevation 981.0.
- Automated inlet gate from Turner Basin No. 1 TR1-TR2-A closes when the Turner Basin No. 2 water level sensor (LT-1101) is greater than or equal to elevation 987.5 (the Basin No. 2 spillway elevation).

#### **5.2.1.2.5 Day Creek Channel System**

##### First Flush Opportunity

Prior to the first flush opportunity, Day Creek Channel inlet gate to Lower Day Cell 1 DYC-LD1-A shall be closed and the rubber dam will be deflated. Sluice gate DYC-LD1-A shall remain closed and the rubber dam deflated until the SBCFCD authorizes sluice gate DYC-LD1-A be opened and the rubber dam inflated when it is determined that the turbidity of the

storm water is acceptable and significant inlet clogging debris has passed the site. The IEUA Groundwater Recharge Coordinator will then divert storm water into the Lower Day Basin.

#### Storm Water Capture

The following are the procedures to operate the Lower Day Basin for the recharge of storm water for a storm that has a non-significant precipitation forecast:

- The IEUA Groundwater Recharge Coordinator will open the inlet sluice gate to Lower Day Cell 1 (DYC-LD1-A), open manual sluice gates LD1-LD2-M & LD2-LD3-M, and close Lower Day Cell 3 outlet sluice gate LD3-DYC-M.
- Automated outlet gate from Cell 3 LD3-DYC-A opens when the water level on LT-0902 is greater than or equal to elevation 1386, and closes when elevation is less than or equal to 1386 (top of soffit of uncontrolled outlet). Coincidentally, the inlet flow control gate to Cell 1 should close when LD3-DYC-A opens.

The following are the procedures to operate the Lower Day Basin for a storm that has a significant precipitation forecast:

- Sluice gate LD3-DYC-M should be opened 24 hours prior to the storm's arrival and the basin should be fully drained before the storm starts.
- Sluice gate DYC-LD1-A shall be closed and the rubber dam deflated.

#### **5.2.1.2.6 Etiwanda and San Sevaine Channels System**

##### First Flush Opportunity

The settings for all operable control elements in the Etiwanda and San Sevaine Creeks System are listed in Tables 5-1 and 5-2. The settings for the first flush opportunity were established to bypass debris accumulation in the channels and thus minimize maintenance. The following inlet gate is closed prior to the first storm for this purpose:

- Automated sluice gate SSC-VBN-A, San Sevaine Channel outlet/inlet to Victoria Basin North.

##### Storm Water Capture

The typical settings for gates and rubber dams within the Etiwanda and San Sevaine Creek Basins for the recharge of storm water for storms that have either a non-significant or significant precipitation forecast are also listed in Tables 5-1 and 5-2. Automated gate controls in the Etiwanda and San Sevaine Creeks System are as follows:

Victoria Basin:

- The outlet flow control gate to the Etiwanda Creek Channel from Victoria Basin VBS-ETI-A opens when Cell 1 water level sensor (LT-1300) is greater than or equal to elevation 1324.5 (15.5 feet deep) and closes when LT-1300 is less than or equal to elevation 1323.9 (outlet spillway elevation is about 1333; Top of SBCFCD spill/box structure is about 1323.9).

### **5.2.1.2.7 West Fontana Channel System**

#### First Flush Opportunity

The settings for all operable control elements in the West Fontana Channel System are listed in Table 5-1. The following inlet gate is closed prior to the first flush opportunity:

- Automated sluice gate SSC-HKW-A, San Sevaine Channel inlet to Hickory West Cell.

#### Storm Water Capture

The typical settings for gates and rubber dams within the West Fontana Channel Basins for the recharge of storm water for storms that have either a non-significant or significant precipitation forecast are also listed in Table 5-1. Automated gate controls in the system are as follows:

Banana Basin:

- The outlet flow control gate to the West Fontana Channel from Banana Basin BAN-WFC-A opens when the Banana Basin water level sensor (LT-0100) is greater than or equal to elevation 1143.5 and closes when LT-0100 is less than or equal to elevation 1143.0 (outlet spillway is 1143.0).

Hickory Basin:

- The divider levee flow control gate between the east and west halves of the Hickory Basin HKE-HKW-A opens when the Hickory Basin east water level sensor (LT-0700) is greater than or equal to elevation 1117.5 (7.5 feet) and closes when LT-0700 drops to elevation 1117.0.
- The inlet from San Sevaine Channel gate to Hickory Basin closes when LT-0701 is greater than elevation 1111.5 and opens 6% when it is less than or equal to elevation 1111.5.

### **5.2.1.2.8 Declez Channel System**

#### First Flush Opportunity

The settings for all operable control elements in the Declez Channel System are listed in Tables 5-1 and 5-2. The following are the policies for first flush opportunities in the Declez Channel System:

- Automated sluice gate DZC-FC-A, Declez Channel outlet/inlet to Feeder Channel, is closed prior to the first flush opportunity.
- The first flush bypasses the RP3 basin but is allowed to enter Declez Basin Cell No. 1. Cell No. 1 is a habitat area that can receive water with higher turbidity.

#### Storm Water Capture

The typical settings for gates and rubber dams within the Declez Channel Basins for the recharge of storm water for storms that have either a non-significant or significant precipitation forecast are also listed in Tables 5-1 and 5-2. Gate controls in the system are as

follows:

Declez Basin:

- The flow control gate between Declez Basin Cells No. 1 and No. 2 DB1-DB2-A opens when the Basin's Cell No. 1 water level sensor (LT-0402) is greater than or equal to elevation 831.5 and closes when LT-0402 is less than or equal to elevation 831.0.
- The flow control gate between Declez Basin Cells No. 2 and No. 3 DB2-DB3-A opens when the Basin's Cell No. 2 water level sensor (LT-0401) is greater than or equal to elevation 830.0 and closes when LT-0401 is less than or equal to elevation 829.5 (top of the existing levee is 830.0).
- The outlet flow control gate from Declez Basin to the continuation of the Declez channel DB3-DZC-A opens when the Declez cell #3 water level sensor (LT-0400) is greater than or equal to elevation 831.5 and closes when LT-0400 is less than or equal to elevation 831.0.

RP3 Basin:

- Inlet gate DZC-FC-A, Declez Channel outlet/inlet to Feeder Channel will remain open in a storm event.
- Manual gate FC-JS-M, Feeder Channel to RP3 Junction Structure, will typically remain closed in a storm event until Cell No. 1 is full.
- Manual gate FC1-M, Feeder Channel Flow Control, will typically remain closed in a storm event until Cell No. 3 is full.

## **5.2.2 Local Storm Water Recharge Facilities and Policies Related to Storm Water Management and Recharge**

Local storm water management practices and LID identified in the Chino Basin are primarily utilized in conjunction with urban development projects and are accordingly privately owned and maintained facilities. As a result of urbanization, storm water runoff accumulates significant amounts of pollution before returning to a natural water body. The primary function of such facilities is to remove pollutants from runoff. All management practices described herein remove pollutants by utilizing some method of infiltration of runoff through the soil. Accordingly, a secondary function of such facilities is to recharge storm water to the groundwater basin.

The potential amount of water recharged to the groundwater basin as a result of such local storm water management practices may not have been previously modeled and considered in the estimation of the safe yield of the Chino Basin. We evaluated the possibility that water collected in newly constructed local storm water treatment facilities reduces water that would otherwise be captured by existing regional facilities and accordingly has no net effect on previous estimates of storm water recharge. A consequence of storm water retention by local facilities is the potential increase in evaporation. Descriptions of local storm water



management practices, contained herein, are based on information collected from individual entities within the Chino Basin.

### **5.2.2.1 Storm Water Recharge Facilities Identified by Chino Basin Entities**

New developments and significant re-developments are required to include facilities to manage storm water runoff commonly referred to as Best Management Practices (BMP). The BMPs are designed according to the Pollutants of Concern (POC) as well as any Hydrologic Conditions of Concern that are specific to each development site. The management of POCs is required by various regulatory decisions such as the federal Clean Water Act 402(p) National Pollutant Discharge Elimination System (NPDES) and the State of California Porter Cologne Act. Developments in the Chino Basin must adhere to the requirements adopted by the Santa Ana Regional Water Board in the NPDES Permit No. CAS618036. Compliance with the permit requires that a WQMP be implemented for such projects. The WQMP template describes steps to be taken for various projects in order to reduce short and long term adverse impacts resulting from the development. The WQMP identifies categories of project types for which a WQMP is required, BMP selection, and operations and maintenance of the BMPs identified.

A total of 260 storm water management project sites were identified by entities within the Chino Basin, utilizing about 569 BMPs (see Figure 5-2). Specific projects are discussed in section 5.2.2.1.2 below. Varying types of BMPs are described in section 5.2.2.1.1 below. The primary sources of information for general descriptions of the effectiveness and maintenance of typical BMPs were the California Storm Water Quality Association (CASQA) BMP Handbooks. We also consulted “Storm Water Best Management Practices in an Ultra-Urban Setting: Selection and Monitoring” prepared by U.S. Department of Transportation (DOT) Federal Highway Administration and Storm Water Technology Fact Sheets prepared by the United States Environmental Protection Agency (EPA).

Each BMP has the potential to recharge storm water to the groundwater basin. However, the recharge effectiveness of a BMP depends not only on the infiltration capacity of its underlying soil matrix but also on regular maintenance. A BMP more prone to failure than others and requires more diligent maintenance might be less effective for recharge, or more expensive.

#### **5.2.2.1.1 Best Management Practices (BMPs)**

##### **5.2.2.1.1.1 Infiltration/Detention Basins**

There were 133 infiltration basins identified by local Chino Basin entities. An infiltration basin is a shallow impoundment designed to temporarily retain storm water for the purpose of infiltration. New development projects often are designed in conjunction with an infiltration basin in order to capture localized urban storm water runoff, particularly the first flush. The first flush of a storm often times will include higher amounts of pollutants and debris. An advantage of an infiltration basin is that they can serve large drainage areas. DOT suggests infiltration basins serve areas between 5 and 50 acres, though some serve much larger areas. Some basins incorporate a forebay in order to settle out sediment before water is conveyed to

the infiltration cells of the basin, limiting maintenance necessary for the majority of the basin. If maintained properly, this practice can have a high efficiency associated with its recharge capabilities, while limiting groundwater contamination.

#### Effectiveness/Maintenance

In order to perform properly, infiltration basins must be constructed of well drained permeable soils in areas with good geologic/hydraulic conductivity with groundwater, thus limiting the number of potentially efficient sites. Infiltration basins constructed in an area of low permeability may quickly become congested with sediment and debris and require more frequent inspections and maintenance. Conversely, if a site is constructed of more coarse materials there is a higher risk of groundwater contamination.

According to CASQA, improperly maintained infiltration basins have a high failure rate. To maintain efficient infiltration, facilities require maintenance by scarification or discing. The policy for maintenance of infiltration basins is to scarify when there are performance issues, such as clogging or significant loss of infiltrative capacity, rather than on a routine basis. CASQA suggests a typical basin should maintain an infiltration rate of 72 hours or less to prevent mosquito and other vector habitats. Trash and debris typically has to be removed at the beginning and end of the wet season. Erosion control can also be an issue and the ground must be stabilized.

#### **5.2.2.1.1.2 Vegetated Swale/Bio-swale**

Vegetated swales are long, open, shallow channels with vegetation (typically grass) covering the side slopes and bottom. 186 swales were identified as part of a storm water management system by local Chino Basin entities. The majority of the vegetated swales identified in the Chino Basin were constructed adjacent to parking lots. These swales are utilized as an aesthetic alternative to curbs or gutters in the storm water drainage system to collect and convey runoff. Storm water runoff is designed to move slowly through the swale where it is filtered by the vegetation in the channel, through a subsoil matrix, and into underlying soils. Water which does not percolate is conveyed to downstream discharge points, often times to an infiltration basin or infiltration trench.

#### Effectiveness/Maintenance

As with any storm water treatment practice, swales are susceptible to failure if not properly maintained. According to CASQA, in order to perform properly, a thick vegetative cover (typical grass height of 6 inches) must be maintained. Typical maintenance can require little more than landscape maintenance activities such as irrigation, mowing, reseeding, etc. The accumulation of debris and sediments must be limited for proper infiltration. Proper infiltration requires slow moving flow which can sometimes require the addition of shallow berms or check dams to increase contact time. Accordingly, vegetated swales are rendered ineffective during periods of high flow velocities.

#### **5.2.2.1.1.3 Underground Chamber Vault**

DOT states that underground chamber vaults are used to attenuate storm water runoff in

urban areas that are very limited in space for other options. Modern chamber vaults are open bottom, perforated, corrugated, polypropylene structures primarily constructed under parking lots for the management of storm water in commercial or municipal sites. Storm drains convey underground to the chambers through inlet pipes. Storm water is attenuated in the chamber vaults and allowed to infiltrate through the open bottoms through surrounding angular aggregate. There were 33 underground chamber vault systems identified by local Chino Basin entities.

#### Effectiveness/Maintenance

As with any storm water management system reliant on infiltration, the effectiveness of the underground chamber vaults depends on the percolation capacity of the soil. If the chamber vaults are properly maintained they can be effective for very long periods of time. “Stormtech”, a commonly used manufacturer of vaults, suggests that systems of underground chamber vaults be constructed with an isolator row wrapped in a filter fabric. The isolator row is intended to capture the first flush of a storm event and remove sediment from runoff before it enters other chambers. The isolator row is typically constructed with an inspection port to visually inspect the chamber. Sediment can also be measured through the inspection port. Excess sediment can be vacuumed from the chamber through access manholes. Proper maintenance of drain inlets and catch basins will also limit debris entering the chamber vaults.

#### **5.2.2.1.1.4 Infiltration Trench**

Similar to vegetated swales, infiltration trenches are long and narrow trenches designed to treat small drainage areas. However, unlike vegetated swales, infiltration trenches are filled with rocks and are not meant to convey water and outlet runoff to downstream discharge points. Many of the 71 infiltration trenches identified by local Chino Basin entities are used in conjunction with vegetated swales. Runoff is stored in the void space between the stones and infiltrates through the bottom and into the soil matrix.

#### Effectiveness/Maintenance

Due to the limitation on drainage area, infiltration trenches are accordingly limited on recharge amount. Infiltration trenches perform well for removal of fine sediment and associated pollutants. However, infiltration trenches typically require some form of pretreatment (such as a vegetative swale) to remove more coarse sediment. Ineffective pretreatment will lead to frequent clogging of infiltration trenches and once clogged, the infiltration functionality is difficult to restore. According to CASQA, similar to infiltration basins, the trenches should be maintained to sustain an infiltration rate of 72 hours or less to prevent creating mosquito and other vector habitats. Due to the difficulty associated with repairing clogged trenches, most of the maintenance is concentrated on the pretreatment practices upstream of the trench to ensure that the more coarse sediment does not reach the infiltration trench.

#### **5.2.2.1.1.5 Pervious Pavement**

Pervious pavement is a storm water recharge practice that can be incorporated into the design of a typical parking lot or low traffic volume roads. According to CASQA, the pervious pavement system is comprised of two layers of functioning material. The top layer is a porous

load bearing surface constructed of a material (porous concrete or porous asphalt) that allows storm water to pass through to the second layer. The underlying second layer is comprised of a material designed for attenuation prior to infiltration for groundwater recharge or, if the soil type isn't suitable for recharge, drainage to a controlled outlet. A total of 16 systems identified by local Chino Basin entities utilize pervious pavement.

#### Effectiveness/Maintenance

Pervious pavement is an unobtrusive option for storm water treatment and groundwater recharge. Improper maintenance can result in clogging, which can then lead to ponding. However, pervious pavement is relatively simple to clean or replace should failure occur. Routine maintenance can simply include proper care of adjacent landscaping to limit debris or prevent soil from being washed onto the pavement. Regular street sweeping and vacuuming is necessary to clean the surface. If properly maintained, pervious pavement can treat runoff for small drainage areas and are an inexpensive option in confined urban areas in which other treatment options are limited.

#### **5.2.2.1.1.6 Drywell**

A total of 124 drywells were identified by the City of Ontario as a BMP for local storm water management. The “MaxWell” drywell system is the most common product used in the storm water management systems incorporated into the development projects identified by Ontario. According to the Torrent Resources, Inc. the MaxWell drywell system is a one or two vertical chamber structure intended to settle out sediment and particulate matter. The drywells utilize infiltration to mitigate surface flows.

#### Effectiveness/Maintenance

Each chamber has a settling capacity of about 1,000 gallons and has a maximum outflow capacity of 0.25 cfs when installed in drainage soils with optimum permeability. Accordingly, the effectiveness of the drywell is dependent on its underlying soil matrix. A single chamber drywell is intended primarily to serve landscaped retention areas, and works best if the water is passed through some sort of pretreatment before entering the drainage structure. The tributary drainage area that can be accommodated by a drywell is limited; a tributary area that is too large will become clogged quicker. Routine maintenance consists of the cleaning of debris using some sort of truck mounted vacuum. If a drywell is not properly maintained the system will accumulate sediment and clog the void spaces of the drainage pipe gravel pack and may not be repairable.

#### **5.2.2.1.1.7 Roof Well**

Particularly in industrial areas, large amounts of precipitation falls directly on roof tops in urbanized areas. Roof downspouts can be directed underground to roof wells for storm water treatment and recharge. A roof well is essentially a hole filled with open graded aggregate. CASQA suggests a roof well be excavated typically 10 feet from the edge of a building. Runoff from the rooftops is conveyed to the roof well from the downspout through an underground connection to fill the voids in the aggregate. Water then infiltrates the soil, consequently recharging the groundwater. Only 6 roof wells were identified by local Chino

Basin entities.

#### Effectiveness/Maintenance

In poorly drained soils, dry wells have very limited feasibility. However, in appropriate sites, runoff collected from roof tops typically has little sediment, which can result in roof wells being effective for long periods. Roof wells are sized according to the amount of rooftop runoff received. Their drainage areas are limited to the size of the roof top, but the use of roof wells limit the need for larger off-site storm water treatment facilities by treating runoff on-site.

#### **5.2.2.1.2 Identified Recharge Facilities**

Our evaluation of local storm water recharge is based on the information provided by local entities within the Chino Basin who responded to a data request letter mailed in March 2009 (see the table below). The responding entities hadn't previously prepared inventories of such sites and accordingly, collection of local storm water management information proved to be very difficult because such sites are largely associated with development projects and are accordingly privately owned and maintained. Representatives from CalTrans were contacted in July 2009 regarding facilities owned and operated by the state of California. CalTrans representatives were in the process of identifying facilities; however this information has not been provided by the date of this report and accordingly not included in our evaluation.

Urban development projects within the last 5-10 years have been required to incorporate a storm water management system that will treat the runoff collecting within the project area. WQMPs and Hydrology Reports for the development projects are submitted to the local entities. Representatives from the various cities provided us with as much information as was readily available regarding local storm water management projects. In many cases, portions of the WQMPs and Hydrology Reports were provided. Most of the WQMP portions provided contain all relevant data regarding the physical parameters of the storm water retention facilities as well as their tributary drainage areas. Facilities identified that were unaccompanied by portions of a WQMP, were mapped using an ArcGIS program as accurately as possible according to information provided. The facility and its tributary drainage area were delineated using ArcGIS, 2007 aerial imagery, San Bernardino County assessor parcel information, USGS 7.5 minute quadrangles, and city storm drain atlases (when available).

### Identified Storm Water Management BMPs

Entity	Infiltration/ Detention	Vegetated Swale	Underground				Roof Well	Total
	Basin		Chamber Vault	Infiltration Trench	Pervious Pavement	Drywell		
Chino	14	15	2	1	0	0	0	<b>32</b>
Chino Hills <sup>(1)</sup>	2	0	0	0	0	0	0	<b>2</b>
Fontana <sup>(2)</sup>	36	0	0	0	0	0	0	<b>36</b>
Montclair	1	3	1	2	0	0	0	<b>7</b>
Ontario	63	168	30	68	16	124	6	<b>475</b>
Rancho Cucamonga	11	0	0	0	0	0	0	<b>11</b>
Upland <sup>(3)</sup>	6	0	0	0	0	0	0	<b>6</b>
<b>Total</b>	<b>133</b>	<b>186</b>	<b>33</b>	<b>71</b>	<b>16</b>	<b>124</b>	<b>6</b>	<b>569</b>

#### Notes:

<sup>(1)</sup> Basins are concrete lined and accordingly do not recharge to the groundwater basin.

<sup>(2)</sup> Does not include regional basins identified by City of Fontana.

<sup>(3)</sup> Does not include regional basins identified by City of Upland. All basins identified were assumed to recharge adjacent groundwater basins, not Chino Basin.

#### 5.2.2.1.2.1 City of Chino

Storm water management information for 19 different development projects were provided by the City of Chino. Chino was able to prepare a very complete inventory of storm water management systems within their city limits. Sections of WQMPs containing site descriptions, drainage area delineations, soil investigations, BMP product specifications, plan sheets, etc. were all made available. Parameters of City of Chino storm water management projects are identified in Table 5-5 and approximate site locations are mapped on Figure 5-3. A total of 19 projects, consisting of 32 different storm water management BMPs can store a total of about 280 acre-ft. The projects collect storm water runoff from a tributary area of about 1,555 acres. All storm water management facilities identified by the City of Chino collect storm water runoff that would otherwise drain to Prado Lake and eventually out of the Chino Basin. Accordingly, any recharge estimated by these facilities would represent a positive impact.

#### 5.2.2.1.2.2 City of Chino Hills

Representatives from the City of Chino Hills were able to provide a copy of a storm water management facility maintenance book. This document identified all the publicly maintained storm water facilities including several catch basins, drainage ditches, and two detention basins. The detention basins were found to be concrete lined which negates any possibility of consequent storm water recharge. These basins are primarily utilized for peak flow attenuation, not for treatment or recharge. Privately owned and maintained storm water management systems were not identified by Chino Hills. According to personal communication with Steven Nix, City Engineer of Chino Hills, the underlying soil type for Chino Hills' projects does not allow for significant infiltration. Accordingly, privately owned and maintained facilities only serve to attenuate peak storm flows and not groundwater

recharge. Accordingly, storm water management facilities in Chino Hills represent a neutral effect on recharge estimates because runoff will continue to drain to Prado Lake and eventually out of the Chino Basin.

#### **5.2.2.1.2.3 City of Fontana**

The City of Fontana provided very detailed electronic copies of their storm drain infrastructure and the locations of storm water management facilities the city utilizes. Fontana identified several regional basins they utilize for storm water management. These basins were evaluated in Section 5.2.1. Unfortunately, Fontana was unable to provide any segments of WQMPs or Hydrology Reports for the locally owned and operated facilities. However, we were able to estimate the surface area and the tributary drainage areas of the identified facilities using ArcGIS, the storm drain atlas provided by Fontana, aerial imagery, USGS 7.5 minute quadrangles, and San Bernardino County assessor parcel information. Parameters of City of Fontana storm water management projects are identified in Table 5-6 and approximate site locations are mapped on Figure 5-4. The 36 basins identified have a total surface area of approximately 46 acres. The basins collect storm water runoff from a tributary area of about 1,445 acres. As described in the notes column in Table 5-5, not all of the facilities identified by the City of Fontana recharge storm water to the Chino Basin. There are 15 facilities that recharge to Chino Basin that would otherwise have drained to regional recharge facilities; these facilities represent a neutral impact to recharge estimates. Seven facilities recharge outside of the Chino Basin but would otherwise drain outside of the Chino Basin, accordingly these sites also represent a neutral impact to recharge estimates. Six facilities recharge storm water to the Chino Basin that would otherwise drain outside of the basin; accordingly this represents a positive impact on recharge estimates. There are eight facilities that capture storm water runoff and recharge outside of the Chino Basin that would otherwise drain to regional recharge basins within the Chino Basin. These sites accordingly represent a negative impact on estimated storm water recharge.

#### **5.2.2.1.2.4 City of Montclair**

The City of Montclair identified four local storm water management projects. Complete copies of the WQMPs and the majority of the accompanying construction plan sheets were provided by Montclair. Montclair was also able to provide electronic copies of the existing storm drain infrastructure. Parameters of City of Montclair storm water management projects are identified in Table 5-7 and approximate site locations are mapped on Figure 5-5. The four basins identified have a total surface area of approximately 11,300 sq. ft. and can store a total of about 0.5 acre-ft. The basins collect storm water runoff from a tributary area of about 10 acres. Two facilities capture storm water runoff that would have otherwise have drained to regional recharge basins and represent a neutral impact on estimated recharge to the Chino Basin. The other two sites capture water that would otherwise drain to Prado Lake and outside of the basin and represent a positive impact to estimated recharge.

#### **5.2.2.1.2.5 City of Ontario**

Representatives of the City of Ontario identified the largest number of local storm water management facilities. A total of 185 development projects were identified that utilize 475

storm water management BMPs. The projects identified by Ontario are shown in Table 5-8 and the locations are mapped on Figure 5-6. The project site locations were mapped according to the provided assessor parcel number corresponding to the development project. The City of Ontario estimates the total surface area of the BMPs to be about 13 acres, have an approximate storage volume of over 24 acre-ft, and have the ability to collect runoff from a tributary drainage area of about 918 acres. 107 of the BMPs identified by City of Ontario are noted to have minimal infiltration capacity. Facilities such as these are primarily used for peak flow attenuation and accordingly represent a neutral impact on estimated recharge. 123 BMPs capture storm water runoff that would otherwise drain to existing regional recharge basins. Recharge from these facilities also represents a neutral impact to total estimated recharge. The remaining 245 BMPs capture storm water runoff that would otherwise drain to Prado Lake and outside of the Chino Basin. Accordingly, recharge from these BMPs represents a positive impact to estimated recharge.

#### **5.2.2.1.2.6 City of Rancho Cucamonga**

Storm water facility construction plans and site location maps featuring aerial imagery and assessor parcel boundaries were provided by representatives of the City of Rancho Cucamonga. Eleven basins were identified that collect storm water runoff primarily from residential areas in Rancho Cucamonga. Parameters of City of Rancho Cucamonga storm water management projects are identified in Table 5-9 and approximate site locations are mapped on Figure 5-7. The 11 basins identified have a total surface area of approximately 26 acres and can capture storm water runoff from a tributary area of about 999 acres. Four of the infiltration basins identified by the City of Rancho Cucamonga capture and recharge runoff outside the Chino Basin that would otherwise be captured by an existing regional recharge basin within the Chino Basin. Accordingly, recharge from these facilities represents a negative impact on estimated recharge to the Chino Basin. The remaining seven infiltration basins capture storm water runoff that would otherwise drain to existing recharge basins. These facilities represent a neutral impact to estimated recharge.

#### **5.2.2.1.2.7 City of Upland**

Representatives from the City of Upland did not identify any privately owned and maintained storm water management systems. However, a large amount of information regarding publicly owned and maintained storm water management facilities was provided. Upland storm water runoff is collected by existing storm drain infrastructure and conveyed to a number of large recharge basins. The Upland Basin is the only facility of the seven recharge facilities identified that recharges groundwater to the Chino Basin. The Calmat Basins and the Blue Diamond/Holliday Pit recharge to the College Heights groundwater basin. The Colonies and 15<sup>th</sup> Street Basins recharge to the Cucamonga Basin. All storm water runoff amounts collected by these regional basins have been estimated in the past. Any new development utilizing privately owned and maintained storm water management facilities in the City of Upland would recharge storm water that would otherwise be collected by the regional basins. Accordingly, estimation of local recharge from development projects would most likely not result in additional recharge to the basin.



### **5.2.2.2 Evaluation of Local Retention Facilities**

In evaluating the recharge capabilities of the facilities identified by local entities within the Chino Basin, the six basins identified by the City of Upland and two basins identified by the City of Chino Hills can be removed from consideration. The local Upland basins recharge to groundwater basins adjacent to the Chino Basin. The Chino Hills basins are concrete lined and accordingly do not recharge. The remaining facilities identified collect storm water runoff from an estimated total tributary area of about 4,927 acres. If each facility were assumed to have equal recharge efficiency, an effective precipitation coefficient can be applied to estimate potential recharge. Previous estimates of discharge to recharge basins in Upland have used a rainfall amount of 11.42 inches/year (Average of last 10 years measured at Upland). If this factor is used, the estimated discharge to the identified local facilities is about 4,690 acre-ft/yr. As discussed in section 5.2.2.1.1, each type of facility has different factors effecting ability to efficiently recharge storm water.

The inclusion of LID elements does not necessarily correlate to an increase of groundwater recharge. The below table displays the potential impact of each of the BMPs identified by the local entities. Each BMP constructed is intercepting runoff that would otherwise drain to another location. If a BMP captures runoff that would otherwise recharge outside of the Chino Basin then it represents a potential positive impact. Conversely, a BMP capturing and recharging water outside of the Chino Basin that would otherwise recharge within the basin represents a potential negative impact (see below).

### Number of BMPs According to Source Runoff and Recharge

BMP	Minimal Infiltration <sup>1</sup>	Recharges to Chino Basin			Recharges Outside Chino Basin		Total
		Would Otherwise Drain to Prado <sup>2</sup>	Would Otherwise Drain to Regional Basin <sup>3</sup>	Would Otherwise Drain Outside Chino Basin <sup>2</sup>	Would Otherwise Drain to Regional Basin <sup>4</sup>	Would Otherwise Drain Outside Chino Basin <sup>3</sup>	
Infiltration Basin	2	54	46	6	18	7	133
Vegetated Swale	89	78	19				186
Infiltration Trench	6	47	18				71
Underground Chamber							
Vault	0	23	10				33
Pervious Pavement	9	3	4				16
Drywell	0	73	51				124
Roof Well	3	2	1				6
<b>Total</b>	<b>109</b>	<b>280</b>	<b>149</b>	<b>6</b>	<b>18</b>	<b>7</b>	<b>569</b>

**Notes:**

<sup>(1)</sup> Represents little to no impact on estimated recharge.

<sup>(2)</sup> Represents positive impact on estimated recharge.

<sup>(3)</sup> Represents neutral impact on estimated recharge.

<sup>(4)</sup> Represents negative impact on estimated recharge.

The potential negative impact attributable to increased evaporation losses as a result of storm water runoff captured in local management facilities was evaluated. We analyzed only the above ground facilities that capture and recharge storm water runoff that would have otherwise drained to existing regional recharge facilities. A “ball-park” estimate of potential negative impact was calculated in order to see if further study was necessary. An average annual unit evaporation loss was estimated using available daily pan increment evaporation measured at Lake Isabella in Kern County (data available from 1994 through 2009). Storm events reported at the Upland Water Facilities Authority precipitation station during the same period were identified. The evaporation corresponding to each storm event was identified and an average annual unit evaporation of 2.91 inches was calculated. This evaporation applied to the surface area of the facilities evaluated (22.3 acres) corresponds to a potential loss of about 5.4 acre-ft/yr. Considering this value is a gross estimation, this amount is most likely negligible and the effect of these facilities on the total estimated recharge is considered a neutral impact (see table below).

**Approximated Annual Reduction in Recharge Resulting from Increased Evaporation<sup>(1)</sup>  
From Open-Air BMPs Capturing Runoff Otherwise Captured By Regional Basins**

BMP	Quantity	Surface Area <sup>(2)</sup> (ac)	Estimated Evaporation Loss (af)
Infiltration Basin	46	21.7	5.26
Vegetated Swale	19	0.34	0.08
Infiltration Trench	18	0.25	0.06
<b>Total</b>	<b>83</b>	<b>22.3</b>	<b>5.40</b>

Notes:

<sup>(1)</sup> Evaporation is estimated using average pan increment evaporation measured at Lake Isabella on days with reported precipitation measured at Upland Water Facilities Authority Station from January 1994 through May 2009.

<sup>(2)</sup> Surface areas for vegetated swales identified by City of Ontario are largely unavailable.

### 5.3 Potential Storm Water Recharge Projects

As described in previous sections, the opportunity to significantly increase recharge from storm water with the current system may be limited for many basins, primarily due to the nature of the timing of precipitation and runoff. Storm water runoff draining to creeks and channels is usually less than the inlet capacity of the existing recharge basins, meaning that most of the time all flow can be captured and recharged by facilities. However, in large storm events some recharge basins are unable to divert all available flow because the rate of flow greatly exceeds the capacity of intake structures. Consequently recharge opportunities are lost. Groundwater recharge could potentially be optimized by developing new projects, altering current practices, or both.

Potential storm water recharge projects evaluated in this Section by CBWCD are as follows:

- Potential Storm Water Recharge Projects
  - Potential Recharge Basins – Sites that could potentially be made available for construction of groundwater recharge basins
  - Brooks Basin Enlargement – Expand to utilize vacant area to the south of the existing basin
  - Whispering Lakes Golf Course – Utilize small depression adjacent to Cucamonga Creek Channel
- Potential Local Storm Water Recharge Projects
  - Low Impact Development Best Management Practices – Required as part of future urban development
- Potential Changes in Storm Water Management Policy to Increase Recharge
  - Increase Divertible Runoff – Enlarge diversion inlet and/or storage capacity

- First Flush Bypass Practice – Effect of discontinuing practice

### **5.3.1 Potential Storm Water Recharge Projects**

#### **5.3.1.1 Potential New Recharge Basins**

John Van Dyk of Beno, Van Dyk & Owens Land Brokers and Development Consultants investigated the existence of potential sites for new groundwater recharge facilities. Mr. Van Dyk identified a total of 51 sites within the boundary of the CBWCD that were vacant (see Table 5-10). The total approximate surface area of these sites is 576 acres. The approximate maximum tributary drainage area if all sites were constructed is about 7,780 acres. Drainage areas were approximated based on knowledge of existing storm drain systems, evaluation of aerial imagery, and topography. Estimated tributary drainage areas for these sites are preliminary and could potentially be affected by changes in storm drain systems.

As shown on Figure 5-8, the potential recharge sites identified are largely upstream of existing regional recharge basins. Accordingly, significant increase in storm water recharge resulting from the development of these sites is not very likely. As mentioned previously, the majority of storm water runoff in this area is captured and recharged by the existing facilities. New facilities collecting runoff from their local tributary drainage areas would be collecting runoff that would most likely be captured by the existing basins. Accordingly, significant increase in recharge of storm water runoff collected upstream of existing basins is limited. However, runoff collected downstream of the existing basins remains largely un-captured and accordingly does not recharge to the Chino Basin.

Runoff occurring in San Antonio Creek and Cucamonga Creek downstream of existing basins is measured at USGS streamgages 11073300 San Antonio Creek at Riverside Dr. near Chino, CA (Riverside Dr. gage) and 11073495 Cucamonga Creek near Mira Loma, CA (Mira Loma gage). Average water year discharge downstream of the existing basins on San Antonio Creek from 1999 through 2008 is about 6,300 acre-ft (excluding contributions from OC-59 releases) and on Cucamonga Creek from 1986 through 2008 is about 39,200 acre-ft. Facilities could conceivably be constructed to divert runoff contributing to the discharge measured at these gages that could transfer water to some of the potential recharge sites identified (see Sections 5.4 and 5.5). Recharge of storm water could potentially be increased significantly if runoff occurring downstream of existing basins were able to be captured.

#### **5.3.1.2 Brooks Basin Enlargement**

Vacant land to the south of Brooks Basin, between the existing basin and the railroad tracks running parallel along West State Street, could potentially be used to expand the basin. We evaluated the potential increase of capacity if the basin were to be expanded 40 feet into the vacant area. Topographic data was digitized from Figure 4-4 of the March 2006 GRCC Chino Basin Recharge Facilities – Operations Procedures manual. Based on a preliminary evaluation using limited resources, expanding Brooks Basin 40 feet to the south would increase the spillway capacity by about 70 acre-ft. This increase in capacity would require the removal of

about 112,000 cu. yd. of soil.

### **5.3.1.3 Whispering Lakes Golf Course**

A small site located in the Whispering Lakes Golf Course was investigated to determine if it was viable as an option for recharging storm water. A depression currently exists adjacent to the Cucamonga Creek (downstream from IEUA's RP-1) that has a surface area of about 4 acres. The site is currently being used as a disposal site for waste "fill" material.

According to representatives from the City of Ontario, the pond site originally had a capacity of about 100 acre-ft. However, the amount of replaced waste fill is currently unknown. The replaced fill is tight, compacted, fine grained soil and would require removal in order for the site to be used for recharge. The side slopes however, are loose gravels and sands and may be more permeable. An additional concern with the Whispering Lakes Golf Course site is an underlying plume of volatile organic compound (VOC) immediately below and down gradient of the site. An investigation would need to be undertaken to determine the potential impacts of recharge on the VOC plume. Artificial recharge could potentially mobilize the plume.

An investigation into historical land use would need to be undertaken. Deep and shallow soils would require testing for permeability and contamination. The existence of the VOC plume potentially raises multiple concerns over the viability of the site. Mobilization of the plume could have a potential impact to down gradient wells including the Watermaster's desalter wells. Reported tricholoethene concentrations under the site are 10 to 20 micrograms per liter and exceed US-EPA and California maximum contaminant level of 5 micrograms per liter.

The potential obstacles involved with the Whispering Lakes Golf Course may make the site a more likely candidate for seasonal off-channel storage similar to proposed facilities described in Section 5.4. The site could potentially be used to store water temporarily during the wet season to be transferred to existing facilities for groundwater recharge during the dry season when there would likely be capacity available.

## **5.3.2 Potential Local Storm Water Recharge Projects**

As described in 5.1.2.1, new developments and significant re-developments are required to include BMPs to manage storm water runoff. Developments in the Chino Basin must adhere to the requirements adopted by the Santa Ana Regional Water Board in the NPDES Permit No. CAS618036. Compliance with the permit requires that a WQMP be implemented for such projects. The WQMP template describes steps to be taken for various projects in order to reduce short and long term adverse impacts resulting from the development. The WQMP identifies categories of project types for which a WQMP is required, BMP selection, and operations and maintenance of the BMPs identified. As urban growth continues, the effects of the new LID BMPs on storm water recharge in the Chino Basin will need to be revisited.

## **5.3.3 Potential Changes in Storm Water Management Policy to**

## **Increase Recharge**

### **5.3.3.1 Increase Divertible Runoff**

A method that could potentially be used to maximize recharge opportunities would be to increase the inlet capacities and/or the storage capacities of the basins enough to capture more of the storm water runoff accumulating in each channel. This method would not be optimal if the cost associated with increasing the recharge capacity of the basins is greater than the value of the increased recharge opportunities.

WEI has developed the Chino Basin Surface Water Simulation R4 Model which estimates daily runoff at points of interest. WEI provided model output for San Antonio Creek flow near Upland Basin, and local inflow to Upland and Montclair Basins from water year 1950 through 2006. The Upland and Montclair Basins have an approximate recharge capacity of about 60 cfs. An initial evaluation of recharge opportunity on the San Antonio Creek was completed using the 60 cfs recharge capacity limitation as an indicator of missed recharge opportunity.

According to the modeled amounts, there is zero flow available to recharge at these basins in over 91% of the days modeled. Of the remaining days, when there is modeled flow available for recharge at the basins, the 60 cfs recharge capacity is exceeded only about 14 % of the time. As shown on Figure 5-9, the resulting average annual amount of runoff greater than 60 cfs occurring on days with greater than zero flow is about 630 acre-ft.

This evaluation serves as a preliminary indicator of the relative efficiency with which storm water runoff is captured in this system. In order to recharge the average amount of runoff available, the basins would have to capture every drop of water passing the inlet. This would include capture of peak flows such as the estimated 3,100 cfs occurring in January 1969 at the Montclair inlet.

If the basins were to regularly fill to capacity, the limitation on the capture of storm water would be the storage capacity. However, as a result of the manner in which runoff occurs in the San Antonio Creek Channel, the factor limiting storm water capture for recharge is typically not storage capacity. The relatively high recharge rates quickly create storage capacity following storm events, as is evident by infrequent spilling. As a result, the factor most commonly limiting recharge opportunities is the capacity of the diversion inlets.

Potential runoff available for diversion at the Montclair Basins can also be estimated using flow measurements taken downstream of the basins. USGS measures flow in San Antonio Creek using the aforementioned Riverside Dr. gage. Measurements at this gage are available from December 1998 through the present. Because the gage is downstream of the basins, flow measured at this gage accounts for diversions made by Pomona Valley Protective Association upstream of the basins. The only other streamflow gages on the San Antonio Creek measure runoff upstream of this diversion. The OC-59 turnout in the Rialto Reach of the Foothill Feeder releases state water to San Antonio Creek for use by Orange County Water District and Municipal Water District of Orange County. Historic daily discharge from

OC-59 was provided by the Santa Ana River Watermaster. Data is available through September 2008. Contributions from OC-59 to San Antonio Creek discharge, where available, were excluded from consideration for diversion to recharge basins.

Mr. Campbell has been measuring diversions to recharge basins within the Chino Basin since April 2005. The estimation of average missed recharge opportunity is thus limited to a period of record from April 2005 through the present. The total runoff available between San Antonio Dam and the Riverside Dr. gage was estimated by adding daily diversions made to the recharge basins to the daily flow measured at the Riverside Dr. gage. Runoff available at the Montclair Basins was then estimated by prorating measured flows according to the ratio of the tributary drainage areas of the basins and the gage (about 30%). In order to accurately measure tributary drainage areas in their entirety, runoff collected in storm drains from surface streets and residential areas were taken into account. Tributary drainage areas are shown on Figure 5-10.

As shown on the below table, the estimated average water year discharge available at the Montclair Basins, using the methodology described above, is about 1,174 acre-ft. Diversions to the basins are limited by an inlet capacity of 100 cfs and an approximate recharge capacity of 40 cfs. Applying these limitations to estimated daily flows, an average of about 1,164 acre-ft could potentially be diverted to the Montclair Basins. The difference of 10 acre-ft is representative of potential missed recharge opportunities on the San Antonio Creek, based on the limitations of the inlet capacity of the Montclair Basins, during this period. Estimated flows are illustrated in the water year hydrographs shown in Figures 5-11 through 5-13.

**Chino Basin Water Conservation District  
Summary of Reported and Calculated Flows in the San Antonio Creek System**

Water Year	Reported SAC Near Chino <sup>(1)</sup> (af)	Actual Measured Total System Diversions <sup>(2)</sup> (af)	Adjusted SAC Near Chino <sup>(3)</sup> (af)	Estimated SAC at Montclair Inlet <sup>(4)</sup> (af)	Estimated Montclair Divertible Discharge <sup>(5)</sup> (af)	Estimated Uncapturable Discharge <sup>(6)</sup> (af)
2006	3,414	1,642	5,056	1,518	1,518	0.0
2007	819	834	1,653	496	496	0.0
2008	3,071	1,954	5,025	1,508	1,478	29.8
<b>Total</b>	<b>7,304</b>	<b>4,430</b>	<b>11,734</b>	<b>3,522</b>	<b>3,492</b>	<b>30</b>
<b>Average</b>	<b>2,435</b>	<b>1,477</b>	<b>3,911</b>	<b>1,174</b>	<b>1,164</b>	<b>10</b>

Notes:

<sup>(1)</sup> USGS 11073300 San Antonio Creek at Riverside Drive near Chino, CA excluding contributions from OC-59 turnout.

<sup>(2)</sup> Actual daily diversions to regional recharge basins in the San Antonio Creek System (from IEUA). This includes local runoff captured in the basins.

<sup>(3)</sup> Discharge is adjusted based on actual daily diversions.

<sup>(4)</sup> Discharge at the Montclair Basin 1 inlet is estimated based on drainage area percentage. (about 30% of the gaged watershed downstream of San Antonio Dam)

<sup>(5)</sup> Estimated Montclair Divertible Discharge assumes zero diversions upstream of Montclair Basins.

<sup>(6)</sup> Uncaptured discharge is estimated as discharge exceeding inlet and/or recharge capacity of the Montclair Basins.

The available period of record occurs during a period of lower than average flow. Accordingly, the amount of missed recharge opportunity is most likely higher than the estimated average 10 acre-ft calculated. The data does, however, show that portions of the

occasional peak flows during a storm event that will not be captured are infrequent. This occurred only one time in the four year period.

When the evaluation described above is applied to the aforementioned modeled WEI runoff, the results support the conclusion that opportunity to decrease the amount of uncapturable flow is limited. According to the modeled data, the estimated average uncapturable flow per water year, using the current inlet and storage capacity of the Montclair Basins, is about 369 acre-ft. This estimation is conservative because it is calculated assuming that there are no storm water diversions upstream at Upland Basin or downstream at Brooks Basin. This is a potentially significant amount of water that could be recharged if it could be captured. Two potential means of increasing the capturable water at the Montclair Basins are to enlarge the storage capacities and/or the inlet capacity of the existing basins. Unfortunately, as a result of the nature of the runoff occurring during a storm event, these methods will most likely not significantly increase the capturable storm water.

As shown in Figure 5-14, if it were possible to enlarge each Montclair Basin 100 acre-ft (nearly an 80% increase in capacity), the uncapturable runoff would be decreased to 296 acre-ft/yr, an increase of only 73 acre-ft/yr. Doubling the capacity of the inlet to the Montclair Basins from San Antonio Creek from 100 cfs to 200 cfs would only increase the capturable runoff 21 acre-ft/yr. If it were possible to increase both the inlet capacity to 200 cfs and each basin by 100 acre-ft, the resulting increase of capturable runoff over the existing condition would be 132 acre-ft/yr.

Similarly, when the same evaluation is applied to WEI modeled runoff potentially available for diversion to the Turner Basins, it is apparent that the opportunity to significantly decrease uncapturable runoff in the Cucamonga Creek system is also limited. From water year 1949 through 1999 about 7,276 acre-ft per water year is estimated to be available for diversion from Cucamonga and Deer Creeks at the Turner Basin drop inlets.

According to WEI, a drop inlet in the Cucamonga Creek channel has the potential to divert up to 255 cfs to Turner 1. Drop inlets in the Deer Creek channel can divert 183 cfs to Turner 1 and 225 cfs to Turner 4. Combined, the three inlets correspond to a relatively large inlet capacity. However, according to the March 2006 GRCC Chino Basin Recharge Facilities Operation Procedures manual and personal communication with Andy Campbell of IEUA (see Table 5-1), the rule curve guideline for Turner Basin storage from October 16<sup>th</sup> through April 15<sup>th</sup> is limited to about 157 acre-ft. Accordingly, the operating storage capacity is the driving factor limiting recharge opportunities in the Turner Basins.

In order to evaluate potential increases in recharge opportunity at the Turner Basins we modeled the effects of increasing inlet capacity and also increasing the operating storage capacity. Increasing the inlet capacity appears to have little to no effect on average annual capturable runoff. However, there is a potential increase in capturable runoff by increasing the operating storage capacity. The basins are operated at a total storage of about 157 acre-ft in the wet season, but the total capacity at the spillways is much greater, about 488 acre-ft total. As shown in Figure 5-15, if the operating storage capacity were increased to 488 acre-ft,



the corresponding capturable runoff could potentially be increased 596 acre-ft.

Increasing capturable runoff 596 acre-ft by simply increasing the operating storage capacity could be cost effective. Clearly, avoiding the need to physically enlarge the basins would be an advantage. Increasing the operating storage capacity may require only changes in operational practices and a reconfiguration of diversion inlets. The four Turner Basins have varying spillway elevations which contribute to a lack of flexibility when utilizing the basins. Mr. Campbell of IEUA has suggested that modifying the diversion structures in Deer Creek, adding a bypass structure from Turner 1 to either Turner 3 or 4, and possibly adding a rubber dam in Deer Creek would increase flexibility without the cost of enlarging the basins.

The potential for additional storage at the Turner Basins is also a possibility. There is vacant land owned by SBCFCD east of Turner 4 that could potentially be used to construct an additional recharge basin. Representatives of IEUA are also investigating the possibility of utilizing several existing ponds on the east side of North Archibald Avenue from the Turner Basins in the Guasti Park. This could also potentially be a cost effective way to increase recharge opportunity due to the fact that the ponds as well as some transfer ability already exist.

### **5.3.3.2 First Flush Bypass**

A current operational practice used by the IEUA operator, as discussed in Section 5.2.1.2, is the first flush bypass. This practice was established in order to limit the amount of debris, dust, dirt, and pollutants that can accumulate in channels and urban impervious areas entering the recharge basins, thus minimizing maintenance. Such an event is referred to as a first flush opportunity. The rate of accumulation of debris and pollutants can vary depending on the area tributary to each basin. According to Andy Campbell of IEUA, this is accomplished by closing inlet gates to the recharge basins for the first two hours of a storm occurring 30 days after any previous storm event. Though this first flush clears excess debris and minimizes the cost of maintenance, it is also a lost recharge opportunity.

Recharge opportunity lost as a result of bypassing the first flush was evaluated by estimating the associated losses that occur in the San Antonio Creek system. This evaluation was based on streamflow measured at the Riverside Dr. gage, excluding contributions from OC-59 releases, as described above (the gage location is also mapped in Figure 5-18). Measurements reported using this gage were used because historic flow measurements taken at 15 minute intervals are readily available from December 1998 through the present. The methodology described above was used to estimate flow available at the Montclair Basins based on flow measured at the Riverside Dr. gage.

The SBCFCD uses the period of October 15<sup>th</sup> through April 15<sup>th</sup> to evaluate storm seasons. However, according to Mr. Campbell, if a storm event occurs outside of this period the runoff is still captured for recharge. Accordingly, a first flush opportunity occurring at any point during the year was evaluated. The daily average flows reported at the Riverside Dr. gage were analyzed to identify the events. A total of 32 first flush opportunities were identified at the Riverside Dr. gage from December 1998 through September 2008, as shown in Table 5-11.

However, as described above, the diversion data used to estimate flow available at the Montclair Basins is only available from April 2005 through June 2009 and releases from OC-59 were only available through September 2008. A total of 14 first flush opportunities were identified and evaluated during this period.

For each storm identified, the total flow measured at the Riverside Dr. gage for the first two hours was calculated. The ratio of reported daily and reported 2-hour discharge measured for these events was then used to calculate the potential 2-hour discharge at the Montclair Basins. This amount was then used to estimate the potential recharge opportunity lost by foregoing the first flush. As indicated in Table 5-12 and Figure 5-16, two to four first flush bypass opportunities typically occur each water year.

The estimated average first flush discharge foregone in each water year, estimated based on 2-hour discharge, is about 8.6 acre-ft per event. The corresponding average water year total discharge foregone is about 37.7 acre-ft. The average daily discharge available at the Montclair Basins occurring on the day of a first flush opportunity is about 26.1 acre-ft, with a corresponding average water year total of 106.7 acre-ft (see Figure 5-17).

An evaluation of the aforementioned modeled daily runoff on San Antonio Creek provided by WEI, yields similar results. From water year 1950 through 2006, there was an average of nearly 3 first flush opportunities per year. Each event produced an average of about 20 acre-ft of runoff for the day, with a corresponding average water year total of about 54 acre-ft (Table 5-13). If the first flush is limited to the first 2-hours of each event, the foregone runoff would likely be much less than 20 acre-ft per opportunity.

The first flush bypass practice not only minimizes maintenance of basins by clearing silt, pollutants, and other small debris, but it also helps to clear large debris as well. It is not uncommon to find branches, even shopping carts and appliances, in the channels. An immeasurable amount of recharge opportunity would be lost if such debris were allowed to clog drop inlets. The evaluation suggests that discontinuing the first flush bypass likely will not create a significant enough increase in recharge opportunity to offset the advantages of continuing the practice.

## **5.4 Reconnaissance Level Evaluation of Improvements to Potential Storm Water Recharge**

Potential alternative projects were identified and evaluated where a large amount of storm water runoff is not currently fully captured for recharge. Estimates of annual uncaptured runoff measured on San Antonio Creek at Riverside Dr. near Chino, CA (excluding contributions from OC-59 releases) averages about 6,300 acre-ft for complete water years from 1999 through 2008. Similarly, the gage on Cucamonga Creek near Mira Loma measures an average of nearly 40,000 acre-ft of water that is un-captured each year (water years 1986 through 2008). Flow measured on Cucamonga Creek includes treated effluent from IEUA's

RP-1. See Figure 5-18 for locations of the gages.

Potential projects in the San Antonio, Cucamonga, Day, San Sevaine, and Declez Creek systems were identified for evaluation to determine if the proposed project could capture a greater portion of the currently uncaptured flow. The preliminary project concept involves the diversion and storage of storm water during the wet season and pumping the stored water to existing recharge basins in the dry season. In the San Antonio Creek system, we evaluated the benefit of a hypothetical off-channel storage reservoir that would be located near the Riverside Dr. Gage. In the Cucamonga Creek system we evaluated the possibility of enhancing the Lower Cucamonga and Chris Basins. Similarly, in the Day, San Sevaine, and Declez systems we evaluated the possibility of enhancing the Wineville, Jurupa, and RP3 Basins.

The following are general proposed operations for the enhanced Lower Cucamonga/Chris, Wineville, and Jurupa Basins:

- Divert storm water runoff from channel.
  - Winter - flows diverted and stored in reservoir.
  - Summer - Stored water and real-time Creek flows pumped to existing recharge basins (and potentially to other seasonal storage sites) via new transfer pump stations and pipelines.

## **5.4.1 Potential Stream System Improvements**

### **5.4.1.1 San Antonio Creek System**

On the San Antonio Creek we evaluated options for a potential off-channel seasonal storage reservoir near the location of the USGS gage at Riverside Dr. Runoff from San Antonio Creek would be diverted when available throughout the year and pumped upstream to be recharged in the dry season at Brooks, Montclair, Upland, or College Heights basins. See Figure 5-19 for a conceptual schematic of the off-channel storage reservoir project.

A preliminary evaluation was completed for potential off-channel reservoir capacities of 1,000, 3,000, 5,000, and 10,000 for capturing runoff from San Antonio Creek near the Riverside Dr. gage. For each potential reservoir storage capacity, we evaluated a range of embankment heights above existing ground. Potential embankment heights range from 10 feet to 40 feet above existing ground. Assumptions made for the evaluation of off-channel storage reservoir options are described below.

- Annual un-captured runoff measured at the Riverside Dr. gage on San Antonio Creek (excluding contributions from OC-59 releases) averaged about 6,300 acre-ft for complete water years during the period of 1999 through 2008 (see Figure 5-20).
  - Includes a peak annual runoff of 21,604 acre-ft in 2005.
  - Winter season average = 5,286 acre-ft.

- Summer season average = 1,034 acre-ft.
- Operational Overview
  - Divert flow from San Antonio Creek near gage site to off-stream storage reservoir.
  - Winter - flows diverted and stored in reservoir.
  - Summer - Stored water and real-time Creek flows pumped to existing recharge basins via new transfer pump station and pipeline.
- Project Facilities
  - Intake and diversion pump station, assume capacity = 200 cfs. This capacity is based on an evaluation of historic daily runoff measured at the gage. A diversion capacity of 200 cfs could potentially capture over 99% of the flow measured at the gage. Pump size varies depending on embankment height.
  - Diversion pipelines (Creek to reservoir) - assume 4 – 42” diameter, length = 200 feet each.
  - Off-stream storage reservoir – evaluated storage capacity options of 1,000, 3,000, 5,000, 7,000, and 10,000 acre-ft. Assumed a simple square shaped design.
  - Transfer pump station size varies depending on runoff stored and pumped to recharge basins. Transfer pump and pipeline sizes are primarily dependent on the maximum real-time summer runoff to be transferred to recharge basins.
  - Transfer pipeline - length = 6 miles, route parallels San Antonio Creek.

#### **5.4.1.2 Cucamonga Creek System**

We evaluated the potential enhancement of the existing Lower Cucamonga and Chris Basins in order to potentially operate them to store available runoff from the Cucamonga Creek and recharge the water in a manner similar to the aforementioned proposed operation on San Antonio Creek. The existing basins have poor infiltration. However, these sites have the advantage of already being owned by SBCFCD and CBWCD, and could potentially be enhanced by excavating soil from on-site to construct embankments and increase the storage capacities.

Four potential enhancement configuration options were evaluated. See Figure 5-21 for the layout of each option. For Option 1, the potential basins were combined into East and West Basins, with the Cucamonga Creek Channel running between them. The potential basins attempt to maximize the use of the existing area currently occupied by Lower Cucamonga and Chris Basins. Option 2 consists of the West Basin the same as Option 1; however the East Basin is expanded to include an adjacent property that could potentially be acquired. Option 3 assumes that the East and West Basins as laid out in Option 1 could be combined into one large basin with the Cucamonga Creek flowing through the basin. Lastly, Option 4 assumes that the East and West Basins as laid out in Option 2 could be combined into one large basin.

For simplicity, earthwork calculations were completed assuming the existing ground is flat. Accordingly, calculated cost estimates are conservative. Similar to the evaluation of off-channel storage reservoirs near San Antonio Creek, the potential reservoirs were evaluated based on a range of potential embankment heights. The basin options range from embankment heights of 10 feet to 40 feet when feasible. Details for the evaluation of Lower Cucamonga and Chris enhancement options are described below.

- Annual un-captured runoff measured at the Mira Loma gage on Cucamonga Creek which is located about 2-miles south of the Cucamonga and Chris Basins, averaged about 39,200 acre-ft for water years during the period of 1986 through 2008 (see Figure 5-22).
  - Includes a peak annual runoff of 99,509 acre-ft in 2005.
  - Winter season average = 25,091 acre-ft.
  - Summer season average = 14,146 acre-ft.

Flow measured at the Mira Loma gage includes treated effluent from IEUA's RP-1. Further evaluation may be required to determine if the inclusion of the treated effluent would limit the opportunity to recharge at this location. It is possible that treated effluent may be sufficiently diluted during the wet winter months.

#### **5.4.1.3 Day Creek System**

In the Day Creek System we evaluated the possibility of enhancing the Wineville Basin. The enhancement assumes a rectangular shaped configuration attempting to maximize use of the existing property. Similar to the Lower Cucamonga/Chris site, for simplicity, earthwork calculations were completed assuming the existing ground is flat. Potential enhancements were evaluated based on a range of potential embankment heights ranging from 5 to 40 feet above existing ground. Details for the evaluation of Wineville Basin enhancement options are described below.

- Annual estimated runoff available at the Wineville Basin was modeled by WEI (see Figures 5-23 and 5-24).
  - Includes a peak daily runoff of 5,223 cfs.
  - Winter season average = 7,707 acre-ft.
  - Summer season average = 1,145 acre-ft.

#### **5.4.1.4 San Sevaine System**

The existing Jurupa Basin is currently about 40 feet deep from the pond bottom to the spillway. We evaluated the potential capacity increase and cost of earthwork if the existing shape at the dam crest were maintained and the basin excavated 25 and 50 feet deeper than current conditions. Details of the evaluation at Jurupa are as follows:

- Annual estimated runoff available at Jurupa Basin was modeled by WEI (see Figures 5-25 and 5-26).
  - Includes a peak daily runoff of 295 cfs.
  - Winter season average = 2,315 acre-ft.
  - Summer season average = 361 acre-ft.

#### **5.4.1.5 Declez Creek System**

The existing RP3 Basins are currently two collections of cells separated by a narrow piece of property. We evaluated two separate configuration options for the enhancement project at RP3 (see Figure 5-27). Option 1 enlarges the basins maintaining two separate reservoirs. Option 2 assumes that the piece of property between the cells could be acquired and one large basin could be constructed. For the RP3 Basin enhancements we evaluated the two greatest capacity options allowable by the limitations of the existing dimensions. Details of the evaluation at RP3 are as follows:

- Annual estimated runoff available in the Declez Channel at the RP3 Diversion was modeled by WEI (see Figures 5-28 and 5-29).
  - Includes a peak daily runoff of 489 cfs.
  - Winter season average = 1,108 acre-ft.
  - Summer season average = 74 acre-ft.

### **5.4.2 Estimated Recharge for Potential Stream System Improvements**

#### **5.4.2.1 San Antonio Creek System**

For these reconnaissance level evaluations, yield for each choice of reservoir size was estimated based on available runoff measured at the Riverside Dr. gage. During the wet season it was assumed that the entire reported runoff available at the gage from October through March of each year could be captured, with a maximum diversion equal to the capacity of the reservoir. Runoff during this period measuring an amount greater than the capacity of the reservoir is assumed to be foregone. During the dry season it was assumed that runoff being stored from the wet season could be transferred to existing recharge basins upstream at a high enough rate to allow for enough capacity to capture any summer flows. Just as during the wet season, measured runoff accumulating during the dry season (April through September) in excess of the capacity of the reservoir is assumed uncapturable.

Estimated annual yield for each reservoir capacity scenario is assumed to be the total capturable runoff occurring in each year less the estimated evaporation that would occur at three-quarter capacity. The estimated annual yield for each reservoir option is shown the below table.

### Estimated Annual Yield for Off-Channel Storage Reservoir Scenarios

Embankment Height (ft)	Estimated Yield (acre-ft/yr)				
	1,000 acre-ft Reservoir	3,000 acre-ft Reservoir	5,000 acre-ft Reservoir	7,000 acre-ft Reservoir	10,000 acre-ft Reservoir
10	1,255	-	-	-	-
15	1,397	3,010	-	-	-
20	1,472	3,226	3,852	-	-
25	1,518	3,355	4,068	4,506	-
30	-	3,446	4,214	4,712	5,052
35	-	3,512	4,323	4,858	5,262
40	-	3,568	4,405	4,972	5,421

#### 5.4.2.2 Cucamonga Creek System

For reconnaissance level evaluation of the potential yield of diversions from Cucamonga Creek to Lower Cucamonga and Chris Basin locations, the yield is assumed to be at least equal to the estimated capacity of the reservoir due to the high rate of runoff measured at the Mira Loma gage. The estimated capacities for enhanced Lower Cucamonga and Chris Basins are shown in the below table.

#### Estimated Potential Capacity for Enhanced Lower Cucamonga and Chris Basin Options (values in acre-ft)

Embankment Height (ft)	Option 1		Option 2		Option 3	Option 4
	West Basin	East Basin	West Basin	East Basin		
10	374	329	374	638	787	1,096
15	554	488	554	950	1,173	1,634
20	734	-	734	1,258	1,552	2,169
25	917	-	917	1,563	1,930	2,698
30	-	-	-	1,865	2,305	3,221
35	-	-	-	2,169	2,681	3,743
40	-	-	-	2,479	3,060	4,262

#### 5.4.2.3 Day Creek System

Similar to the enhancements at the Lower Cucamonga/Chris site, it is assumed that potential yield is most likely at least equal to the estimated capacity of the reservoir. The estimated capacities for enhanced Wineville Basin options are shown in the below table.

**Estimated Potential Capacity for  
Wineville Basin Enhancement Options**

Embankment Height (ft)	Estimated Potential Capacity (acre-ft)
5	352
10	700
15	1,044
20	1,388
25	1,731
30	2,076
35	2,427
40	2,787

#### **5.4.2.4 San Sevaine System**

Potential yield for Jurupa Basin enhancements is estimated to be at least equal to the estimated capacity of the reservoir. The estimated capacities for enhanced Jurupa Basin options are shown in the below table.

**Estimated Potential Capacity for  
Jurupa Basin Enhancement Options**

Cut Depth (ft)	Estimated Potential Capacity (acre-ft)
25	3,292
50	4,104

#### **5.4.2.5 Declez Creek System**

Potential yield for RP3 Basin enhancements is estimated to be at least equal to the estimated capacity of the reservoir. The estimated capacities for enhanced RP3 Basin options are shown in the below table.



**Estimated Potential Capacity for  
Enhanced RP3 Basin Options**

(values in acre-ft)

Embankment Height (ft)	Option 1		Option 2
	North Basin	South Basin	
15	224	-	-
20	286	-	-
30	-	1,181	-
32	-	1,265	-
35	-	-	2,198
40	-	-	2,519

### 5.4.3 Implementation Barriers for Potential Stream System Improvements

#### 5.4.3.1 San Antonio Creek System

Construction of such a project would require cooperation between CBWCD, Watermaster, IEUA and SBCFCD. The most obvious obstacle that would have to be overcome in order to construct an off-channel seasonal storage reservoir in the San Antonio Creek system would be the acquisition of the necessary property. Cost of acquiring land could vary greatly. Another barrier could be the availability of the appropriate easements for all related pipelines, pump stations, etc. Once the appropriate land and easements are available, and an actual project is identified an accurate estimate of yield and cost can be made.

#### 5.4.3.2 Cucamonga Creek System

Enhancement of the Lower Cucamonga and Chris Basins would require cooperation between several entities as well. With cooperation from SBCFCD, this project would not have the same land acquisition barriers as the project in the San Antonio Creek System for Options 1 and 3. Options 2 and 4 would require acquisition of land adjacent to the existing basins. Appropriate land and easements would need to be available for the required pipeline alignments, pump stations, etc. necessary to transfer water from the new facility to existing recharge basins upstream for recharge.

Further study of the availability of RP-1 effluent for storage, transfer, and ultimately recharge would be required. Effluent is assumed to be diluted, and more likely available for recharge, during the wet season.

Additional implementation and project barriers for enhancement of the Cucamonga and Chris Basins are identified and discussed in Section 5.6.6.

### **5.4.3.3 Day and San Sevaine Creek Systems**

With cooperation from the IEUA, the Wineville and Jurupa Basin projects would not have any land acquisition barriers. However, the appropriate land and easements would need to be available for the required pipeline alignments, pump stations, etc. necessary to transfer water from the new facility to existing recharge basins for recharge, or the transfer of water between potential seasonal storage facilities.

Additional implementation and project barriers for enhancement of the Wineville and Jurupa Basins are identified and discussed in Sections 5.6.1 & 5.6.3.

### **5.4.3.4 Declez Creek System**

With cooperation from SBCFCD, the enhancement of RP3 Basin would not have land acquisition barriers for Option 1. Option 2 would require acquisition of a narrow strip of land between the north and south basins. Appropriate land and easements would need to be available for the required pipeline alignments, pump stations, etc. necessary to transfer water from the new facility to existing recharge basins upstream for recharge.

Additional implementation and project barriers for enhancement of the RP3 Basin are identified and discussed in Section 5.6.4.

## **5.4.4 Policy Changes**

All proposed seasonal storage facility projects require sufficient capacity to be available in the upstream existing recharge basins. The off-channel seasonal storage facilities and the recharge basins would need to be operated in a way that would maximize recharge opportunity without encroaching on the existing operational rule curve limitations. It is possible that little change in the operation of the existing recharge basins would be required as water would be transferred from the proposed facilities during the dry season.

## **5.4.5 Review of Preliminary Evaluation of Stream System Improvements**

Preliminary evaluation of local recharge facilities, in the form of LID BMPs, and their impact on estimated groundwater recharge is not conclusive. Further hydrologic analysis by WEI with the aid of its model should provide an estimate of recharge attributable to the LID BMPs.

Based on our preliminary conceptual project evaluations of regional facilities, some existing regional groundwater recharge facilities appear to be effective for the recharge of storm water runoff. Physically changing facilities or changing the operation of facilities likely would not efficiently increase storm water recharge opportunity. Such changes could potentially increase groundwater recharge, but likely at an expense that would outweigh the benefit. One exception might be the existing Turner Basins on Cucamonga Creek. It is estimated that a large amount of water is available for diversion at the Turner Basins. By reconfiguring inlets

and changing operation in order to utilize more of the existing capacity up to the basin spillway, capturable storm water runoff could potentially be increased nearly 600 acre-ft/yr. These findings are encouraging and warrant further evaluation.

After preliminary evaluations of existing facilities, operations, and hydrology in the Chino Basin, it was determined that further investigation was warranted to identify cost effective projects that capture and recharge the currently uncapturable runoff that is accumulating to the channels downstream of existing recharge facilities. Such further evaluation of facilities that might enhance storm water recharge is provided in Sections 5.5 and 5.6.

## **5.5 Conceptual Regional Recharge Distribution System**

Conceptual project components comprising the Recharge Distribution System were developed by the CBWCD and Watermaster and were presented by WEI on December 17, 2009 at a Watermaster Workshop. Conceptual project designs and cost estimates were prepared by CBWCD and conservation and recharge estimates were determined by WEI for each project components individually and as a system.

The system of conceptual project components involves improvement of existing facilities to enhance operation for recharge and development of new recharge facilities and distribution systems. The system components evaluated for the Recharge Distribution System includes the following:

- Improvements to Wineville Basin including a new gate structure on the discharge spillway.
- A pump station and conveyance pipeline from Wineville Basin to Jurupa Basin.
- Improvements to the Lower Day Basin inlet facilities.
- Improvements to Jurupa Basin including improved inlet facilities and capacity enlargement.
- Upgrades to the Jurupa pump station to increase diversion rates to RP3 Basin
- Improvements to RP3 Basin including improved inlet facilities and enlargement.
- Development of the Vulcan Pit as a storm water recharge facility.
- A new flow-through storm water detention basin, Lower Cucamonga Basin, at the lower portion of Cucamonga Creek.
- A pump station and conveyance pipeline from the new Lower Cucamonga Basin to Wineville Basin.
- Improvements to Declez Basin.
- A pump station and conveyance pipeline from Wineville Basin to regulatory storage tanks at the former Etiwanda Basin.
- A pump station and conveyance pipeline from the former Etiwanda Basin to regulatory storage at Hickory Basin.

- A pump station and conveyance pipeline from Hickory Basin to Victoria Basin for regulation and recharge.
- A pump station and conveyance pipeline from Hickory Basin to recharge storm water in Banana Basin.
- A pump station and conveyance pipeline system from the Victoria Basin to recharge storm water in the San Sevaine, Etiwanda Debris and Lower Day basins.
- A new flow through recharge basin, Lower San Sevaine Basin, on Etiwanda and San Sevaine Creek channels.

**5.5.1 Existing Condition**

Most existing recharge basins are located to the north, at higher elevations within the Chino Basin, typically where quarry pits existed in the past or where basins were built for peak flow attenuation to protect downstream areas. The lower basins that do exist have not been exploited for recharge because they generally have poor recharge capabilities. Recharge opportunities for many existing facilities are limited because while basins often fill to conservation capacity during storm events, the storm events are generally short in duration and do not afford replenishment of basin capacity. Storm water in excess of the capacity of the basins bypasses the facility and is lost. Similarly storm water collected in channels below the recharge facilities is also lost.

**5.5.2 Evaluated Alternative**

The regional Recharge Distribution System was conceived and conceptually designed to divert storm water at locations where flow is plentiful and diversion facilities exist and conveyed to recharge facilities when recharge opportunities allow. The system was evaluated at varying capacities, rates and configurations to determine overall net improvement to storm water recharge of Chino Basin.

The Recharge Distribution System has been evaluated to be developed in a series of five phases of system development ranging from improvements to inlets of existing facilities, to implementation of the full diversion, storage, and distribution network. Permutations will all be further optimized as additional project information and constraints are indentified. The five phases of project development are described in the below table and following sections.

**Regional Recharge Distribution System  
Development Phases**

Phase	Description
I	Improvements to Existing Facilities
II	Partial South System Diversion and Distribution System Improvements and Development
III	Total South System Diversion, Distribution System, and Storage Improvements and Development
IV	Northern System Diversion, Distribution and Development
V	Complete System

### 5.5.3 Phase I Development

Phase I development of the Regional Recharge Distribution System involves improvements to existing facilities. These improvements involve modification of diversion inlets or discharge spillway structures of existing recharge facilities to allow greater diversion and storage of water naturally accruing to the facilities.

Phase I construction includes the installation of a pneumatic gate on the Wineville Basin spillway, improvements to the inlet for Lower Day, Jurupa and RP3 Basins, construction of inlet and discharge facilities into Vulcan Pit and operating the existing Jurupa pump station to transfer storm water to RP3 Basin. Facilities of Phase I development are mapped on Figure 5-30 and shown schematically on Figure 5-31.

#### 5.5.3.1 Potential Recharge Increase

WEI estimated potential recharge, by simulating potential diversions to existing recharge facilities under Phase I development conditions. Results of the simulation are shown on the following table:

**Regional Recharge Distribution System**  
**Phase I - Recharge Conditions**  
(values in acre-ft)

Project	Project Component	Current Recharge	Potential Recharge	Potential Recharge Increase
Wineville Basin	Spillway Gate	346	3,474	3,128
Jurupa Basin	Inlet Improvements	596	200	-396
RP3 Basin	Inlet Improvements	244	2,655	2,411
Vulcan Pit	Inlet Improvements	0	1,077	1,077
Lower Day Basin	Inlet Improvements	601	2,070	1,469
<b>Total</b>		<b>1,787</b>	<b>9,476</b>	<b>7,689</b>

Total recharge of the system for Phase I development is up to 9,476 acre-ft and potential increase in recharge is estimated to be between 6,959 and 7,689 acre-ft depending on simulated recharge rates.

#### 5.5.3.2 Potential Cost

Estimated costs for Phase I development projects are shown on the below table.

**Regional Recharge Distribution System  
Phase I - Estimated Cost**

Project	Project Component	Component Cost
Wineville Basin	Spillway Gate	\$5,990,000
Jurupa Basin	Inlet Improvements	\$690,000
RP3 Basin	Inlet Improvements	\$5,890,000
Vulcan Pit	Inlet Improvements	\$2,446,000
Lower Day Basin	Inlet Improvements	\$2,130,000
<b>Total</b>		<b>\$17,146,000</b>

Annualized cost for Phase I development, estimated at 5-percent annual rate of interest for a period of 30 years, is about \$1,115,000. This equates to an annual capital cost of \$183 per acre-foot.

#### **5.5.4 Phase II Development**

Phase II development of the Regional Recharge Distribution System involves improvements to the existing facilities of the Phase I development and the development of a storm water distribution system in the southern area of Chino Basin. The distribution system includes construction of a pump station and about 2 miles of pipeline from Wineville Basin to Jurupa Basin, and upgrading of the pump station at Jurupa Basin to increase its rate of discharge to RP3 Basin.

The new distribution system will allow additional water diverted from Day Creek in Wineville Basin to be recharge in the RP3 and Declez basins where recharge capacities are greater.

The southern basin distribution system and facilities of Phase II development are shown on Figure 5-32. The pipeline alignment from Wineville Basin to Jurupa Basin, depicted on Figure 5-32, is shown for distance and destination purposes only and does not indicate currently known or intended alignments. To the extent possible, the alignment follows Southern California Edison easements, existing roads, and flood control channels. Facilities are shown schematically on Figure 5-33.

##### **5.5.4.1 Potential Recharge Increase**

WEI estimated potential recharge, using their model, by simulating potential diversions to existing recharge facilities under Phase II development conditions. Results of the simulation are shown on the following table:

### Regional Recharge Distribution System

#### Phase II - Recharge Conditions

(values in acre-ft)

Project	Project Component	Current Recharge	Potential Recharge	Potential Recharge Increase
Wineville Basin	Spillway Gate	346	2,425	2,079
Jurupa Basin	Inlet Improvements	596	344	-252
RP3 Basin	Inlet Improvements	244	3,926	3,682
Vulcan Pit	Inlet Improvements	0	1,077	1,077
Lower Day Basin	Inlet Improvements	601	2,070	1,469
<b>Phase I Subtotal</b>		<b>1,787</b>	<b>9,842</b>	<b>8,055</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	0	0	0
Jurupa Pump Station to RP3	40 cfs Diversion Rate	0	0	0
<b>Phase II Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
<b>Total</b>		<b>1,787</b>	<b>9,842</b>	<b>8,055</b>

Note: 1) Recharge increase by Phase II project attributed to increase recharge realized at Phase I project basins.

Total recharge of the system for Phase II development is up to 9,842 acre-ft and potential increase in recharge is estimated to be between 7,298 and 8,055 acre-ft, depending on simulated recharge rates.

#### 5.5.4.2 Potential Cost

Estimated costs for Phase II development projects are shown on the below table.

### Regional Recharge Distribution System

#### Phase II - Estimated Cost

Project	Project Component	Component Cost
Wineville Basin	Spillway Gate	\$5,990,000
Jurupa Basin	Inlet Improvements	\$690,000
RP3 Basin	Inlet Improvements	\$5,890,000
Vulcan Pit	Inlet Improvements	\$2,446,000
Lower Day Basin	Inlet Improvements	\$2,130,000
<b>Phase I Subtotal</b>		<b>\$17,146,000</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	\$9,119,000
Jurupa Pump Station to RP3	40 cfs Diversion Rate	\$282,000
<b>Phase II Subtotal</b>		<b>\$9,401,000</b>
<b>Total</b>		<b>\$26,547,000</b>

Annualized cost for Phase II development, estimated at 5-percent annual rate of interest for a period of 30 years, is about \$1,727,000. This equates to an annual capital cost of \$246 per

acre-foot.

### 5.5.5 Phase III Development

Phase III development of the Regional Recharge Distribution System involves improvements to existing facilities of the Phase I and II developments, and also development of additional storage capacity in southern system by constructing Lower Cucamonga Basin; including a pump station and about 5-miles of pipeline to move water to Wineville Basin. The new Lower Cucamonga Basin will enable diversion of storm flow from Cucamonga Creek that would otherwise be lost.

The southern basin distribution system and facilities of Phase III development are shown on Figure 5-34. Pipeline alignments depicted on Figure 5-34 are shown for distance and destination purposes only and do not indicate currently known or intended alignments. To the extent possible, alignments are shown to follow Southern California Edison easements, existing roads, and flood control channels. Facilities are shown schematically on Figure 5-35.

#### 5.5.5.1 Potential Recharge Increase

WEI estimated potential recharge, using their model, by simulating potential diversions to existing recharge facilities under Phase III development conditions. Results of the simulation are shown on the following table:

**Regional Recharge Distribution System**  
**Phase III - Recharge Conditions**  
(values in acre-ft)

Project	Project Component	Current Recharge	Potential Recharge	Potential Recharge Increase
Wineville Basin	Spillway Gate	346	2,425	2,079
Jurupa Basin	Inlet Improvements	596	344	-252
RP3 Basin	Inlet Improvements	244	7,132	6,888
Vulcan Pit	Inlet Improvements	0	1,077	1,077
Lower Day Basin	Inlet Improvements	601	2,070	1,469
<b>Phase I Subtotal</b>		<b>1,787</b>	<b>13,048</b>	<b>11,261</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	0	0	0
Jurupa Pump Station to RP3	40 cfs Diversion Rate	0	0	0
<b>Phase II Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
Lower Cucamonga Basin	Construct Basin	0	0	0
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	0	0	0
<b>Phase III Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
<b>Total</b>		<b>1,787</b>	<b>13,048</b>	<b>11,261</b>

Note: 1) Recharge increase by Phase II & III projects attributed to increase recharge realized at Phase I project basins.



Total recharge of the system for Phase III development is up to 13,048 acre-ft and potential increase in recharge is estimated to be between 10,504 and 11,261 acre-ft depending on simulated recharge rates.

### 5.5.5.2 Potential Cost

Estimated costs for Phase III development projects are shown on the below table.

#### Regional Recharge Distribution System Phase III - Estimated Cost

Project	Project Component	Component Cost
Wineville Basin	Spillway Gate	\$5,990,000
Jurupa Basin	Inlet Improvements	\$690,000
RP3 Basin	Inlet Improvements	\$5,890,000
Vulcan Pit	Inlet Improvements	\$2,446,000
Lower Day Basin	Inlet Improvements	\$2,130,000
<b>Phase I Subtotal</b>		<b>\$17,146,000</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	\$9,119,000
Jurupa Pump Station to RP3	40 cfs Diversion Rate	\$282,000
<b>Phase II Subtotal</b>		<b>\$9,401,000</b>
Lower Cucamonga Basin	Construct Basin	\$21,060,000
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	\$16,717,000
<b>Phase III Subtotal</b>		<b>\$37,777,000</b>
<b>Total</b>		<b>\$64,324,000</b>

Annualized cost for Phase III development, estimated at 5-percent annual rate of interest for a period of 30 years, is about \$4,184,000. This equates to an annual capital cost of \$519 per acre-foot.

### 5.5.6 Phase IV Development

Phase IV development of the Regional Recharge Distribution System involves improvements to existing facilities of the Phase I, II and III developments in addition to development of the recharge distribution system to basins in the northern and upper end of Chino Basin. Completion of the distribution system to the north involves construction of four pump stations, two regulatory reservoirs, and about 13-miles of pipeline between Wineville Basin and the existing recharge basins to the north.

The complete recharge distribution system will enable water diverted in Lower Cucamonga Basin to be pumped to Wineville Basin where it will be re-diverted to Jurupa Basin and also up to Victoria Basin for recharge and redistribution to Lower Day, Etiwanda Debris, and San Sevaine basins. Movement of water up to Victoria Basin from Wineville Basin is anticipated to require two intermediate pumping stations and regulatory reservoirs to overcome the

approximate 450-feet of elevation gain between Wineville and Victoria basins. These regulatory storage facilities have been preliminarily located at existing or former recharge facilities where either existing basins will be improved or a steel storage tank will be constructed.

Conveyance pipelines between Lower Cucamonga and Victoria Basin are sized to accommodate flow rates modeled by WEI which vary between 10 and 40 cfs. Pipelines from Victoria and Hickory basins to end use recharge facilities are sized in accordance to the maximum recharge rate of the facility.

The complete distribution system is shown on Figure 5-36. The pipeline alignments depicted on Figure 5-36 are shown for distance and destination purposes only and do not indicate currently known or intended alignments. To the extent possible, alignments are shown to follow Southern California Edison easements, existing roads, and flood control channels. Facilities are shown schematically on Figure 5-37.

#### **5.5.6.1 Potential Recharge Increase**

WEI estimated potential recharge, using their model, by simulating potential diversions to existing recharge facilities under Phase IV development conditions. Increase in recharge is shown in the below table.

### Regional Recharge Distribution System

#### Phase IV - Recharge Conditions

(values in acre-ft)

Project	Project Component	Current Recharge	Potential Recharge	Potential Recharge Increase
Wineville Basin	Spillway Gate	346	1,875	1,529
Jurupa Basin	Inlet Improvements	596	288	-308
RP3 Basin	Inlet Improvements	244	3,054	2,810
Vulcan Pit	Inlet Improvements	0	1,077	1,077
Lower Day Basin	Inlet Improvements	601	2,070	1,469
<b>Phase I Subtotal</b>		<b>1,787</b>	<b>8,364</b>	<b>6,577</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	0	0	0
Jurupa Pump Station to RP3	40 cfs Diversion Rate	0	0	0
<b>Phase II Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
Lower Cucamonga Basin	Construct Basin	0	0	0
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	0	0	0
<b>Phase III Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
Wineville Pump Station & Pipeline to Etiwanda	40 cfs Diversion Rate	0	0	0
Etiwanda Pump Station & Pipeline to Hickory	40 cfs Diversion Rate	228	230	2
Hickory Pump Station & Pipeline to Victoria	40 cfs Diversion Rate	739	1,551	812
Hickory Pump Station & Pipeline to Banana	6 cfs Diversion Rate	476	999	523
Victoria Pump Station & Pipeline to Lower Day	8 cfs Diversion Rate	0	259	259
Victoria Pump Station & Pipeline to Etiwanda Debris	7 cfs Diversion Rate	1,409	2,125	716
Victoria Pump Station & Pipeline to San Sevaine 1-4	27 cfs Diversion Rate	1,978	6,089	4,111
Victoria Pump Station & Pipeline to San Sevaine 5	17 cfs Diversion Rate	1,691	2,245	554
<b>Phase IV Subtotal</b>		<b>6,521</b>	<b>13,498</b>	<b>6,977</b>
<b>Total</b>		<b>8,308</b>	<b>21,862</b>	<b>13,554</b>

Note: 1) Recharge increase by Phase II & III projects attributed to increase recharge realized at Phase I and IV project basins.

Total recharge of the system for Phase IV development is up to 21,862 acre-ft and potential increase in recharge is estimated to be between 12,933 and 13,554 acre-ft depending on simulated recharge rates.

#### 5.5.6.2 Potential Cost

Estimated costs for Phase IV development projects are shown on the below table.

**Regional Recharge Distribution System  
Phase IV - Estimated Cost**

Project	Project Component	Component Cost
Wineville Basin	Spillway Gate	\$5,990,000
Jurupa Basin	Inlet Improvements	\$690,000
RP3 Basin	Inlet Improvements	\$5,890,000
Vulcan Pit	Inlet Improvements	\$2,446,000
Lower Day Basin	Inlet Improvements	\$2,130,000
<b>Phase I Subtotal</b>		<b>\$17,146,000</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	\$9,119,000
Jurupa Pump Station to RP3	40 cfs Diversion Rate	\$282,000
<b>Phase II Subtotal</b>		<b>\$9,401,000</b>
Lower Cucamonga Basin	Construct Basin	\$21,060,000
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	\$16,717,000
<b>Phase III Subtotal</b>		<b>\$37,777,000</b>
Wineville Pump Station & Pipeline to Etiwanda	40 cfs Diversion Rate	\$11,900,000
Etiwanda Pump Station & Pipeline to Hickory	40 cfs Diversion Rate	\$19,216,000
Hickory Pump Station & Pipeline to Victoria	40 cfs Diversion Rate	\$22,208,000
Hickory Pump Station & Pipeline to Banana	6 cfs Diversion Rate	
Victoria Pump Station & Pipeline to Lower Day	8 cfs Diversion Rate	
Victoria Pump Station & Pipeline to Etiwanda Debris	7 cfs Diversion Rate	\$31,228,000
Victoria Pump Station & Pipeline to San Sevaine 1-4	27 cfs Diversion Rate	
Victoria Pump Station & Pipeline to San Sevaine 5	17 cfs Diversion Rate	
<b>Phase IV Subtotal</b>		<b>\$84,552,000</b>
<b>Total</b>		<b>\$148,876,000</b>

Annualized cost for Phase IV development, estimated at 5-percent annual rate of interest for a period of 30 years, is about \$9,685,000. This equates to an annual capital cost of \$736 per acre-foot.

### 5.5.7 Phase V Development

Phase V development of the Regional Recharge Distribution System involves improvements to existing facilities of the Phase I, II, III, and IV developments in addition to development of additional storage capacity in the system. Additional storage capacity is created through enlargement of Jurupa and RP3 basins, as well as the construction of Lower San Sevaine Basin.

Jurupa Basin modifications pursuant to the Option 2 alternative developed by Stantec Consulting Inc. (Stantec) include excavation and pumping station modifications. Modifications of RP3 Basin include and excavation and facility improvements. Additional storage in Jurupa and RP3 Basins will further increase the amount of storm water to be recharge in the RP3 and Declez basins. Construction of the new Lower San Sevaine Basin

will develop about 600 acre-ft of storage capacity.

The complete system and facilities of Phase V development are shown on Figure 5-38. Pipeline alignments depicted on Figure 5-38 are shown for distance and destination purposes only and do not indicate currently known or intended alignments. To the extent possible, alignments are shown to follow Southern California Edison easements, existing roads, and flood control channels. Facilities are shown schematically on Figure 5-39.

#### **5.5.7.1 Potential Recharge Increase**

WEI estimated potential recharge, using their model, by simulating potential diversions to existing recharge facilities under Phase V development conditions. Increase in recharge is shown in the below table.

### Regional Recharge Distribution System

#### Phase V - Recharge Conditions

(values in acre-ft)

Project	Project Component	Current Recharge	Potential Recharge	Potential Recharge Increase
Wineville Basin	Spillway Gate	346	1,875	1,529
Jurupa Basin	Inlet Improvements	596	169	-427
RP3 Basin	Inlet Improvements	244	3,054	2,810
Vulcan Pit	Inlet Improvements	0	1,077	1,077
Lower Day Basin	Inlet Improvements	601	2,070	1,469
<b>Phase I Subtotal</b>		<b>1,787</b>	<b>8,245</b>	<b>6,458</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	0	0	0
Jurupa Pump Station to RP3	40 cfs Diversion Rate	0	0	0
<b>Phase II Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
Lower Cucamonga Basin	Construct Basin	0	0	0
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	0	0	0
<b>Phase III Subtotal</b>		<b>0</b>	<b>0</b>	<b>0<sup>1</sup></b>
Wineville Pump Station & Pipeline to Etiwanda	40 cfs Diversion Rate	0	0	0
Etiwanda Pump Station & Pipeline to Hickory	40 cfs Diversion Rate	228	230	2
Hickory Pump Station & Pipeline to Victoria	40 cfs Diversion Rate	739	1,551	812
Hickory Pump Station & Pipeline to Banana	6 cfs Diversion Rate	476	999	523
Victoria Pump Station & Pipeline to Lower Day	8 cfs Diversion Rate	0	259	259
Victoria Pump Station & Pipeline to Etiwanda Debris	7 cfs Diversion Rate	1,409	2,125	716
Victoria Pump Station & Pipeline to San Sevaine 1-4	27 cfs Diversion Rate	1,978	6,089	4,111
Victoria Pump Station & Pipeline to San Sevaine 5	17 cfs Diversion Rate	1,691	2,245	554
<b>Phase IV Subtotal</b>		<b>6,521</b>	<b>13,498</b>	<b>6,977</b>
Lower San Sevaine Basin	Construct Basin	0	1,679	1,679
RP3 Basin	Basin Enlargement	-	738	738
Jurupa Basin	Basin Enlargement	-	0	0
<b>Phase V Subtotal</b>		<b>0</b>	<b>2,417</b>	<b>2,417</b>
<b>Total</b>		<b>8,308</b>	<b>24,160</b>	<b>15,852</b>

Note: 1) Recharge increase by Phase II & III projects attributed to increase recharge realized at Phase I and IV project basins.

Total recharge of the system for Phase V development is up to 24,160 acre-ft and potential increase in recharge is estimated to be between 14,539 and 15,852 acre-ft depending on simulated recharge rates.

### 5.5.7.2 Potential Cost

Estimated costs for Phase V development projects are shown on the below table.

#### Regional Recharge Distribution System Phase V - Estimated Cost

Project	Project Component	Component Cost
Wineville Basin	Spillway Gate	\$5,990,000
Jurupa Basin	Inlet Improvements	\$690,000
RP3 Basin	Inlet Improvements	\$5,890,000
Vulcan Pit	Inlet Improvements	\$2,446,000
Lower Day Basin	Inlet Improvements	\$2,130,000
<b>Phase I Subtotal</b>		<b>\$17,146,000</b>
Wineville Pump Station & Pipeline to Jurupa	20 cfs Diversion Rate	\$9,119,000
Jurupa Pump Station to RP3	40 cfs Diversion Rate	\$282,000
<b>Phase II Subtotal</b>		<b>\$9,401,000</b>
Lower Cucamonga Basin	Construct Basin	\$21,060,000
Lower Cucamonga Pump Station & Pipeline to Wineville	20 cfs Diversion Rate	\$16,717,000
<b>Phase III Subtotal</b>		<b>\$37,777,000</b>
Wineville Pump Station & Pipeline to Etiwanda	40 cfs Diversion Rate	\$11,900,000
Etiwanda Pump Station & Pipeline to Hickory	40 cfs Diversion Rate	\$19,216,000
Hickory Pump Station & Pipeline to Victoria	40 cfs Diversion Rate	\$22,208,000
Hickory Pump Station & Pipeline to Banana	6 cfs Diversion Rate	
Victoria Pump Station & Pipeline to Lower Day	8 cfs Diversion Rate	
Victoria Pump Station & Pipeline to Etiwanda Debris	7 cfs Diversion Rate	\$31,228,000
Victoria Pump Station & Pipeline to San Sevaine 1-4	27 cfs Diversion Rate	
Victoria Pump Station & Pipeline to San Sevaine 5	17 cfs Diversion Rate	
<b>Phase IV Subtotal</b>		<b>\$84,552,000</b>
Lower San Sevaine Basin	Construct Basin	\$30,360,000
RP3 Basin	Basin Enlargement	\$16,630,000
Jurupa Basin	Basin Enlargement	\$20,270,000
<b>Phase V Subtotal</b>		<b>\$67,260,000</b>
<b>Total</b>		<b>\$216,136,000</b>

Annualized cost for Phase V development, estimated at 5-percent annual rate of interest for a period of 30 years, is about \$14,060,000. This equates to an annual capital cost of \$887 per acre-foot.

Considering the potential for the excavation of the Lower San Sevaine, RP3 and Jurupa Basins could be completed and compensated by lease agreements to surface mining operators, the cost for completing the Phase V work could be significantly reduced. Estimating that the cost could be reduced by about \$66-million, the annualized cost for Phase V development is reduced to about \$9,737,000 which equates to an annual capital cost of \$614 per acre-foot.

### 5.5.8 Phased Development Discussion

The Recharge Distribution System is proposed and evaluated for development in a series of phases. The phasing of construction of the Recharge Distribution System is proposed for convenience of design and construction without any prioritization or rigorous cost to benefit analysis. The phasing of the system development was established by developing an order of construction with each component or phase building on the previous phase of work.

The following table summarizes the cost and the incremental increase recharge developed in the phase of Recharge Distribution System development.

#### Regional Recharge Distribution System Summary of Cost and Recharge by Phase

(values in acre-ft)

Phase	Incremental Total Cost	Incremental Recharge Increase
I	\$17,146,000	7,689
II	\$9,401,000	366
III	\$37,777,000	3,206
IV	\$84,552,000	2,293
<u>V</u>	<u>\$67,260,000</u>	<u>2,298</u>
<b>Total</b>	<b>\$216,136,000</b>	<b>15,852</b>

The increase in cost to progress the development of the Recharge Distribution System from, for example, Phase II to Phase III is an additional \$37,777,000 which nets an additional 3,206 acre-ft of recharge to the Chino Basin. The Phase III project could not be completed and obtain the estimated increase in recharge unless the Phase II project components are completed. The Phase II projects components, considering the relatively minimal amount of recharge increase, would probably not be completed unless Phase III project components were planned to be developed.

The increase in recharge developed by each phase is evaluated in the aggregate of all projects within the Chino Basin. The system is proposed and is modeled to move storm water to recharge facilities as capacity is available. Further optimization may improve recharge and reduce incremental costs.

### 5.5.9 Distribution Power Requirements and Cost

The cost to pump and move water as part of the Regional Recharge Distribution System is estimated based on a rate of \$0.14 per kwh as provided in the 2010 Recharge Master Plan Update Technical Memorandum, Task 3 Planning Criteria, prepared by Black & Veatch and WEI dated March 19, 2009. Annual power costs for distributing increased storm water for recharge, determined by estimating the power required to move the storm water at the



maximum rate simulated by WEI, are shown in the below table.

**Regional Recharge Distribution System  
Annual Energy Cost**

Phase	Total Horsepower Required	Annual Energy Cost
I	300	\$63,000
II	905	\$382,000
III	1,700	\$769,000
IV	6,850	\$4,038,000
V	6,850	\$4,038,000

### 5.5.10 Operation and Maintenance Costs

The cost attributable to annual Operation and Maintenance (O&M) of the Regional Recharge Distribution System has been estimated at a rate of \$50 per acre-foot of total recharge. Annual O&M costs for each phase of development are shown in the below table.

**Regional Recharge Distribution System  
Operation and Maintenance Cost**

Phase	Total Recharge	Annual O&M Cost
I	9,476	\$473,800
II	9,842	\$492,100
III	13,048	\$652,400
IV	21,862	\$1,093,100
V	24,160	\$1,208,000

### 5.5.11 Total Annualized Cost

The annualized cost of the Regional Recharge Distribution System including project construction, energy and O&M costs is shown in the below table. Phase Vb is provided for discussion proposes to demonstrate the possible effect of removing the cost of excavation, approximately \$66-million, for additional storage capacity of RP3, San Sevaine and Jurupa Basins. The concept is that the excavation could be performed as part of a lease agreement with a surface mining operation or similar.

**Regional Recharge Distribution System  
Total Cost**

Phase	Total Recharge Increase	Annual Cost	Cost /AF Recharge
I	7,689	\$1,651,800	\$215
II	8,055	\$2,601,100	\$323
III	11,261	\$5,605,400	\$498
IV	13,554	\$14,816,100	\$1,093
V	15,852	\$19,306,000	\$1,218
Vb	15,852	\$14,962,000	\$944

The range of realized recharge and cost of the Regional Recharge Distribution System (including additional contingencies) will vary depending on basin maintenance and variations in annual costs. To estimate the range of costs for each phase of development we applied a reduction factor of 25 percent to recharge values and a 15 percent increase to annual cost values. Estimated realized costs of recharge developed at each level of development, based on the aforementioned contingency factors, are shown in the below table.

**Regional Recharge Distribution System  
Range of Realized Recharge and Total Cost**

Phase	Realized Recharge	Realized Annual Cost	Cost /AF Recharge
	Decrease 25%	Increase 15%	
I	5,767 - 7,689	\$1,651,800 - \$1,899,600	\$215 - \$329
II	6,041 - 8,055	\$2,601,100 – \$2,991,300	\$323 - \$495
III	8,446 - 11,261	\$5,605,400 – \$6,446,200	\$498 - \$763
IV	10,166 - 13,554	\$14,816,100 – \$17,038,500	\$1,093 - \$1,676
V	11,889 - 15,852	\$19,306,000 – \$22,201,900	\$1,218 - \$1,867
Vb	11,889 - 15,852	\$14,962,000 – \$17,206,300	\$944 - \$1,447

**5.6 Potential Improvement Projects**

**5.6.1 Wineville Basin**

**5.6.1.1 Existing Condition**

Wineville Basin is located on Day Creek and is essentially a flow-through flood control basin, designed for peak flood discharge attenuation. Both the primary inlet spillway and outlet spillway are not gated. There are four smaller drain inlets to the basin. The basin is roughly nine feet deep at the outlet spillway (the basin bottom elevation varies). Wineville Basin was evaluated for potential groundwater recharge use in 2000, but determined to not be viable due to shallow clay lenses. However, recent experience with Lower Day Basin revealed that the clay lenses may have resulted from mining activity on Day Creek and remediation may be

possible to increase infiltration capacity.

### **5.6.1.2 Proposed Improvement Alternatives**

- Install a pneumatic gate in the spillway of the existing basin. This alternative is described in Section 5.6.1.3.
- Excavate the interior basin to acquire additional storage capacity. Wineville Basin was preliminarily evaluated to increase storage capacity by excavating the interior basin 5, 15 and 25 feet below the original basin bottom elevation. Excavating the interior basin generates additional capacity, but it also requires modification and repairs of the inlet spillway, drain inlet energy dissipation and erosion protection facilities. Excavating the existing basin bottom 25 feet deeper would develop about 895 acre-ft of storage and require the export of over 1.4-million cubic yards of material. Alternatives involving excavation of Wineville Basin are potentially viable, albeit costly; however they have been removed from further evaluation primarily due to the efficiency of storage capacity gained by only adding a gate to the existing spillway and making any necessary changes to the embankment, as described in Section 5.6.1.3.

### **5.6.1.3 Evaluated Alternatives**

The proposed Wineville Basin improvement project will operate as a multi-purpose facility operated for storm water detention, on-site groundwater recharge, and regulatory storage for the re-diversion of storm water to other recharge facilities. The primary element to the Wineville Basin project is construction and installation of a pneumatic gate in the existing spillway of the basin. Installation of a gate structure in the spillway will develop about 510 acre-ft of storage within the existing freeboard of the basin.

A pneumatic gate is a bladder actuated gate system that allows for the automatic level or flow control of water in the reservoir or over the gate structure. The pneumatic gate will monitor and self-adjust to maintain the reservoir water storage level or discharge over the gate structure in accordance with the logic programming that has been set to operate. For the Wineville Basin project, the primary mode of operation for the pneumatic gate will be to maintain a maximum reservoir water surface elevation while inflows into the basin from Day Creek or local storm water flows are occurring. The gate will automatically raise or lower (until the gate is flat with the spillway channel bottom if necessary) to maintain the set channel water surface elevation in the reservoir. The gate can also be manually lowered if necessary to evacuate all storage in the reservoir prior to storm events or other operational requirements. Details of the proposed project are shown in Figures 5-40 and 5-41.

The existing earth embankment structure will be evaluated and reconstructed to meet the requirements of a dam embankment under the jurisdiction of the State of California Department of Water Resources Division of Safety of Dams (DSOD). Embankment fills of height and capacity shown on Figure 5-42 are under the jurisdiction of the State of DSOD. Improvements to the dam structure may include excavation of the existing embankment to expose firm, undisturbed and stable material across the entire width and length of the embankment and excavation of a keyway or cutoff trench that will extend to an underlying impervious material, or to a depth considered adequate to prevent piping or seepage through

the embankment. The dam embankment will be constructed at a typical slope of about 3:1 (H:V) on the upstream side and 2:1 (H:V) on the downstream side.

The existing basin bottom will be cleaned and graded to improve the recharge capacity of the basin and to allow the basin to better function as a distribution system for water being pumped to other recharge facilities.

Storm water accruing to Wineville Basin is proposed to be diverted to Jurupa Basin and/or to other recharge facilities within Chino Basin for recharge. A pump station will be constructed with conveyance pipelines extending from Wineville Basin to Jurupa and/or towards other recharge facilities (see Figure 5-43). This system is described in Section 5.5.

Additional conceptual level investigations and evaluations will be required to verify the project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- Evaluate affects of the proposed project to the hydraulics of the existing drain inlets and inlet channels.
- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Review and evaluate project operations during design storm events with SBCFCD.
- Review and evaluate known environmental concerns with SBCFCD.

Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

#### **5.6.1.3.1 Potential Recharge Increase**

Potential recharge at Wineville Basin was modeled by WEI according to varying potential diversion rates and varying potential infiltration rates resulting from basin improvements. Diversions from Wineville could vary from 10 to 30 cfs. Results of the WEI simulation are shown in the below table.

**Potential Increased Storm Water Recharge  
Wineville Basin**

(values in acre-ft)

Alternative	Current Recharge	Potential Recharge	Potential Increase in Recharge
0.25 ft/day Infiltration	176	2,597	2,421
0.50 ft/day Infiltration	346	3,474	3,128

**5.6.1.3.2 Potential Cost**

The estimated cost for construction of Wineville Basin is shown on the below table. A discussion of the development of project cost items is provided in Section 5.6.11. Cost of basin cleaning and contouring can be significantly reduced or offset if material excavated for the project can be used for other purposes such as in conjunction with another construction project that requires imported borrow material.

**Cost Estimate for Conceptual Project Evaluation of Wineville Basin**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization @ 3% Other Direct Construction Cost</u>	1	Job	Lump Sum	\$127,000
2 <u>Compacted Embankment</u>				
Foundation Excavation	122,000	Cu. Yds.	\$3.00	\$366,000
Compacted Embankment	122,000	Cu. Yds.	\$6.00	\$732,000
3 <u>Basin Spillway/Discharge Structure</u>				
Spillway Gate	1	Job	\$720,000	\$720,000
Concrete/Building Components	1	Job	\$1,038,000	\$1,038,000
4 <u>Basin Cleaning and Contouring</u>				
Basin Excavation	110,000	Cu. Yds.	\$12.50	\$1,375,000
<b>Subtotal Direct Construction</b>				<b>\$4,358,000</b>
<b>Contingency @ 25%</b>				<b>\$1,089,500</b>
<b>Total Construction</b>				<b>\$5,447,500</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$545,000</u>
<b>Total Engineering and Administration</b>				<b>\$545,000</b>
<b>Total Estimated Cost</b>				<b>\$5,992,500</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$5,990,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$389,800</b>

**5.6.1.3.3 Discussion**

Preliminary evaluation of recharge efficiency of the project indicates that the project is efficient in diversion of additional water for recharge and for diversion export to other recharge facilities. At an estimated annual cost of about \$390,000, the facility could capture for recharge, and/or diversion, an additional 2,421 to 3,128 acre-ft of water annually. This equates to an annualized cost between \$125 and \$161 per acre-foot.

**5.6.2 Lower Day Basin****5.6.2.1 Existing Condition**

Lower Day Basin is located on the western side of the Day Creek channel and is currently operated as a multi-purpose facility serving first as a flood control facility and secondarily for recharge of storm and supplemental water. The basin is divided into three cells and can

receive water from the Day Creek channel for recharge during low-flow events by means of an existing rubber dam diversion structure and pipe conduit. The basin also receives inflow from a side channel overflow weir for flood control operation.

### **5.6.2.2 Proposed Improvement Activities**

- Modify the existing diversion intake structure and install pneumatic gates in the channel. This alternative is described in Section 5.6.2.3.
- Enlarge the existing Lower Day Basin by excavating the area currently held by the local storm water detention basin. Excavating the basin would develop about 158 acre-ft of additional storage however, would require removal of over 1.1 million cubic yards of material. Cost of this excavation with the relatively minor amount of storage obtained provided reasonable justification to drop the concept from further evaluation.

### **5.6.2.3 Evaluated Alternatives**

The proposed Lower Day Basin project will function as a modified flow-through basin through modification of the existing diversion and inlet channel structure and installation of pneumatic gates both in the Day Creek channel and the diversion channel. The diversion and inlet channel will be modified by removing the side-channel overflow weir wall and reshaping of the channel bottom to direct low and moderate level flows into the diversion channel and thence into the basin. Gate structures will provide the capability to fully adjust diversion rates through the diversion and Day Creek channels. Details of the proposed project are shown in Figures 5-44 and 5-45.

The pneumatic gate will monitor and self-adjust to maintain a water level or rate of discharge over the gate structure in accordance with logic programming that has been set to operate. For the Lower Day Basin, the gate in the Day Creek channel will function to impede water flowing through the channel so that it can be diverted through the existing diversion channel into Lower Day Basin. Gates will automatically raise or lower (until the gate is flat with the channel bottom if necessary) to maintain the set channel water surface elevation. The gate structure in the diversion channel will function to control the rate of diversion into the basin. If the basin is filled to capacity, the gate will function to allow only enough water into the facility to keep the basin full. Discussions with the gate manufacturer and review of test results provided by the gate manufacturer indicate that a pneumatic gate will perform adequately as proposed in the Day Creek channel (see Figure 5-46).

The existing earth embankment structure will be evaluated and reconstructed to meet the requirements of a dam embankment under the jurisdiction of the DSOD. Embankment fills of sufficient height and capacity are under the jurisdiction of DSOD. Improvements to the dam structure may include excavation of the existing embankment to expose firm, undisturbed and stable material across the entire width and length of the embankment and excavation of a keyway or cutoff trench that will extend to an underlying impervious material, or to a depth considered adequate to prevent piping or seepage through the embankment.

The dam embankment will be constructed at a typical slope of about 3:1 (H:V) on the upstream side and 2:1 (H:V) on the downstream side.

Lower Day Basin is also proposed to receive water diverted at other diversion facilities, such as Lower Cucamonga and Wineville Basins for recharge as part of the regional recharge distribution system as was described in Section 5.5.

Additional conceptual level investigations and evaluations will be required to verify the project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- SCE should be consulted to discuss the project’s encroachment into the existing SCE easement.
- Site specific analysis and modeling of the project to verify hydraulic constraints of existing and proposed facilities.
- Evaluate the existing outlet conduit to determine if modification will be required. (SCADA will most likely be necessary)
- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Review and evaluate project operations during design storm events with SBCFCD.
- Further review and evaluate performance of gate structure in high-energy channel installation with gate manufacturer.
- Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

**5.6.2.3.1 Potential Recharge Increase**

The potential increase of storm water recharge resulting from improvements to Lower Day, as estimated by WEI, is as follows:

**Potential Increased Storm Water Recharge**  
**Lower Day Basin**  
 (values in acre-ft)

Current Recharge	Potential Recharge with Inlet Improvement	Potential Increase in Recharge with Inlet Improvement
601	2,070	1,469



### 5.6.2.3.2 Potential Cost

The estimated cost for construction of Lower Day Basin is shown on the below table. A discussion of the development of project cost items is provided in Section 5.6.11.

**Cost Estimate for Conceptual Project Evaluation of  
Lower Day Basin**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$45,000
2 <u>Compacted Embankment</u>				
Foundation Excavation	72,000	Cu. Yds.	\$3.00	\$216,000
Compacted Embankment	72,000	Cu. Yds.	\$6.00	\$432,000
3 <u>Day Creek Channel Modification</u>				
Channel Demolition	400	Cu. Yds.	\$55.00	\$22,000
Gate	1	Job	\$144,000	\$144,000
Gate Structure	1	Job	\$165,000	\$165,000
4 <u>Basin Diversion Channel Inlet</u>				
Gate	1	Job	\$144,000	\$144,000
Gate Structure	1	Job	\$378,000	\$378,000
<b>Subtotal Direct Construction</b>				<b>\$1,546,000</b>
<b>Contingency @ 25%</b>				<b>\$386,500</b>
<b>Total Construction</b>				<b>\$1,932,500</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				\$193,000
<b>Total Engineering and Administration</b>				<b>\$193,000</b>
<b>Total Estimated Cost</b>				<b>\$2,125,500</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$2,130,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$138,300</b>

### 5.6.2.3.3 Discussion

Preliminary evaluation of recharge efficiency of the project indicates that the project is relatively efficient in diversion of additional water for recharge. Improvements to the diversion structure as proposed will increase capture about 1,469 acre-ft of water annually at an annualized cost of about \$138,300 or about \$95 an acre-foot.

## 5.6.3 Jurupa Basin

### 5.6.3.1 Existing Condition

Jurupa is a flood control basin adjacent to San Sevaine Creek channel in Fontana, CA. Jurupa is designed for peak flood discharge attenuation. Flows are diverted into the basin through an

overflow side channel weir. Imported and recycled water can also be transferred to Jurupa through a low flow diversion culvert. Jurupa has been evaluated and found to have limited groundwater recharge potential as a result of poor infiltration capacity.

### **5.6.3.2 Proposed Improvement Alternatives**

An analysis was conducted by Stantec and preliminary results were reported in their October 28, 2009 draft study. The Stantec study identified conceptual improvements to the San Sevaine Creek channel and Jurupa Basin in order to increase both the rate of water diverted from the creek and the amount of water stored for groundwater recharge in Jurupa. Options Stantec reviewed included the following:

- Construction of a drop inlet in San Sevaine Creek Channel.
- Construction of a rubber dam in San Sevaine Creek Channel.
- Creation of additional conservation storage in Jurupa Basin.

### **5.6.3.3 Evaluated Alternatives**

Evaluated alternatives reported by Stantec are as follows:

Creation of conservation storage within Jurupa Basin is proposed as a feasible approach to meeting storm water capture/storage objectives. Two options have been developed conceptually including:

- Option 1 – Excavate the existing basin about 9 feet with a typical side slope 5:1 (H:V) would add approximately 300 acre-ft of additional storage. Limits of excavation will be offset from existing embankments at least 100-feet except at the north embankment where the existing low-flow delivery channel for the pump station is located and at the existing conservation dike. The minimum basin invert for the water conservation pool is set by the elevation at the inlet to the existing pump station wet well. The pump station is currently capable of lifting approximately 20 cfs corresponding to an approximate drawdown time with no infiltration or inflow of 8 days.
- Option 2 – Excavate the existing basin about 29 feet with a typical side slope 5:1 (H:V). This will add approximately 685 acre-ft of additional conservation storage. Limits of excavation will be offset from existing embankments at least 100-feet except at the north embankment where the existing low-flow delivery channel for the pump station is located and at the existing conservation dike. The proposed basin invert for the water conservation pool will require a lift station in order to deliver water to the existing pump station wet well. The flow rate for the additional lift station is assumed to match the existing pump station (20 cfs) and the approximate drawdown time with no infiltration or inflow is 17 days assuming a pumping rate of 20 cfs.

Conceptual improvements to increase the diversion rates are as follows:

- Drop Inlet – Construct a drop inlet located upstream of the existing low flow

diversion turnout in order to take advantage of the elevation difference between the main line channel and adjacent diversion channel. The entire mainline channel and a portion of the diversion channel would be demolished in order to construct the drop inlet.

- Rubber Dam – Construct a rubber dam located downstream of the existing low flow diversion turnout, providing additional headwater at the existing turnout and thus an increased diversion rate. A portion of the easterly mainline channel sidewall and westerly diversion channel sidewall would be demolished in order to construct a new turnout adjacent to the rubber dam.

See Figure 5-47 for evaluated alternative schematic.

In previous analyses CBWCD evaluated the potential increase in storage in Jurupa Basin if the reservoir was excavated 25 or 50 feet deeper. The analyses determined that if the basin was excavated at a 3H:1V slope from the interior toe of the existing basin, about 1,930 acre-ft of additional storage would be developed by the 25 foot depth of excavation, and about 2,730 acre-ft would be developed by excavating 50 feet in depth. Excavation configurations were conceptual in nature however comparison between Stantec and CBWCD configurations show that the CBWCD configuration for the corresponding depth of excavation of 25 feet is 1,245 acre-ft greater in capacity increase than the Stantec configuration. This is due to differences in basin excavation criteria. Stantec included an offset from the interior basin toe of 100 feet, CBWCD had no offset; Stantec estimated excavated basin slopes at 5H:1V, CBWCD evaluated the basin at 3H:1V; Stantec included terracing of the excavation slopes when slope depths exceeded 30 feet per UBC requirements. CBWCD (for simplicity) did not include this constraint in its conceptual evaluation and therefore the estimated volumes maybe slightly overstated, the significant difference however indicates that additional storage capacity may be realized under Stantec options of excavation if the interior toe offset was reduced and excavated basin slopes were excavated at 3H:1V. We note that increasing storage volume at Jurupa Basin may not increase recharge.

**5.6.3.3.1 Potential Recharge Increase**

WEI simulated potential recharge increases resulting from improvement alternatives at Jurupa Basin based on the evaluation prepared by Stantec. Recharge estimates for Option 1 or Option 2 basin enlargements with only inflow from San Sevaine Creek from an improved inlet were not evaluated. Results of the simulation are shown in the below table.

**Potential Increased Storm Water Recharge Jurupa Basin**

(values in acre-ft)

Alternative	Current Recharge	Potential Recharge in Basin	Potential Increase in Recharge in Basin
Improved Inlet	596	1,054	458

### 5.6.3.3.2 Potential Cost

The estimated cost for construction of Jurupa Basin is shown on the below tables. Potential costs for development of project options were estimated utilizing quantities and lump sum costs prepared by Stantec. Unit costs for excavation developed by CBWCD for evaluation of other RMP projects were applied to quantities provided by Stantec. Mobilization for the project was also evaluated with the same methodology as other RMP cost estimates. A discussion of the development of project cost items is provided in Section 5.6.11. The cost for excavation of the basin could be significantly reduced or offset if material excavated for the project can be used for other purposes such as in conjunction with another construction project that requires imported borrow material.

#### Cost Estimate for Conceptual Project Evaluation of Jurupa Basin Stantec - Option 1 (Improved Inlet and 15 Foot Excavation)

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$197,000
2 <u>Reservoir Excavation</u> Excavate & Haul Offsite	485,000	Cu. Yds.	\$12.50	\$6,062,500
3 <u>Inlet Improvement</u> Rubber Dam and Structure	1	Job	\$335,000	\$335,000
Sluice Gate	1	Job	\$25,000	\$25,000
Electrical Service	1	Job	\$100,000	\$100,000
SCADA Interface	1	Job	\$30,000	\$30,000
<b>Subtotal Direct Construction</b>				<b>\$6,749,500</b>
<b>Contingency @ 25%</b>				<b><u>\$1,687,400</u></b>
<b>Total Construction</b>				<b>\$8,436,900</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$844,000</u>
<b>Total Engineering and Administration</b>				<b>\$844,000</b>
<b>Total Estimated Cost</b>				<b>\$9,280,900</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$9,280,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$603,700</b>

**Cost Estimate for Conceptual Project Evaluation of Jurupa Basin  
Stantec - Option 2 (Improved Inlet and 29 Foot Excavation)**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$444,000
2 <u>Reservoir Excavation</u>				
Excavate & Haul Offsite	1,105,000	Cu. Yds.	\$12.50	\$13,812,500
3 <u>Inlet Improvement</u>				
Rubber Dam and Structure	1	Job	\$335,000	\$335,000
Sluice Gate	1	Job	\$25,000	\$25,000
Electrical Service	1	Job	\$100,000	\$100,000
SCADA Interface	1	Job	\$30,000	\$30,000
4 <u>Pump Station Modification</u>				
Lift Station	1	Job	\$500,000	\$500,000
<b>Subtotal Direct Construction</b>				<b>\$15,246,500</b>
<b>Contingency @ 25%</b>				<b><u>\$3,811,600</u></b>
<b>Total Construction</b>				<b>\$19,058,100</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$1,906,000</u>
<b>Total Engineering and Administration</b>				<b>\$1,906,000</b>
<b>Total Estimated Cost</b>				<b>\$20,964,100</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$20,960,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$1,363,700</b>

**Cost Estimate for Conceptual Project Evaluation of Jurupa Basin  
Stantec - Inlet Improvement (Drop Inlet)**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$12,000
2 <u>Inlet Improvement</u>				
Drop Inlet Structure	1	Job	\$330,000	\$330,000
Sluice Gate	1	Job	\$25,000	\$25,000
Electrical Service	1	Job	\$25,000	\$25,000
SCADA Interface	1	Job	\$30,000	\$30,000
<b>Subtotal Direct Construction</b>				<b>\$422,000</b>
<b>Contingency @ 25%</b>				<b><u>\$105,500</u></b>
<b>Total Construction</b>				<b>\$527,500</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$53,000</u>
<b>Total Engineering and Administration</b>				<b>\$53,000</b>
<b>Total Estimated Cost</b>				<b>\$580,500</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$580,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$37,800</b>

**Cost Estimate for Conceptual Project Evaluation of Jurupa Basin  
Stantec - Inlet Improvement (Rubber Dam)**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$15,000
2 <u>Inlet Improvement</u>				
Dam and Structure	1	Job	\$335,000	\$335,000
Sluice Gate	1	Job	\$25,000	\$25,000
Electrical Service	1	Job	\$100,000	\$100,000
SCADA Interface	1	Job	\$30,000	\$30,000
<b>Subtotal Direct Construction</b>				<b>\$505,000</b>
<b>Contingency @ 25%</b>				<b>\$126,300</b>
<b>Total Construction</b>				<b>\$631,300</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$63,000</u>
<b>Total Engineering and Administration</b>				<b>\$63,000</b>
<b>Total Estimated Cost</b>				<b>\$694,300</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$690,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$45,200</b>

#### 5.6.3.3.3 Discussion

Preliminary evaluation of recharge efficiency of the project without diversions of storm water to other recharge facilities and without excavation of the basin indicates improvements will capture about 458 acre-ft of water annually at an annualized cost of about \$45,000 (for the more expensive inlet improvement option evaluated) or about \$98 an acre-foot.

## 5.6.4 RP3 Basin

### 5.6.4.1 Existing Condition

RP3 is made up of 4 separate cells adjacent to Declez Channel. Water is diverted from Declez channel by inflating a rubber bladder dam in the channel and directing flow into a feeder channel. Cells 1, 3, and 4 divert flow from the feeder channel for recharge. Cell 1 also has the potential to receive water from Jurupa Basin. Recharge cells typically produce relatively high infiltration rates (up to 2.5 ft/day). Some storm water is diverted into Cell 2, though Cell 2 is reserved as a mitigation site in compliance with the Regional Water Quality Board 401

Certification.

#### **5.6.4.2 Proposed Improvement Alternatives**

- Construct a new diversion inlet and conveyance between existing cells of the RP3 Basin. Excavate Cells 1, 3 & 4 40-feet to acquire additional storage. These alternatives are described in Section 3.4.3.
- Excavate Cell 2 and move the existing mitigation site.
- Excavate to combine Cells 3 and 4 or Cells 2, 3 & 4 into one basin. Combination of cells 3 and 4 or Cells 2, 3 & 4 would require either or a combination of excavation of material above the proposed storage elevation and construction of a dam for the lower portion of project area.
- Excavate Cells 3 and 4 or Cells 2, 3 & 4 to also include the area currently occupied by the existing diversion intake and distribution canal.
- Excavate Cells to a depth greater or less than the 40-foot depth currently evaluated.

#### **5.6.4.3 Evaluated Alternatives**

The RP3 Basin project is proposed to function as a modified flow-through basin for water in Declez Creek channel. A new diversion structure and conduit is proposed to be constructed east of the project at a point higher in elevation than the existing point of diversion. A pneumatic gate will be installed in Declez Channel immediately downstream of the new diversion intake structure. The intake structure will be equipped with an intake gate to control the rate of diversion from the channel. Water will flow from the intake structure through a box culvert channel into Cell 1 of the RP3 Basin. The box culvert is proposed to be sufficiently sized to allow equipment to traverse the culvert for cleaning and maintenance. With the new diversion structure located higher in Declez Channel, water can be diverted and stored to a higher elevation than existing operations allow. The proposed maximum storage elevation for Cell 1 will be equal to the invert of the channel at the point of diversion. A low-level box culvert channel with an automatic flow level-control valve will hydraulically connect Cell 1 to Cells 3 so that the cells will effectively operate as one basin. A similar low-level pipe outlet will connect Cell 3 to Cell 4. Overflow spillways will be constructed for each basin. The overflow conduit for Cell 1 will discharge into the existing diversion channel that can be diverted into Cell 3 & 4 or else outfall to the Declez Channel. Cells 3 & 4 will each have an overflow spillway channel that will discharge into Declez Channel. Details of the proposed project are shown in Figures 5-48 and 5-49.

RP3 Basin, particularly Cells 1, 3 & 4, may be excavated to acquire additional storage capacity. Excavation of cells 40 feet deep would develop about 476 acre-ft of storage.

RP3 Basin, Cell 1 currently receives water pumped from Jurupa Basin. A pipeline is proposed to be added to allow water to discharge directly to Cells 3 and/or 4 independently from Cell 1.



The existing earth embankment structure will be evaluated and reconstructed as necessary to meet requirements of a dam embankment under the jurisdiction of the DSOD. Embankment fills of height and capacity are under the jurisdiction of DSOD. Improvements to the dam structure may include the excavation of the existing embankment to expose firm, undisturbed and stable material across the entire width and length of the embankment and excavation of a keyway or cutoff trench that will extend to an underlying impervious material, or to a depth considered adequate to prevent piping or seepage through the embankment. The dam embankment will be constructed at a typical slope of about 3:1 (H:V) on the upstream side and 2:1 (H:V) on the downstream side.

Additional conceptual level investigations and evaluations will be required to verify the project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- SCE should be consulted to discuss the projects encroachment into the existing SCE easement.
- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Review and evaluate project operations during design storm events with SBCFCD.
- Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

See Figure 5-50 for evaluated alternative schematic.

#### **5.6.4.3.1 Potential Recharge Increase**

WEI estimated potential recharge using their model by simulating potential diversions to RP3 transferred from Jurupa and Wineville Basins as discussed in Section 5.5 of this report. Results of the simulation are as follows:

### Potential Increased Storm Water Recharge RP3 Basin

(values in acre-ft)

Alternative	Current Recharge	Potential Recharge	Potential Increase in Recharge
Improve Inlet	244	1,048	804
Improve Inlet and Basin Enlargement for Cells 1, 3 & 4	244	1,357	1,113

#### 5.6.4.3.2 Potential Cost

The estimated cost for construction of RP3 Basin is shown on Tables 5-14 and 5-15. A discussion of development of project cost items is provided in Section 5.6.11. The cost for excavation of the basin could be significantly reduced or offset if material excavated for the project can be used for other purposes such as in conjunction with another construction project that requires imported borrow material.

#### 5.6.4.3.3 Discussion

Preliminary evaluation of recharge efficiency of the project indicates that the project is most efficient in diversion of additional water for recharge from Declez Creek without import of water from other facilities when the basin is not enlarged. Improvements to the diversion structure and basin modifications without basin enlargement will capture about 804 acre-ft of water annually at an annualized cost of about \$383,000 or about \$476 an acre-foot. Improvements to the diversion structure and basin modifications with basin enlargement will capture about 1,113 acre-ft of water annually at an annualized cost of about \$1,465,000 or about \$1,316 an acre-foot.

## 5.6.5 Vulcan Pit

### 5.6.5.1 Existing Condition

Vulcan Pit is located in Fontana, CA adjacent to West Fontana Channel. According to WEI, the site had previously been used as a sand and gravel mine for over 60 years, as well as an asphalt batch plant for 30 years. The site is currently an open pit about 100 feet deep. Above ground structures associated with historic uses have been removed. WEI reported in their 2006 document, “Reconnaissance-Level Feasibility Assessment of Recharge at the Vulcan Pit,” that similar aggregate mining practices occurred in pits that later became the Upland and Montclair recharge basins. Vulcan Pit could potentially recharge at a similar rate to these existing facilities (0.5-2.0 ft/day).

### 5.6.5.2 Proposed Improvement Alternatives

- The preliminary alternative proposed to be evaluated is the installation of pneumatic

gates in Lower Fontana Channel and in a new diversion channel and spillway into Vulcan Pit which will allow controlled diversions of water into the basin at times when discharge is available. An outflow spillway will also be constructed from Vulcan Pit to West Fontana Channel. Vulcan Pit is proposed to function as a multi-purpose facility ideally capable of diverting low flows for recharge and conservation and peak storm flows greater than the capacity of West Fontana Channel downstream of the facility. (See Figure 5-51.)

- An additional consideration for the preliminary project evaluation includes utilizing the upper portion of storage as a regulatory reservoir and pumping water out of the basin during and between storm events to Banana or Hickory Basins wherefrom water will be pumped to northern recharge basins for recharge as part of the regional recharge distribution system described in Section 5.5.

**5.6.5.3 Evaluated Alternatives**

Formal evaluation of alternatives will be completed following consultation with SBCFCD.

**5.6.5.3.1 Potential Recharge Increase**

Similar to Lower San Sevaine, a new basin at Vulcan Pit was simulated by WEI according to three different assumed operating infiltration rates. Results are shown in the below table.

**Potential Increased Storm Water Recharge Vulcan Pit**

(values in acre-ft)

Alternative	Current Recharge	Potential Increase in Recharge
0.5 ft/day Infiltration	0	1,054
1.0 ft/day Infiltration	0	1,074
1.5 ft/day Infiltration	0	1,077

**5.6.5.3.2 Potential Cost**

Evaluation of cost for the project alternative will be completed following consultation with SBCFCD. Cost for reclamation of the existing mining pit into a recharge basin will not be included into the cost evaluation of the project as this is a component to the surface mining reclamation plan required to be completed by the current mining operator.

For preliminary conceptual project evaluation, the estimated cost to develop Vulcan Pit into a flood control and storm water recharge facility was obtained from the “Reconnaissance-Level Construction Cost Opinion Alternative 2 Flood Control Use with Maximum Storm Water Capture” summary and cost update worksheet prepared by WEI. The estimated cost for Watermaster’s portion of the project is \$2,446,000.



### **5.6.5.3.3 Discussion**

Preliminary evaluation of recharge efficiency of the project indicates that the project is efficient in diversion of additional water for recharge if the project is cost shared with SCBFCD with Watermaster responsible for only the components required for operation as a recharge facility. At an estimated annual cost of about \$159,000 the facility could capture for recharge an additional 1,054 to 1,077 acre-ft of water annually. This equates to an annualized cost of about \$150 per acre-foot.

## **5.6.6 Lower Cucamonga Basin**

### **5.6.6.1 Existing Condition**

Lower Cucamonga Basin is located on Cucamonga Creek within the City of Ontario. The facility is owned by SBCFCD and the basins are currently not utilized for groundwater recharge as a result of an evaluation by CBWCD which found that the basins have limited infiltration capacity. The basins are underlain by a thick clay layer. Lower Cucamonga consists of four cells, two on each of the east and west sides of Cucamonga Creek. The east and west cells are divided into north and south cells by a Southern California Edison (SCE) high-voltage power line easement. The southeastern cell of the existing Lower Cucamonga Basin is currently a mitigation site for the burrowing owl.

### **5.6.6.2 Proposed Improvement Alternatives**

- Construct a flow-through regulatory storage facility at the site of the existing Lower Cucamonga local storm water detention basins. This alternative is described in Section 5.6.6.3.
- Construct a flow-through regulatory storage basin at the site of the existing Lower Cucamonga local storm water detention basins and extending the new basin across the generally open ground to the east. This alternative was not pursued because the ground surface in this area is generally 10 to 30 feet above the proposed maximum storage elevation of the basin and would require a significant amount of excavation just to get to the point where excavation depth yields an increase in storage capacity. Additionally, this alternative would require an island be constructed around an SCE high voltage power tower and/or movement of the tower, both of which are unattractive options on a cost and project efficiency basis.
- Construct a flow-through regulatory storage basin at the site of the existing Lower Cucamonga local storm water detention basins and extending the new basin to include the existing Chris Basin and inflow from Lower Deer Creek. This alternative was not pursued because the water surface elevation for the proposed Lower Cucamonga Basin would inundate the Lower Deer Creek channel above its discharge into Chris Basin. This inundation would affect the hydraulics and discharge capacity of the Lower Deer Creek channel. In addition, it is presumed that the hydrology of Lower Deer Creek is similar to the hydrology of Cucamonga Creek and will most significantly

vary in amount of flow rather than timing. Cucamonga Creek will generate a significantly greater amount of discharge than Lower Deer Creek. It is anticipated that discharge of Cucamonga Creek will be ample to fill the proposed Lower Cucamonga Basin. An inlet to Lower Cucamonga Basin from Chris Basin is included in the evaluated alternative to enable diversion of water during low flow periods.

- Construct a flow-through regulatory storage basin within the same footprint area as the evaluated alternative with depth of excavation varying to yield storage capacities ranging from about 1,000 to 1,800 acre-ft. The number of basin storage capacity options for evaluation was reduced as it became apparent that the proposed project was less dependent on basin storage capacities than the diversion rate to recharge facilities and the capacity of recharge facilities. Final basin capacity will ultimately be optimized to balance storage, diversion rates, recharge facility capacities, project site constraints, and cost.
- A technical memorandum from CDM, who is a consultant to SBCFCD, dated February 24, 2010 to the MSAR Bacterial TMDL Taskforce regarding Dry Weather Runoff Controllability Assessment for Lower Deer Creek Sub-watershed (Chris Basin) describes a bacterial indicator concentration in Lower Deer Creek that exceed water quality objectives. The memorandum discusses two options for control of dry weather runoff from Chris Basin. 1) Construct a wetland within Chris Basin or 2) Collaborate with IEUA to develop a project to divert runoff from Lower Deer Creek into the proposed Lower Cucamonga Basin. Further discussion should be coordinated with SBCFCD and IEUA to develop a mutually beneficial project for resolution of IEUA's bacterial problems during dry weather periods that could also be utilized for diversion of Lower Deer Creek flows during wet weather periods for recharge.

### **5.6.6.3 Evaluated Alternatives**

The proposed Lower Cucamonga Basin is a flow-through regulatory storage facility to be constructed at the site of the existing Lower Cucamonga local storm water detention basins. The proposed Lower Cucamonga Basin project will be situated over the footprint of the existing basins, bifurcating the existing Cucamonga Creek channel above and below the basin. Cucamonga Creek will discharge directly into Lower Cucamonga Basin through a new inlet channel and energy dissipation structure. Water in excess of the storage capacity of Lower Cucamonga Basin will return to Cucamonga Creek through a new concrete lined spillway structure that discharges to the channel below the basin. Details of the proposed project are shown in Figures 5-52 and 5-53.

The basin will require construction of an earth embankment structure along the southern portion of the basin which will be constructed of soil and rock materials obtained from excavations within the project area. General construction protocol for a dam embankment requires sub-excavation of the ground surface across the entire width and length of the embankment to expose firm, undisturbed and stable material. Within the embankment foundation area a keyway or cutoff trench will be excavated extending to an underlying impervious material or to a depth considered adequate to prevent piping or seepage through

the embankment. Embankment fills of sufficient height and capacity are under the jurisdiction of DSOD. The dam embankment is proposed to be constructed, at a typical slope of about 3:1 (H:V) on the upstream side and 2:1 (H:V) on the downstream side.

Lower Cucamonga Basin has been evaluated at capacity of 1,200 acre-ft. Previous analyses of basins with larger capacities yielded that the amount of water obtainable for re-diversion to other recharge facilities is less dependent on basin storage capacity than rate of pumping and recharge capacity. The basin configuration and grading plan shown on Figure 5-52 is for conceptual evaluation purposes only for general project layout and preliminary earthwork quantity determination. Subsequent project evaluations will include design of basin features including access ramps, benches on slopes, and basin bottom grading features.

Water surface elevation, discharge spillway width, and dam embankment height were determined through a preliminary hydraulic analysis of water surface elevations at a flow rate of 20,000 cfs which corresponds to a freeboard allowance of about 7.5 feet within the channel. This flow rate is larger than the largest instantaneous flow rate measured in Cucamonga Creek in 40 years of record.

An inlet conduit between the proposed Lower Cucamonga Basin and Chris Basin will be constructed to enable diversion of water from Chris Basin and Deer Creek into Lower Cucamonga Basin. The existing inlet from Chris Basin to the southeastern cell of the existing Lower Cucamonga Basin will be removed and replaced.

Storm water accruing to Lower Cucamonga Basin is proposed to be re-diverted to Wineville Basin and thence to other recharge facilities within Chino Basin for recharge. A pump station will be constructed at Lower Cucamonga Basin with a conveyance pipeline extending from Lower Cucamonga Basin to Wineville Basin. This system is described in Section 5.5.

Additional conceptual level investigations and evaluations will be required to verify the project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- SCE should be consulted to discuss the project's encroachment into the existing SCE easement and resulting modification to its operations.
- Impact to and relocation of the burrowing owl mitigation site located in the southeastern cell of the existing Lower Cucamonga Basin will need to be evaluated.
- Collaborate with IEUA and SBCFCD on development of a dry weather diversion facility on Deer Creek discharging into the proposed Lower Cucamonga Basin that could also be utilized during wet weather to enhance diversion opportunities from Deer Creek.
- Basin capacity and configuration shall be reviewed for optimization of storage, diversion and cost.
- Localized condition and net reflection of regional groundwater system needs to be reviewed and analyzed to determine its impact to the project.

- The existing drain inlet discharging into the northwestern cell of the existing Lower Cucamonga Basin will need to be evaluated.
- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Review and evaluate the project operations during design storm events with SBCFCD.
- Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

See Figure 5-54 for evaluated alternative schematic.

#### 5.6.6.3.1 Potential Recharge Increase

A potential increase in groundwater recharge was estimated by WEI using their hydrologic simulation model. Lower Cucamonga Basin, however, is not expected to be a recharge basin because of limited infiltration capacity of underlying soils. Discharge from Cucamonga Creek will be diverted and transferred elsewhere to be recharged. Potential diversions at Lower Cucamonga Basin are shown in the below table.

#### Potential Increased Storm Water Recharge Lower Cucamonga Basin

(values in acre-ft)

Alternative	Current Recharge	Potential Recharge	Potential Diversion Export
10 cfs Diversion	0	0	4,020
20 cfs Diversion	0	0	5,551
30 cfs Diversion	0	0	6,483
40 cfs Diversion	0	0	7,160

#### 5.6.6.3.2 Potential Cost

The estimated cost for construction of the Lower Cucamonga Basin is shown on the below table. A discussion of development of the project cost items is provided in Section 5.6.11. Cost for reservoir excavation can be significantly reduced or offset if material excavated for the project can be used for other purposes such as in conjunction with another construction project that requires imported borrow material.

**Cost Estimate for Conceptual Project Evaluation of  
Lower Cucamonga Basin**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$446,000
2 <u>Compacted Embankment</u>				
Foundation Excavation	214,000	Cu. Yds.	\$3.00	\$642,000
Compacted Embankment	409,000	Cu. Yds.	\$6.00	\$2,454,000
3 <u>Reservoir Excavation</u>				
Excavate & Haul Offsite	709,800	Cu. Yds.	\$12.50	\$8,872,500
4 <u>Existing Channel</u>				
Channel Demolition	17,300	Cu. Yds.	\$24.00	\$415,200
5 <u>Basin Discharge Structure</u>				
Concrete Spillway Structure	1,400	Cu. Yds.	\$800	\$1,120,000
6 <u>Basin Inlet Structure</u>				
Concrete Inlet Spillway Structure	1,300	Cu. Yds.	\$700	\$910,000
7 <u>Basin Outlet to Cucamonga Creek</u>				
60" Dia. RCP Outlet Conduit	400	Lin. Ft.	\$600	\$240,000
Gates and Controls	1	Job	\$50,000	\$50,000
8 <u>Chris Basin Inlet Structure</u>				
60" Dia. RCP Outlet Conduit	200	Lin. Ft.	\$600	\$120,000
Gates and Controls	1	Job	\$50,000	\$50,000
<b>Subtotal Direct Construction</b>				<b>\$15,319,700</b>
<b>Contingency @ 25%</b>				<b>\$3,829,900</b>
<b>Total Construction</b>				<b>\$19,149,600</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				\$1,915,000
<b>Total Engineering and Administration</b>				<b>\$1,915,000</b>
<b>Total Estimated Cost</b>				<b>\$21,064,600</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$21,060,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$1,370,300</b>

### 5.6.6.3.3 Discussion

Preliminary evaluation of recharge efficiency of the project indicates that efficiency is limited by the capacity of the recharge facilities. More water is available for diversion than there is a place to put it. Additional destination facilities should be explored. Assuming a destination facility is available for all storm water estimated to be available at the rates shown, between 5,551 and 7,160 acre-ft can be annually captured at an annualized cost of \$1,370,000. This equates to a cost between \$191 and \$247 per acre-foot.

The development of Lower Cucamonga Basin is estimated to be about \$21-million and is about 10-percent of the total cost for the entire RMP project; however it generates between



25 and 45-percent of new water to be recharged.

## **5.6.7 Lower San Sevaine Basin**

### **5.6.7.1 Existing Condition**

The proposed Lower San Sevaine Basin is a new facility that would be located in a vacant area downstream of the San Sevaine flood control basins and Victoria Basin, adjacent to Interstate 15 in Etiwanda, CA. The proposed basin was previously referred to in discussions with Watermaster as the Lower Victoria Basin.

### **5.6.7.2 Proposed Improvement Alternatives**

Construct a flow-through recharge basin on Etiwanda and San Sevaine Creek. This alternative is described in Section 5.6.7.3.

Evaluate the potential for enlargement of existing recharge storage basins upstream of the proposed Lower San Sevaine Basin both on the Etiwanda and San Sevaine stream system.

### **5.6.7.3 Evaluated Alternatives**

Lower San Sevaine Basin is a proposed new flow-through basin located on San Sevaine and Etiwanda Creek channels. The basin is proposed to collect flows occurring in San Sevaine and Etiwanda Creeks for recharge. Flows in excess of the basin storage capacity will return to the San Sevaine and Etiwanda channels.

The basin is designed for a maximum reservoir depth of 25 feet and will store about 605 acre-ft of water. The dam embankment crest elevation and freeboard allowance was determined pursuant to preliminary hydraulic analyses performed to estimate surcharge storage capacity to pass the design storm event through the reservoir and spillway structure and into the San Sevaine and Etiwanda Creek channels below the proposed basin. Although inflow into the basin from the San Sevaine and Etiwanda Creek channels will vary in rate and proportion due to the operations of upstream basins, discharge from the is proposed to occur by proportion to design capacity of the channels, (i.e. Etiwanda channel with receive about 63 percent of all discharge and San Sevaine channel will receive the balance, about 37 percent). Low-level outlet conduits will be constructed to release water into the channels below the basin. Details of the proposed project are shown in Figures 5-55 and 5-56.

Earth embankment structures are anticipated to be constructed of soil and rock materials obtained from excavations within the project area. General construction protocol for a dam embankment requires sub-excavation of the ground surface across the entire width and length of the embankment to expose firm, undisturbed and stable material. Within the embankment foundation area a keyway or cutoff trench will be excavated extending to an underlying impervious material or to a depth considered adequate to prevent piping or seepage through the embankment. The dam embankment will be constructed, at a typical slope of about 3:1

(H:V) on the upstream side and 2:1 (H:V) on the downstream side. Embankment fills of sufficient height will be under the jurisdiction of the DSOD.

Lower San Sevaine Basin will also receive water diverted at other diversion facilities, such as Lower Cucamonga and Wineville Basins, for recharge as part of the regional recharge distribution system. This system is described in Section 5.5. See Figure 5-57 for evaluated alternative schematic.

Additional conceptual level investigations and evaluations will be required to verify project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Evaluate potential for having the basin excavated by a surface mining operator.
- Review and evaluate project operations during design storm events with SBCFCD.

Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

#### 5.6.7.3.1 Potential Recharge Increase

Lower San Sevaine was simulated by WEI according to three different assumed operating infiltration rates. Results are shown in the below table.

##### Potential Increased Storm Water Recharge Lower San Sevaine Basin

(values in acre-ft)

Alternative	Current Recharge	Potential Increase in Recharge
0.25 ft/day Infiltration	0	1,157
0.5 ft/day Infiltration	0	1,429
1.0 ft/day Infiltration	0	1,679

#### 5.6.7.3.2 Potential Costs

The estimated cost for construction of Lower San Sevaine Basin is shown on the below table. A discussion of the development of project cost items is provided in Section 5.6.11. Cost can be significantly reduced or offset if material excavated for the project can be used for other purposes such as in conjunction with another construction project that requires imported borrow material. Another consideration to reduce project costs is to lease out land to a mining operator who would construct the basin concurrent with their mining operations.

**Cost Estimate for Conceptual Project Evaluation of  
Lower San Sevaine Basin**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$643,000
2 <u>Compacted Embankment</u>				
Foundation Excavation	30,000	Cu. Yds.	\$3.00	\$90,000
Compacted Embankment	46,000	Cu. Yds.	\$6.00	\$276,000
3 <u>Reservoir Excavation</u>				
Excavate & Haul Offsite	1,542,000	Cu. Yds.	\$12.50	\$19,275,000
4 <u>Existing Channel Demolition</u>				
Channel Demolition	5,800	Cu. Yds.	\$24.00	\$139,200
5 <u>Basin Outlet to Etiwanda Channel</u>				
60" Dia. RCP Outlet Conduit	300	Lin. Ft.	\$600	\$180,000
Gates and Controls	1	Job	\$50,000	\$50,000
6 <u>Basin Outlet to San Sevaine Channel</u>				
60" Dia. RCP Outlet Conduit	300	Lin. Ft.	\$600	\$180,000
Gates and Controls	1	Job	\$50,000	\$50,000
6 <u>Basin Spillway/Discharge Structure</u>				
Concrete Structure	650	Cu. Yds.	\$1,200	\$780,000
7 <u>Basin Inlet Structure</u>				
Concrete Structure	350	Cu. Yds.	\$1,200	\$420,000
<b>Subtotal Direct Construction</b>				<b>\$22,083,200</b>
<b>Contingency @ 25%</b>				<b>\$5,520,800</b>
<b>Total Construction</b>				<b>\$27,604,000</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				<u>\$2,760,000</u>
<b>Total Engineering and Administration</b>				<b>\$2,760,000</b>
<b>Total Estimated Cost</b>				<b>\$30,364,000</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$30,360,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$1,975,200</b>

### 5.6.7.3.3 Discussion

Preliminary evaluation of recharge efficiency of the project indicates that the project is not efficient in diversion of additional water for recharge. At an estimated annual cost of about \$1,975,200 the facility could capture for recharge an additional 1,157 to 1,679 acre-ft of water annually. This equates to an annualized cost between \$1,176 and \$1,707 per acre-foot. If the

cost of constructing the basin was reduced by leasing the land to a mining operator as discussed above to about \$1,500,000 (95-percent cost reduction) and with an annualized cost of about \$100,000, the cost for recharge the project would be worth pursuing.

## **5.6.8 Declez Basin**

### **5.6.8.1 Existing Condition**

Declez Basin is located downstream of RP3 on Declez Channel. Declez is currently operated as a flow-through multi-purpose basin. The basin is divided into 3 cells with the upper cell utilized as a habitat area. Habitat use in the upper cell currently allows for the sediment and debris flowing into the basin to be filtered to reduce the maintenance of the subsequent cells.

### **5.6.8.2 Proposed Improvement Alternatives**

- Reconstruct existing embankment and install a gate on the existing low level outlet. This alternative is described in Section 5.6.8.3.
- Repair and reconstruct internal berms as required to prevent frequent wash-out and repair.

### **5.6.8.3 Evaluated Alternatives**

Declez Basin is proposed to be improved to a storage reservoir by installation of a gate on the existing low-level conduit and reconstruction of the embankment to function satisfactorily as a dam. A new spillway structure will be constructed at a lower elevation to maintain the storage level at a point where it will not affect the inflow to the basin from Declez Channel upstream. Existing berms which separate the existing basin into cells will be removed. Details of the proposed project are shown in Figure 5-58.

The existing earth embankment structure will be evaluated and reconstructed as necessary to meet requirements of a dam embankment under the jurisdiction of the DSOD. Embankment fills of sufficient height and capacity are under the jurisdiction of DSOD. Improvements to the dam structure may include the excavation of the existing embankment to expose firm, undisturbed and stable material across the entire width and length of the embankment and the excavation of a keyway or cutoff trench that will extend to an underlying impervious material, or to a depth considered adequate to prevent piping or seepage through the embankment. The dam embankment will be constructed at a typical slope of about 3:1 (H:V) on the upstream side and 2:1 (H:V) on the downstream side.

Additional conceptual level investigations and evaluations will be required to verify the project design and determine if or how the project will be required to be modified to address issues that arise. The following is a preliminary list of items that are known at this time that will require further review.

- Hydraulic analysis of the channel and reservoir system will be completed pursuant to

receipt of channel design flow information from SBCFCD.

- Evaluate operation and maintenance procedures to determine facility requirements for periodic dewatering and cleaning of the basin.
- Review and evaluate project operations during design storm events with SBCFCD.
- Review and evaluate project operations and maintenance waste discharge requirements of storm water discharges from MS4 for compliance with Tentative Order No. R8-2009-0036 from the California Regional Water Quality Control Board, Santa Ana Region, NPDES Permit and Waste Discharge Requirements for SBCFCD, et al., Area-Wide Urban Storm Water Runoff Management Program.

See Figure 5-59 below for evaluated alternative schematic.

#### 5.6.8.3.1 Potential Recharge Increase

Similar to RP3, WEI estimated potential recharge using their model by simulating potential diversions to Declez transferred from Jurupa and Wineville Basins as discussed in Section 5.5 of this report. Results of the simulation are as follows:

#### Potential Increased Storm Water Recharge Declez Basin

(values in acre-ft)

Alternative	Current Recharge	Potential Recharge	Potential Increase in Recharge
Enlarged & with Improved Inlet for RP3 Basin	789	827	38
Enlarged & with Improved Inlet and Enlargement of Cells 1, 3 & 4 for RP3 Basin	789	820	31

#### 5.6.8.3.2 Potential Cost

The estimated cost for construction of Declez Basin is shown in the below table. A discussion of the development of project cost items is provided in Section 5.6.11.

**Cost Estimate for Conceptual Project Evaluation of Declez Basin**

Description	Quantity	Unit	Unit Cost	Total Cost
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$79,000
2 <u>Compacted Embankment</u>				
Foundation Excavation	70,600	Cu. Yds.	\$3.00	\$211,800
Compacted Embankment	70,600	Cu. Yds.	\$6.00	\$423,600
Interior Berm Excavation	40,000	Cu. Yds.	\$3.00	\$120,000
<u>Interior Berm Compacted Fill</u>	40,000	Cu. Yds.	\$6.00	\$240,000
3 <u>Existing Spillway Demolition</u>				
Channel Demolition	1,000	Cu. Yds.	\$18.17	\$18,170
4 <u>Basin Spillway/Discharge Structure</u>				
Basin Discharge Concrete Structure	1,000	Cu. Yds.	\$1,200	\$1,200,000
Berm Overflow Concrete Structure	300	Cu. Yds.	\$1,200	\$360,000
5 <u>Outlet Gate</u>				
Gates and Controls	1	Job	\$50,000	\$50,000
<b>Subtotal Direct Construction</b>				<b>\$2,702,600</b>
<b>Contingency @ 25%</b>				<b>\$675,700</b>
<b>Total Construction</b>				<b>\$3,378,300</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				\$338,000
<b>Total Engineering and Administration</b>				<b>\$338,000</b>
<b>Total Estimated Cost</b>				<b>\$3,716,300</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$3,720,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$241,800</b>

**5.6.8.3.3 Discussion**

Preliminary evaluation of recharge efficiency of the project indicates that the project is not efficient in diversion of additional water for recharge. At an estimated annual cost of about \$242,000 the facility could capture for recharge an additional 31 to 38 acre-ft of water annually. This equates to an annualized cost between \$6,370 and \$7,800 per acre-foot. In addition, as the recharge facilities are developed upstream of the Declez Basin, less water is available for recharge at Declez Basin which results in a diminishing return on the improvements.

### **5.6.9 Turner Basin Expansion/Gausti Park**

The Turner Basin Gausti Park project includes the Turner 4 basin and the Gausti Park located east and adjacent to the Turner 4 basin. Modifications and enhancements to the existing Turner Basins and Gausti Park have been conceptually developed by IEUA and other stakeholders. The plan is a mixed use project proposed to serve recreational, flood control and groundwater recharge interests. Modifications of the existing facilities include moving the inlet from Deer Creek upstream to enable diversion at a higher elevation and subsequently increasing the storage capacity of the existing basins and construction of additional basins for storage and recharge. Preliminary evaluation of the available water supply by WEI indicates that if the project could be built as shown on the plan, recharge to Chino Basin could be increased by about 1,300 acre-ft/yr.

The plan presented by IEUA is a graphical representation of ideas developed in discussions by IEUA with local agencies and has not undergone preliminary engineering design. A conceptual level project design and evaluation would need to be completed to verify project hydraulics, evaluate proposed basin excavations and estimate material quantities. A preliminary cost estimate for construction of the proposed facility could then be developed based on quantities of materials and work required to complete the project. This project is actively being pursued by the IEUA and other stakeholders and will likely be implemented outside of the RMPU.

### **5.6.10 Pumping and Conveyance Systems**

#### **5.6.10.1 Existing Condition**

Existing conveyance systems for the distribution of water for recharge are limited to a single pipeline and pump station between Jurupa and RP3 basins. The pipeline is currently only utilized for the transfer of recycled water to RP3 Basin Cell 1.

#### **5.6.10.2 Proposed Improvement Alternatives**

The pumping and distribution system was prepared utilizing the maximum recharge and diversion amounts the recharge basins could receive as simulated by WEI. The distribution system should be reviewed as the system is optimized to maximize recharge.

#### **5.6.10.3 Evaluated Alternatives**

The pumping and conveyance system was evaluated to estimate the cost for moving water from one facility to another utilizing the most direct and assessable route as determined by review of available aerial photography. Pipeline alignments were prepared to determine distance to the intended destination and do not indicate currently known or intended alignments. To the extent possible, alignments are shown to follow Southern California

Edison easements, existing roads, and flood control channels.

#### 5.6.10.4 Potential Cost

The estimated cost for construction of the elements of the recharge pumping and conveyance system are shown on the below tables. A discussion of the development of project cost items is provided in Section 5.6.11.

**Cost Estimate for Conceptual Conveyance System**

Segment	Flowrate (cfs)	Pipe		Pipe Cost (\$/LF)	Pipeline Cost	Contingency & Engineering	Total Cost Pipeline
		Diameter (in)	Length (ft)				
Lower Cucamonga to Wineville	20	24	26,900	\$294	\$8,943,300	\$3,130,100	\$12,073,400
Wineville to Jurupa	20	24	10,400	\$294	\$3,315,100	\$1,160,300	\$4,475,400
Wineville to Etiwanda	40	36	12,000	\$383	\$5,196,800	\$1,818,900	\$7,015,600
Etiwanda to Hickory West	40	36	11,000	\$383	\$4,947,100	\$1,731,500	\$6,678,500
Hickory West to Victoria	40	36	18,700	\$383	\$7,163,200	\$2,507,100	\$9,670,300
Hickory West to Banana	6	18	3,300	\$249	\$821,700		
Victoria to Lower Day	8	18	12,000	\$249	\$3,225,000		
Victoria to Etiwanda Debris	59	42	2,500	\$428	\$1,445,300		
	7	18	700	\$249	\$394,400		
	34	30	3,700	\$338	\$1,252,000		
	51	36	1,600	\$383	\$946,300		
Victoria to San Sevaine #1 (Upper)	59	42	2,500	\$428	\$1,445,300	\$6,081,500	\$23,457,000
	27	30	4,000	\$338	\$1,353,500		
	34	30	3,700	\$338	\$1,252,000		
Victoria to San Sevaine #5 (Lower)	51	36	1,600	\$383	\$946,300		
	59	42	2,500	\$428	\$1,445,300		
	17	24	1,800	\$294	\$528,600		
Victoria to San Sevaine #5 (Lower)	51	36	1,600	\$338	\$874,800		
	59	42	2,500	\$428	\$1,445,300		
<b>Total</b>			<b>123,000</b>		<b>\$46,941,300</b>	<b>\$16,429,400</b>	<b>\$63,370,200</b>

Note: Pipeline Contingency and Engineering are estimated 25% and 10% of total construction cost, respectively.



**Cost Estimate for Conceptual Pumping System**

Segment	Hp Req'd	Pump Cost	Structure Cost	Regulatory Tank, 20 MG	Pump Station Cost	Contingency & Engineering	Total Cost Pump Station
Lower Cucamonga to Wineville	794	\$240,000	\$3,200,000	-	\$3,440,000	\$1,204,000	\$4,644,000
Wineville to Jurupa	305	\$240,000	\$3,200,000	-	\$3,440,000	\$1,204,000	\$4,644,000
Wineville to Etiwanda	1,147	\$418,000	\$3,200,000	-	\$3,618,000	\$1,266,300	\$4,884,300
Etiwanda to Hickory West	692	\$418,000	\$3,200,000	\$5,700,000	\$9,287,000	\$3,250,450	\$12,537,450
Hickory West to Victoria							
Jurupa to RP3	1,382	\$418,000	\$3,200,000	\$5,700,000	\$9,287,000	\$3,250,450	\$12,537,450
Hickory West to Banana	-	\$209,000					
Victoria to Lower Day	179	\$120,000					
Victoria to Etiwanda			\$0	-	\$209,000	\$73,150	\$282,150
Debris	180	\$209,000					
Victoria to San Sevaine #1	329	\$120,000					
Victoria to San Sevaine #5	918	\$298,000					
<b>Total</b>		<b>\$2,690,000</b>	<b>\$20,800,000</b>	<b>\$11,400,000</b>	<b>\$34,828,000</b>	<b>\$12,189,800</b>	<b>\$47,017,800</b>

**Note:**

Pump Station Contingency and Engineering are estimated 25% and 10% of total construction cost, respectively.

**5.6.10.5 Discussion**

Pumping and conveyance elements of the recharge distribution system are integral to the concept of capturing storm water in areas where it is plentiful and moving it to areas where it can be recharged to the Chino Basin. This system is the primary component to the Recharge Master Plan Update project.

**5.6.11 Project Evaluation****5.6.11.1 Cost Evaluations**

Project cost estimates were developed on a unit cost or per item basis where applicable. The following described components of, or sources to, cost values used for project evaluations.

**Mobilization:** Mobilizations were estimated at 3-percent of the total of all other direct construction cost items. For projects that require a large number of equipment move-in with a relatively small scope of work, mobilization cost may exceed 3-percent. In some cases this overstates expected cost for a contractor to mobilize, and in other cases it underestimates it. Mobilization is generally expected to cover items such as equipment move-in and move-out, preparation and installation of SWPPP plans and erosion control features, project schedules, traffic control, office facilities and other relatively minor components of the project.

**Compacted Embankment:** The cost for excavation and construction of soil and rock

materials which comprise the structural fill of dam embankment structures were estimated from review of unit cost bids received from previous dam construction projects and by discussion with local contractors. As the scope of proposed projects are preliminary at best and limits of dam foundation and cutoff trench excavation and sources of borrow material suitable for construction of a dam embankment are unknown, unit costs will need to be reviewed and reevaluated.

**Reservoir Basin Excavation:** The unit cost for reservoir basin excavation was developed by building the cost from equipment production and hourly cost estimates. Equipment production and cost estimates were obtained from discussions with contractors familiar with similar work in the project area. Costs include time and equipment to load and off-haul the material to an unknown location located within a two hour round trip radius of the project site. Grading of the reservoir basin is assumed to occur during excavation. Costs do not include purchase or acquisition of the disposal site or work performed at the disposal site. The cost for basin excavation can potentially be partially offset or reduced by the sale of excavated material to an aggregate supplier or the lease of the project site to an aggregate supplier who would effectively construct the basin in course of its operations.

**Concrete Channel Demolition:** The unit cost for demolition was developed by building the cost from equipment production and hourly cost estimates. Equipment production and cost estimates were obtained from discussions with contractors familiar with similar work in the project area. Costs include time and equipment to break-up existing concrete and transport it to a temporary stockpile location on-site. Concrete rubble material would then be loaded for off-haul to an unknown location located within a one hour round trip radius of the project site. Cost can be reduced by establishing an on-site crushing plant to develop recycled aggregate road base for sale to other projects or use on the project site.

**Concrete Structures:** The unit cost for concrete structures such as basin inlet or outlet spillways were estimated on a per cubic yard unit cost basis. Unit costs were obtained from discussions with contractors familiar with similar work. Unit costs were estimated separately for concrete placed on a base slab and concrete placed on wall-type structures.

**Basin Inlet/Outlet Conduits:** The unit cost for basin inlet/outlet conduits and gate controls was estimated by review and adjustment of unit cost bids received for similar inlet/outlet conduits and by discussion with local contractors.

**Pneumatic Gates:** The cost for construction and installation of pneumatic gates was estimated from review of project costs for previous pneumatic gate projects. Material costs for gate components were obtained from the gate manufacturer.

**Pipeline:** The unit cost for pipelines was developed from review and adjustment of pipeline installation bids received for the Chino Basin Facilities Improvement Project – Bid Package No. 3 which involved the construction of about 11,000 feet of 36-inch CML&C steel pipe between the Jurupa and RP3 basins. Review of bid results indicated that about 70 percent of the cost of the project was for construction of the pipeline and required pipeline appurtenances; the remaining 30% was for miscellaneous required elements such as traffic

control and road repair. It is assumed that miscellaneous elements would not vary substantially for projects that varied by pipeline diameters. The total project unit cost for the Jurupa pipeline was about \$290 per linear foot. This corresponds to a cost for the pipeline portion of this project of about \$200 per foot and other costs of about \$90 per foot. Unit costs for pipelines of diameters greater or lesser than 36-inches in diameter were determined on a per inch-diameter basis. The miscellaneous portion of the unit cost was applied without adjustment for pipe diameter differences. All unit costs were updated to current cost values by the composite trend index of the Bureau of Reclamation Construction Cost Trend for July of 2003 and 2009 which yields cost increase of about 32 percent. Portions of proposed pipelines will require horizontal directional drilling or micro-tunneling to pass under highways and canals. Unit costs were obtained from a horizontal drilling contractor and are additive to the cost of the general pipeline unit cost.

**Pump Station:** The cost for pump stations was estimated from review and adjustment of pump station construction bids received for the Chino Basin Facilities Improvement Project – Bid Package No. 4 which involved construction of the Jurupa Basin Pump Station. The pump station construction cost was updated to current cost values by the composite trend index of the Bureau of Reclamation Construction Cost Trend for July of 2003 and 2009 which yields an increase of about 32 percent. The pump station was designed to accommodate diversion of up to 40 cfs from the Jurupa Basin, however only one of the two ultimate pumps was installed. Costs for pumps ranging from 10 cfs to 40 cfs were obtained from a pump supplier and were used to determine an estimate for construction of the pump station structure (building, wet well, intake conduit, control equipment, etc.), separate from the cost of the pumps. For purposes of this cost evaluation study, it is assumed that the pump station structure cost would be essentially the same for each project. The total pump station cost includes the cost for the pump station structure and cost of pumps required to move the water at the desired rate.

**Regulatory Storage Tanks:** The cost for regulatory storage tanks were obtained from discussions with a tank supplier. The cost assumes that adequate foundation support is readily available and no significant special factors will affect design of the structures. Tanks may be able to be reduced in capacity or eliminated if it is possible to construct a regulatory reservoir, either by excavation or by balanced cut/fill.

**Box Culvert Conduit:** The unit cost for construction of box culvert conduits was estimated from information provided by and discussions with a box culvert supplier and contractor familiar with construction and installation of RCB conduits.

**Other:** Miscellaneous unit or per item costs were obtained from review and adjustment of bid received for similar items constructed for the Chino Basin Facilities Improvement Projects and from the County of Los Angeles, Dept. of Public Works, Rio Hondo Coastal Basin Spreading Grounds and Termino Avenue Drain Projects.

## **5.7 Conclusions and Recommendations**

The Recharge Distribution System is estimated to capture and recharge up to 16,000 acre-

ft/yr of additional storm water into the Chino Basin at a capital cost of about \$216 million, or \$800 per acre-foot annualized for 30-years at an interest rate of 5%. When including estimates for energy and operation and maintenance, the annualized cost is about \$1,200 per acre-foot.

The estimated cost for the regional Recharge Distribution System and the additional yield of storm water recharge acquired demonstrate that the concept of improving the diversion and storage capacity of existing recharge basins moving the water to existing and proposed basins for recharge could be cost effective compared to the cost of imported water and warrants further evaluation.

The proposed Recharge Distribution System, if developed in total, includes construction of two new diversion and recharge basins, six new major pump station facilities, over 20 miles of conveyance pipeline, excavation of over 4-million cubic yards of material, installation of pneumatic gates in the spillway or flood control channels of four existing basins, and significant modifications to the inlet facilities of two existing basins.

**Table 5-1**  
Existing Regional Conservation Basin Parameters<sup>(1)</sup>

A	B	C	D	E	F	G	H	I			J			K			L			M			N			O			P			Q			R			S			T			U			V			W	X	Y
								Maximum	Conservation	Storage <sup>(2)</sup>	Rule Curves Apr 16 - Oct 15	Rule Curves Oct 16 - Apr 15	Annual Recharge Estimates <sup>(3)</sup>	Maximum	Maximum	Storage	Rule Curves Apr 16 - Oct 15	Rule Curves Oct 16 - Apr 15	Annual Recharge Estimates <sup>(3)</sup>	Storm	Supplemental	Recycled	Control Element	Operator	Control Element Settings	First Storm	Non-Significant Storm	Significant Storm																								
Basins	Owner	Bottom Elevation (ft MSL)	Spillway Elevation (ft MSL)	Maximum Intake Capacity from Channel (cfs)	Storage Volume at Spillway Elevation (af)	Typical Percolation Rate (ft/day)	Recharge Capacity (cfs)	Maximum Operation Depth (ft)	Maximum Operating Elevation (ft MSL)	Storage Volume at Maximum Operating Depth (af)	Elevation (ft MSL)	Storage (af)	Percent Full	Elevation (ft MSL)	Storage (af)	Percent Full	Storm Water (af/yr)	Supplemental Water (af/yr)	Recycled Water (af/yr)	Control Element	Operator	Control Element Settings	First Storm	Non-Significant Storm	Significant Storm																											
<b>San Antonio Channel - CB59</b>																																																				
College Heights West (MZ1)	CBWCD	1,224.0	1,243.0	162.3	87.8	2.5	15	10.0	1,234.0	39.4	NA	NA	NA	NA	NA	NA	50	0	0	San Antonio Channel Rubber Dam	Rubber dam operated from adjacent control building or SCADA	Deflated	Deflated	Deflated																												
College Heights East (MZ1)	CBWCD	1,224.0	1,243.0	161.4	83.0	2.5		10.0	1,234.0	33.4	NA	NA	NA	NA	NA	NA				NA	San Antonio Channel to College Heights West	Automated Sluice Gate	Closed	Closed	Closed <sup>(5)</sup>																											
Montclair 1 (MZ1)	CBWCD	1,099.0	1,127.2	100.0	117.0	1.5	40	28.0	1,127.0	117.0	1,127.2	134.0	100%	1,127.2	134.0	100%	340	2,331	668	San Antonio Channel to Montclair 1	Automated Sluice Gate	Closed	Open	Open																												
Montclair 2 (MZ1)	CBWCD	1,070.0	1,102.0	-	308.0	1.5		28.0	1,098.0	258.0 <sup>(4)</sup>	1,098.0	258.0	100%	1,087.0	132.0	51%	370	3,682	1,013	Montclair 1 to Montclair 2	Manual Sluice Gate	Open	Open	Open																												
Montclair 3 (MZ1)	CBWCD	1,034.0	1,054.0	-	33.0	1.5		20.0	1,054.0	33.0	1,054.0	33.0	100%	1,034.0	0.0	0%	160	1,317	369	Montclair 2 to Montclair 3	Manual Sluice Gate	Open	Open	Open																												
Montclair 4 (MZ1)	CBWCD	1,010.0	1,037.0	-	111.0	1.5		27.0	1,037.0	111.0	1,037.0	111.0	100%	1,010.0	0.0	0%	250	1,697	487	Montclair 3 to Montclair 4	Passive Overflow	NA	NA	NA																												
Brooks (MZ1) <sup>(5)</sup>	CBWCD	860.0	923.0	112.1	200.0	1.5	5	29.0	875/893 <sup>(6)</sup>	185.0 <sup>(6)</sup>	888.0	180.0	90%	875.0	65.0	13%	1,710	3,724	1,359	San Antonio Channel to Brooks Basin	Automated Sluice Gate	Closed	Open	Varies <sup>(7)</sup>																												
<b>West Cucamonga Channel</b>																																																				
Ely 1 (MZ2)	SBCFCD	823.0	835.0	NA	85.0	0.5	5	5.0	828.0	22.0	828.0	22.0	26%	828.0	22.0	26%	1,570	3,167	1,184	West Cucamonga Channel to Ely 1 Basin	Manual Sluice Gate	Open	Open	Open																												
Ely 2 (MZ2)	SBCFCD	825.0	835.0	-	96.0	0.5		3.0	828.0	25.0	828.0	25.0	26%	828.0	25.0	26%				Ely 1 Basin to Ely 2 Basin	Manual Sluice Gate	Open	Open	Open																												
Ely 3 Cells 1 (MZ2) <sup>(8)</sup>	CBWCD	820.0	835.0	-	136.0	0.5		3.8	823.8	12.0	823.8	11.8	100%	823.8	11.8	100%				Ely 2 Basin to Ely 3 Basin to Cell 1	Manual Sluice Gate	Open	Open	Open																												
Ely 3 Cells 2 (MZ2) <sup>(8)</sup>	CBWCD	820.0	835.0	-		3.8		823.8	9.0	823.8	8.7	100%	823.8	8.7	100%	Ely 2 Basin to Ely 3 Basin to Cell 2				Manual Sluice Gate	Open	Open	Open																													
Ely 3 Cells 3 (MZ2) <sup>(8)</sup>	CBWCD	820.0	835.0	-		3.8		823.8	9.0	823.8	9.1	100%	823.8	9.1	100%	Ely 2 Basin to Ely 3 Basin to Cell 3				Manual Sluice Gate	Open	Open	Open																													
Ely 3 to West Cucamonga Channel	Automated Sluice Gate	Closed	Closed	Open																																																
<b>Riverside Drive Drain</b>																																																				
Grove (MZ2)	CBWCD	742.5	767.3	NA	305.5	0.25	NA	5.0	747.5	52.0	742.9	0.0	0%	747.5	52.0	100%	NA	NA	NA	Grove Basin to Grove Ave.	Automated Sluice Gate	Closed	Closed	Open																												
<b>Cucamonga/Deer Cr Channels - CB11</b>																																																				
Turner 1 (MZ2)	CBWCD	965.0	1,000.0	255.0 182.7	266.0	0.5	6	13.0	978.0	56.0	981.0	80.0	30%	978.0	56.0	21%	1,240	1,098	584	Cucamonga Channel Rubber Dam	Rubber dam operated from adjacent control building or SCADA	Deflated	Inflated	Deflated																												
Turner 2 (MZ2)	SBCFCD	968.0	990.0	-	52.0	0.5		10.0	978.0	16.0	978.0	16.0	31%	978.0	16.0	31%				Cucamonga Channel Inlet to Turner Basin 1	Automated Sluice Gate	Closed	Open	Open																												
Turner 3 (MZ2)	SBCFCD	966.0	986.5	-	120.0	0.5		12.0	978.0	60.0	978.0	59.6	50%	978.0	59.6	39%				640	937	394	Deer Creek Channel Drop Inlet (48" pipe) to Turner Basin 1	Automated Sluice Gate	Closed	Closed	Closed																									
Turner 4 (MZ2)	SBCFCD	961.0	987.0 <sup>(9)</sup>	224.9	50.0	0.5		17.0	978.0	25.0	978.0	25.0	39%	978.0	25.0	50%				Turner Basin 1 to Turner Basin 2 (42" pipe)	Manual Sluice Gate	Closed <sup>(9)</sup>	Closed <sup>(9)</sup>	Open																												
Turner Basin 4 to Turner Basin 3 (42" pipe)	Manual Sluice Gate	Open	Open	Closed																																																
Deer Creek Drop Inlet (48" pipe) to Turner Basin 4	Automated Sluice Gate	Closed	Open	Closed																																																
<b>Etiwanda Channel - CB14</b>																																																				
Victoria North (MZ2)	SBCFCD	1,313.0	1,318.0	100.0	28.5	1.5	6	3.0	1,316.0	19.0	1,317.5	23.7	67%	1,317.5	23.7	67%	2,090	2,365	1,114	San Sevaine Channel Outlet/Inlet to Victoria Basin North	Automated Sluice Gate	Closed	Open	Closed																												
Victoria South (MZ2) <sup>(11)</sup>	SBCFCD	1,309.0	1,318.0	-	47.1	1.5		7.0	1,316.0	31.8	1,317.5	43.2	84%	1,317.5	43.2	84%				Victoria Basin North to Victoria Basin South	Manual Sluice Gate	Open	Open	Open																												
Etiwanda Conservation Ponds (MZ3)	SBCFCD	1,010.0	1,048.0	NA	120.0	1.0		NA	11.0	1,048.0	120.0	NA	NA	NA	NA	NA				NA	NA	NA	Victoria Basin South to San Sevaine Channel	Automated Sluice Gate	Closed	Closed	Closed																									
NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA																												
<b>DeClez Channel</b>																																																				
RP3 Cell 1a (MZ3)	IEUA	948.0	952.0	-	20.0	2.5	7	2.0	950.0	10.0	952.0	20.0	100%	952.0	20.0	100%	1,330	6,562	1,973	DeClez Channel Rubber Dam	Rubber dam operated from adjacent control building or SCADA	Deflated	Inflated	Deflated																												
RP3 Cell 1b (MZ3)	IEUA	948.0	952.0	-	13.2	2.5		2.0	950.0	6.3	952.0	13.2	100%	952.0	13.2	100%				DeClez Channel Outlet/Inlet to Feeder Channel <sup>(12)</sup>	Automated Sluice Gate	Closed	Open	Open																												
RP3 Cell 2 (MZ3)	IEUA	949.0	955.0	-	48.1	2.5		4.0	953.0	31.4	949.0	0.0	0%	955.0	48.1	100%				Feeder Channel to RP3 Junction Structure	Manual Sluice Gate	Closed <sup>(14)</sup>	Closed <sup>(14)</sup>	Closed <sup>(14)</sup>																												
RP3 Cell 3a (MZ3)	IEUA	941.0	946.0	-	12.9	2.5		3.0	944.0	7.4	945.0	10.3	80%	945.0	10.3	80%				Feeder Channel Flow Control	Manual Sluice Gate	Closed <sup>(15)</sup>	Closed <sup>(15)</sup>	Closed <sup>(15)</sup>																												
RP3 Cell 3b (MZ3)	IEUA	941.0	946.0	-	13.2	2.5		3.0	944.0	6.3	945.0	10.6	80%	945.0	10.6	80%				Feeder Channel Outlet to DeClez Channel	Manual Sluice Gate	Closed	Closed	Closed																												
RP3 Cell 4a (MZ3)	IEUA	937.0	942.0	-	13.1	2.5		3.0	940.0	9.6	941.0	10.5	80%	941.0	10.5	80%				Jurupa Basin to RP3 Cell 1a	Automated Valve	NA	NA	NA																												
RP3 Cell 4b (MZ3)	IEUA	937.0	942.0	-	15.1	2.5		3.0	940.0	7.3	941.0	12.1	80%	941.0	12.1	80%				RP3 Cell 1a to Junction Structure	Manual Sluice Gate	Open	Open	Open																												
RP3 Cell 1b to Junction Structure	Manual Sluice Gate	Open	Open	Open																																																
Feeder Channel to RP3 Cell 2	Manual Sluice Gate	Open	Open	Open																																																
Feeder Channel to RP3 Cell 3a	Manual Sluice Gate	Open	Open	Open																																																
Feeder Channel to RP3 Cell 3b	Manual Sluice Gate	Open	Open	Open																																																
Feeder Channel to RP3 Cell 4a	Manual Sluice Gate	Open	Closed	Closed																																																
Feeder Channel to RP3 Cell 4b	Manual Sluice Gate	Open	Closed	Closed																																																

**Notes:**

- <sup>(1)</sup> Recharge Basin Operating Parameters represent the most recent available data reported in either the March 2006 Chino Basin Recharge Facilities Operation Procedures prepared for the Groundwater Recharge Coordinating Committee by WEI, the August 2001 Recharge Master Plan Phase II Report prepared for Chino Basin Watermaster by WEI and Black & Veatch, the January 1998 Chino Basin Recharge Master Plan prepared for CBWCD and Chino Basin Watermaster by WEI, SBCFCD Facility Drawings, or SBCFCD Zone 1 Project Systems Inventory.
- <sup>(2)</sup> Water level and storage generally associated with the maximum storage with one foot of freeboard.
- <sup>(3)</sup> Recharge estimates post Chino Basin Facilities Improvement Project.
- <sup>(4)</sup> Open when San Antonio Dam releases and water quality is acceptable.
- <sup>(5)</sup> Exception to the rule for 7-day perc out due to basin geometry. Maximum Inlet Capacity from West State Street is 96.24 cfs.
- <sup>(6)</sup> Brooks Street Basin has a desired maximum operation elevation of 893 feet MSL. Groundwater monitoring is being done in piezometers adjacent this basin to determine slope stability. Pending evaluation of this monitoring data, 875 feet MSL will be the maximum operating water surface elevation for supplemental recharge operations. Storm water can be retained in Brooks Street Basin in excess of 875 feet MSL provided that no additional supplemental water will be discharged into the basin until the water surface elevation falls below 875 feet MSL.
- <sup>(7)</sup> Generally, gate should be open to capture storm water from San Antonio Creek. Gate SAC-BRK-A must be closed if water surface elevation in Brooks Street is greater than the inlet elevation.
- <sup>(8)</sup> The storage shown for Ely 3 Maximum Conservation Storage and Rule Curves is based on the storage at the top of internal berms, minus 1.0 foot.
- <sup>(9)</sup> Closed until Turner 1 is full.
- <sup>(10)</sup> Only possible if Deer Creek gate DRC-TR4-A is shut and local flow fills basins.
- <sup>(11)</sup> Maximum Inlet Capacity from Etiwanda Channel is 156.2 cfs.
- <sup>(12)</sup> Open if Banana Basin is full.
- <sup>(13)</sup> Maximum Intake Capacity from DeClez Channel to RP3 Diversion is 192.0 cfs.
- <sup>(14)</sup> Changed from March 2006 document per personal communication from Andy Campbell. Adjusted Rule Curve elevations based on capacity curves in March 2006 document.
- <sup>(15)</sup> Closed until Cell 3 is full.



**Table 5-3**  
**Existing Regional Flood Control Basin Parameters<sup>(1)</sup>**

<b>Basins</b>	<b>Owner</b>	<b>Bottom Elevation (ft MSL)</b>	<b>Spillway Elevation (ft MSL)</b>	<b>Maximum Intake Capacity from Channel (cfs)</b>	<b>Storage Volume at Spillway Elevation (af)</b>	<b>Typical Percolation Rate (ft/day)</b>
<b>West Cucamonga Channel</b>						
Princeton (MZ1)	SBCFCD	1,070.0	1,077.0	NA	6.4	0.5
<b>Cucamonga/Deer Cr Channels - CB11</b>						
Lower Cucamonga Spreading Grounds (MZ2)	SBCFCD	714.0	730.0	NA	Varies (70 ac)	0.1
Chris (MZ2)	CBWCD	715.0	720.0	NA	NA	0.1
<b>Day Creek Channel - CB15</b>						
Wineville (MZ3)	SBCFCD	864.0	869.0	NA	95.0	0.5
Riverside (MZ3)		780.0	813.0	NA	840.0	0.5
<b>San Sevaine Channel - CB13</b>						
Rich (MZ2)	SBCFCD			NA	87.0	1.0
Jurupa (MZ3)	SBCFCD	885.0	927.0	23.2	1,365.0	0.5
<b>East Fontana Storm Drain</b>						
Linden (MZ3)	SBCFCD	1,195.0	1,201.7	NA	146.6	2.0
Merrill (MZ3)	SBCFCD	1,201.0	1,214.0	NA	79.1	2.0

Notes:

<sup>(1)</sup> Recharge Basin Operating Parameters represent the most recent available data reported in either the March 2006 Chino Basin Recharge Facilities Operation Procedures prepared for the Groundwater Recharge Coordinating Committee by WEI, the August 2001 Recharge Master Plan Phase II Report prepared for Chino Basin Watermaster by WEI and Black & Veatch, the January 1998 Chino Basin Recharge Master Plan prepared for CBWCD and Chino Basin Watermaster by WEI, or 1976 SBCFCD Project Systems Inventory for zone 1.

**Table 5-4**  
**Information on Rubber Dam Automation Within the Chino Basin Boundary**

<b>Dam Location</b> <b>(Basin/Creek)</b>	<b>Channel Elevation</b> <b>(feet msl)</b>	<b>Dam Height</b> <b>(feet)</b>	<b>Top of Dam Elevation</b> <b>(feet msl)</b>	<b>Plus Depth to Auto Deflate</b> <b>(inches)</b>	<b>Auto-Deflation Elev.</b> <b>(feet msl)</b>	<b>Max Pressure Setpoint</b> <b>(feet of water)</b>	<b>Max WL Setpoint</b> <b>(feet)</b>
College Heights /San Antonio	1,242	4.0	1,246	9-5/8"	1,247	4.8	4.0
Hickory/San Sevaine	1,114	5.0	1,119	12"	1,120	4.8	4.0
Lower Day/ Day Crk	1,460	3.3	1,463	7-7/8"	1,464	3.9	3.3
RP3 / Declez Crk	947	5.0	952	12"	953	6.8	7.5
Turner Basin #1 / Cucamonga Crk	996	4.5	1,000	10-3/4"	1,001	5.4	4.5



**Table 5-5**  
City of Chino Storm Water Recharge

Map ID	Project Name	Project No.	Stormwater BMP	Approximate Surface Area (ac)	Length (ft)	Storage Volume (af)	Typical Percolation Rate (ft/day)	Tributary Drainage Area (ac)	Notes
1	Watson Commerce Center (Nature's Best)	SA 05-35	Vegetated Swale	-	-	-	3.0-6.0	22	Discharges to Detention Basin. (LOCATION UNCERTAIN)
			Detention Basin	0.21	-	2.2	3.0-6.0		
			Underground Retention Chamber	-	-	0.23	3.0-6.0		
2	Watson Industrial Building (816)	SA 05-36	Vegetated Swale (Swale A)	0.02	224	0.09	2.0	14	6 inch underdrain pipe conveys low flows from one swale to the next, and discharging to the basin. Overflow drains directly to existing storm drains.
			Vegetated Swale (Swale B)	0.06	616	0.26	2.0		
			Vegetated Swale (Swale C)	0.03	296	0.22	2.0		
			Detention Basin	0.07	-	0.79	5.0		
			Vegetated Swale (Swale B1)	0.01	170	0.0119	2.5		
3	Euclid Plaza (Stater Bros. Market)	SA 05-30	Vegetated Swale (Swale B3)	0.01	156	0.0119	2.5	15	
			Vegetated Swale (Swale B4)	0.01	201	0.0147	2.5		
			Vegetated Swale (Swale B5)	0.01	146	0.0141	2.5		
			Underground Retention Chamber	0.61	-	1.44	2.0		
4	Victory Outreach Church	SA 05-38	Underground Retention Chamber	0.61	-	1.44	2.0	1.2	Cultec Recharger 330HD, 840 units, 60 rows x 14 units long
5	Carson Companies Industrial Buildings	SA 05-03	Detention Basin	6.58	-	72.75	0.2	92	Cypress Channel Diversion. Designed for 100 yr Event .
6	Yoshimura	PM-15166	Vegetated Swale	0.07	-	-	0.04-2.0	1.5	
7	Brehm Communities (The Preserve)	TM-17055	Detention Basin	0.44	-	2.6	0.2	31	
Tract 16419		Wetlands/Detention Basin	2.75	-	10.0	0.18	269	Bickmore Basin (Forebay is 2.2 af) (5 ac of basin floor covered by liner)	
		Wetlands/Detention Basin Forebay	4.53	-	10.40	0.18			
		Wetlands/Detention Basin Cell 1	5.51	-	43.78	0.18			
		Wetlands/Detention Basin Cell 2	5.49	-	44.56	0.18			
		Wetlands/Detention Basin Cell 3	5.77	-	44.71	0.18			
9		Tracts 17635, 17057, & 17572	Detention Basin	0.37	-	1.16	0.18	21	Northern Basin 1 (LOCATION UNCERTAIN)
			Detention Basin	0.28	-	0.9	0.18	22	Southern Basin 2 (LOCATION UNCERTAIN)
10		Tract 17571	Detention Basin	1.43	-	9.6	0.18	65	
11		Tract 16419 (Phase 2)	Temporary Detention Basin	1.18	-	3.5	-	305	"Hellman Basin"
12	Rancho Del Chino (Panattoni Retail)	TM -17819	Detention Basin	0.30	-	1.26	0.8	24	
13	College Park Phase 1	Tr 16837	Detention Basin	5.21	-	27.0	2.5-3.0	164	An estimated 50 ac drains directly to the swales, which discharge to existing storm drains.
			Vegetated Swale	0.16	1,295	0.05	2.5-3.0		
			Vegetated Swale	0.71	-	-	-		
15	Watson Industrial Buildings (818 & 819)	SA 05-34	Vegetated Swale A	0.08	820	0.53	3.0	28	(TRUE LENGTH AND VOLUME UNCERTAIN)
			Vegetated Swale B	0.06	420	0.79	3.0		(TRUE LENGTH AND VOLUME UNCERTAIN)
			Vegetated Swale C	0.06	425	0.38	3.0		(TRUE LENGTH AND VOLUME UNCERTAIN)
			Infiltration Trench	0.07	-	0.04	4.0		0.8
17	Canyon Ridge Hospital	SCUP 558	Detention Basin	0.05	-	0.04	0.3	1	(ACTUAL CONSTRUCTION DIFFERS FROM PLAN)
18	Don Lugo High School	-	Detention Basin	0.96	-	0.71	-	47	
19	Ayala Park Expansion	-	Vegetated Swale	NA	2,222	-	3.0-14.1	38	13 different Swales
<b>Total</b>				<b>43.1</b>		<b>280</b>		<b>1,555</b>	

**Table 5-6**  
**City of Fontana Storm Water Recharge**

Map ID	Project Name	Approximate Surface Area (ac)	Tributary Drainage Area (ac)	Notes
1	NA	0.36	14.9	Would otherwise drain to Banana or Hickory Basins
2	NA	0.86	19.6	Would otherwise drain to Banana or Hickory Basins
3	NA	0.53	11	Would otherwise drain to Banana or Hickory Basins
4	NA	0.86	17.2	Would otherwise drain to Banana or Hickory Basins
5	NA	4.75	85.2	Would otherwise drain to Banana or Hickory Basins
6	NA	2.34	81	Would likely otherwise drain outside of Chino Basin.
7	NA	0.16	8.2	Would likely otherwise drain outside of Chino Basin.
8	NA	0.37	15.7	Would likely otherwise drain outside of Chino Basin.
9	NA	0.29	9.9	Would likely otherwise drain outside of Chino Basin.
10	NA	0.83	8.6	Would likely otherwise drain outside of Chino Basin.
11	NA	0.27	7.2	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
12	NA	0.27	5.5	Would likely otherwise drain outside of Chino Basin.
13	NA	0.21	34.7	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
14	NA	0.45	18.9	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
15	NA	0.55	6.4	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
16	NA	0.79	30.7	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
17	NA	0.59	32.4	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
18	NA	0.46	12	Outside of Chino Basin. Would likely otherwise drain outside of Chino Basin.
19	NA	0.73	21.7	Would otherwise drain to Banana or Hickory Basins
20	NA	0.20	16.4	Would otherwise drain to Banana or Hickory Basins
21	NA	0.17	30.8	Would otherwise drain to Banana or Hickory Basins
22	NA	0.33	19	Would otherwise drain to Banana or Hickory Basins
23	NA	0.37	4.4	Would otherwise drain to Banana or Hickory Basins
24	NA	4.12	167.9	Would otherwise drain to Banana or Hickory Basins
25	NA	0.69	14.2	Would otherwise drain to Banana or Hickory Basins
26	NA	0.38	19.2	Would otherwise drain to Banana or Hickory Basins
27	NA	0.97	47.5	Would otherwise drain to Banana or Hickory Basins
28	NA	4.78	338.7	Would otherwise drain to RP3 Basins
32	NA	0.70	18.1	Outside of Chino Basin. Would likely otherwise drain to San Sevaine Basins.
33	NA	2.25	37.4	Outside of Chino Basin. Would likely otherwise drain to San Sevaine Basins.
41	Sierra Lakes Golf Club	0.50	115.4	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
42	Sierra Lakes Golf Club	0.20	28.4	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
43	Sierra Lakes Golf Club	0.35	14.6	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
44	Sierra Lakes Golf Club	0.16	44.3	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
45	Sierra Lakes Golf Club	0.15	14.5	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
46	Sierra Lakes Golf Club	0.18	73.5	Outside of Chino Basin. Would likely otherwise drain to Victoria Basins.
<b>Total</b>		<b>46.1</b>	<b>1,445</b>	

**Table 5-7**  
**City of Montclair Storm Water Recharge**

<b>Map ID</b>	<b>Basin Name</b>	<b>BMP</b>	<b>Approximate Surface Area (ac)</b>	<b>Storage Volume (af)</b>	<b>Typical Percolation Rate (ft/day)</b>	<b>Tributary Drainage Area (ac)</b>	<b>Notes</b>
1	4855 Mission Blvd	Underground Chamber Vault	0.09	0.17	17.1	1.5	
2	Chaffey West Community Day School	Infiltration Trench and Vegetated Swale	NA	0.13	NA	5.0	Would otherwise drain to Brooks Basin
3	Montclair Retail Center	Infiltration Trench and Vegetated Swale	0.11	0.06	1.8	0.6	
4	Storage Specialists LLC	Infiltration Basin and Vegetated Swale	0.06	0.09	15.0	2.5	Would otherwise drain to Montclair Basins
<b>Total</b>			<b>0.26</b>	<b>0.45</b>		<b>9.6</b>	

**Table 5-8**  
City of Ontario Storm Water Recharge

Map No.	Project No.	Name of Project	APN	Project Acres	Structural BMP	Status	Approximate Surface Area (ac)	Storage Volume (af)	Tributary Drainage Area (ac)	Infiltration Capacity (ft/day)	Vegetated Swale	Infiltration/ Detention Basin	Drywell	Infiltration Trench	Underground Chamber Vault	Pervious Pavement	Roof Well	Notes
1	99-048-S	Belmont Business Park	1049-401-03,04 to 09	7.02	Detention Basin+SunTree Filters	Complete	0.03	0.19	7.02	2		1						Would otherwise drain to Ely Basins
2	99-068-S	Walgreens	0218-041-29	1.68	2 - Pervious Turf Filter channels	Complete					2							Minimal infiltration capacity
3	PDEV00-030	Milliken Francis LLC	0238-152-01, 03	5.96	Veg.Swale+1-MaxWell Plus+SunTree Filter	Complete			5.96	688	1		1					
4	PDEV00-047	Empire Towers, Bldg IV	0210-205-16	2.88	4 shallow infiltration trenches+ 4 SunTree filters	C-10/12/04								4				Infiltration trenches located between parking spaces. Minimal infiltration capacity
5	PDEV00-052	ACCO Airport Center	0211-263-37	3.98	5 - Turf Swales/2-pervious natural channels	Complete					5							Minimal infiltration capacity
6	PDEV00-057	Access Mini Storage	1050-181-17	2.81	Detention Basin + 2-SunTree filters	C-10/24/04	0.02	0.05	3.35	2		1						Would otherwise drain to Ely Basins
7	PDEV00-059	Bldg NWC Pointe/Philadel	0211-275-24	1.00	Underground retention/infiltration chambers (4)	C- 1/4/06	0.01	0.01	1.00	2					4			
8	PDEV00-064	AAA Self Storage	1011-192-04	2.74	1-Detention Basin	Complete	0.01	0.00	2.74	2		1						
9	PDEV00-076	West Locust Court	0113-395-45,46,41	6.24	6-Perv Channels, 4-Filters,3 roof wells	Complete	0.00	0.00	8.05	2	6			4				
10	PDEV00-077	Ontar Gateway West, II	0113-401-06	17.89	2-MaxWell Plus + 1-Drainage Channel	Complete			17.89	688	1		2					Would otherwise drain to Ely Basins
11	PDEV01-005	Vogel Engineers, Inc.	0238-133-44, 43	5.76	2-10'x3' Porous Channels+2 roof wells	Complete					2						2	Minimal infiltration capacity
12	PDEV01-011	Kobold Indust Pk, Phase 2	1011-211-14,15 to 21	5.23	2-4'x80' ADS Leach Lines+SunTree Filt	Complete	0.02	0.08	5.23	2								
13	PDEV01-012	Guasti Ontario	0238-042-25	6.12	1 - 6' x 75' underground retention/infiltration trench	Complete	0.01	0.07	6.12	2		1						
14	PDEV01-013	Vogel Engineers, Inc.	0238-132-04, 05	6.40	2 - Drainage Swales + 2 Fossil Filters	Complete					2							Minimal infiltration capacity
15	PDEV01-029	Grove Ave Business Pk.	1050-481-30 1050-491-17	0.77	2- CSR Stormceptors + 2 Rock Swales	Complete					2							Minimal infiltration capacity. Would otherwise drain to Grove Basin.
16	PDEV01-030	Pat & Oscar's Restaur	0238-014-45	1.37	1- 2'x6' Filter Drain Channel	Complete					1							Minimal infiltration capacity
17	PDEV01-039	Nissin Cap Inc.	1050-451-04	4.67	2 - MaxWell IV Drainage Systems	Complete			4.67	688			2					Would otherwise drain to Grove Basin
18	PDEV01-042	Tom's Burger #1	0211-263-34	0.94	2 - Grassy Swales+ Trash Enc drain	C- 7/20/04					2							Minimal infiltration capacity
19	PDEV01-047	Haven Bldg G	0211-275-46	0.99	1-Grassy Swale + Fossil Filter insert	Complete					1							Minimal infiltration capacity
20	PDEV01-048	Crown Lexus	0238-251-13	4.75	1-MaxWell IV + 1- Drain-Pac filter insert	Complete			4.75	688			1					
21	PDEV01-050	Campus Self-Storage	1050-211-03	3.08	1-MaxWell IV + 1-Drain-Pac Filter insert	C-7/10/06			3.08	688			1					Would otherwise drain to Ely Basins
22	PDEV01-053	Panattoni Development	0211-222-70	9.51	1-Swale + 1-MaxWell IV + 4 Fossil Filter inserts	Complete			9.51	688	1		1					
23	PDEV01-058	Calif Manufacturing Corp	1050-521-01	1.12	1-Grassy Swale/Basin	Complete	0.02	0.06	1.12	2	1							Would otherwise drain to Grove Basin
24	PDEV01-062	Airport Drive Industrial	0238-044-24	1.13	1- Stormgate Separator + 1-vegetated swale	C- 11/8/05					1							Minimal infiltration capacity
25	PDEV01-064	The Village/Ontario Ctr	0210-204-29	8.06	1-underground retention/infiltration pipe/trench 5'x260'	Complete	0.04	0.12	12.79	2				1				
26	PDEV02-001	47 Jurupa Partnership	0238-132-23	7.38	1- MaxWell IV Drywell + Retention Basin	Complete	0.06	0.03	7.38	10			1					
27	PDEV02-002	Cedar St Industrial	0113-461-33	3.79	1-Grass Swale + HydroCartridge Filter	Complete					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
28	PDEV02-003	Waxie - Ontario	0238-021-66	11.76	Grass Swales + SunTree Filter	Complete					2							Minimal infiltration capacity
29	PDEV02-005	Vineyard Townhomes	0110-441-15,16 to 47 0110-441-49,50 to 87 0110-441-91	6.32	2-MaxWell Plus, 3300+1200 cu ft Ret/Inf Chambers	C-12/10/04	0.01	0.10	6.32	86			2	1				Would otherwise drain to Turner Basins
30	PDEV02-006	Burgundy/Philadelphia	0238-152-22	3.26	1-Large Grass Swale, 1 - curb drain filter	Complete					1							Minimal infiltration capacity
31	PDEV02-009	Ontario Towne Center	1011-141-10	6.27	3-Vegetated Swales	C-12/22/04					3							Minimal infiltration capacity. Would otherwise drain to Brooks Basin.
32	PDEV02-014	MBK Homes	0110-531-01,02 to 71 0110-531-86,87	15.00	1-Detention Basin	C-10/26/04	0.13	0.13	15.00	2		1						
33	PDEV02-015	Richard Dick & Assoc	0238-121-63	3.83	1-Grass Swale, 2-BioClean Filters+ 1-CDS PMSU20_20	Complete					1							Minimal infiltration capacity
34	PDEV02-025	RiverArch Shopping Ctr	0218-041-36	2.30	1-Vortentry Sep + 2-underground 36" retention/infiltration pipes	C- 7/10/05	0.04	0.13	2.30	2				1				
35	PDEV02-026	Washington Mutual	0218-041-30	1.09	1- BioClean filter insert + 1-underground 36" retention/infiltration pipe	C- 1/31/05	0.02	0.08	1.09	2				1				
36	PDEV02-027	Campus Court LLC	1050-441-63,64 to 72	8.62	2-Bioswales + 4-Maxwell IV drywells	C-5/13/05			8.62	688	2		4					Would otherwise drain to Grove Basin
37	PDEV02-029	Richard Dick & Assoc	0238-121-62	2.01	Grass Swale, 1-SunTree Filter	Complete					1							Minimal infiltration capacity
38	PDEV02-034	Hampton Inn & Suites	0238-014-15	1.82	1 MaxWell drywell,1 Fossil Filter, 1-grass swale	C-12/21/04			1.82	688	1		1					
39	PDEV02-036	CSI Ontario Senior House	0110-254-77,78	6.17	2 Large Grass Swales, 2 SunTree Filters	C-1/31/05					2							Minimal infiltration capacity
40	PDEV02-044	Concours Plaza	0210-182-70	1.67	Grass Swale, 1-MaxWell Plus drain sys	Complete			4.67	688	1		1					
41	PDEV02-045	Ontario Spectrum Bus Ctr	0211-232-53	1.31	SunTree Filters, 1-MaxWell Plus System	Complete			1.31	688			1					

**Table 5-8**  
City of Ontario Storm Water Recharge

Map No.	Project No.	Name of Project	APN	Project Acres	Structural BMP	Status	Approximate Surface Area (ac)	Storage Volume (af)	Tributary Drainage Area (ac)	Infiltration Capacity (ft/day)	Vegetated Swale	Infiltration/ Detention Basin	Drywell	Infiltration Trench	Underground Chamber Vault	Pervious Pavement	Roof Well	Notes
42	PDEV02-050	PC Indust.Distribution Fac	0113-343-30	3.13	1- Large Vegetated Retention/Infiltration Basin	C-6/28/05	0.28	0.76	3.13	2		1						Would otherwise drain to Ely Basins
43	PDEV02-051	Legacy I	0211-242-24	5.88	2-CDS Units+2-MaxWell Plus drywells	C-1/10/08			5.88	688			2					
44	PDEV02-052	Euclid Garden Apts.	1050-591-17	1.75	1-Retention Basin + 1-MaxWell Plus Drywell	C-8/21/06	0.03	0.08	1.75	17		1	1					
45	PDEV02-062	Shilpark Paint	0218-051-76	0.00	1-Infilt Basin+2-Drainpac filters+1-MaxWell Plus	C- 6/10/05	0.06	0.57	0.00	10		1	1					
46	PDEV02-065	MLRCE Warehouse Bldg	0211-301-18	3.81	1 MaxWell IV, Large landscape swale	C- 7/27/04			4.90		1		1					
47	PDEV02-069	Ontario Christian Parking	1050-391-33	9.91	2-Vegetated Swales + 1 Drainpac filter insert	C-1/30/06	0.02	0.04	9.91	2	2							
48	PDEV02-072	Bedford Property Phase3	0211-281-54	1.42	2-Kristar Flogard drain inserts + 2 infiltration swales	C-11/12/04					2							Minimal infiltration capacity
49	PDEV02-073	Airport Wineville Project	0238-081-87	1.00	9-infiltration trenches+4 swales+ 3-1000 & 1-3000 Vortechs Separators	C-6/20/06	0.17	0.18	8.20	2	4			9				
50	PDEV02-074	Rockefeller CommerceCtr	0238-201-16	9.84	1-MaxWell IV drywell + 6 SunTree Filters	Complete			9.84	688			1					
51	PDEV02-076	Housing Tract #14266	1014-091-35,36 to 54 1014-091-62,63 to 72	13.36	1- MaxWell IV drywell	Complete			13.36	688			1					
52	PDEV02-079	Indigo Hotel	0210-182-71,11	2.95	1-Vortechs Model 1000 + StormTech Underground Chambers	Active	0.02	0.00	2.95	2					1			
53	PDEV02-080	Fazoli's Restaurant	0210-204-33	0.82	1-Vegetated Swale	Complete					1							Minimal infiltration capacity
54	PDEV02-081	Parkside Manor Condos	0210-425-02, 03 to 13	0.92	Pervious pavement + 1-MaxWell IV Drywell	C-6/10/08			0.92	688			1			1		
55	PDEV02-082	Wendy's Restaurant	0110-261-12	0.78	1-Grass swale, SunTree Filter	Complete					2							Minimal infiltration capacity
56	M-324	Woodcrest Junior High	1051-381-07	1.79	State Controlled project, 1- MaxWell drywell	Complete			9.50	688			1					Would otherwise drain to Grove Basin
57	PDEV03-001	Hudson Ave Indust Bldg	0238-121-28	1.49	1-Grass Swale,1-retention/infiltration trench	C-12/8/04	0.02	0.08	1.49	2	1			1				
58	PDEV03-003	Christensen Airport Ind Bl	0238-081-86	3.56	1-MaxWell drywell+ 1-CDS PMSU20_15 +Ret Basin	C-2/22/06	0.01	0.02	3.56	67			1	1				
59	PDEV03-004	SW Council Carpenters	0210-193-20	14.54	7-BioClean Inlet Filters + 1 Veg Swale + 1 Ret Basin	C-2/23/07	0.53	0.78	14.54	2	1	1						
60	PDEV03-007	Bridgestone Phase II	0218-081-22	49.04	1-earthen bottomed detention/retention basin	Complete	0.88	0.88	49.04	2		1						
61	PDEV03-008	Art Damos Warehouse	0113-381-27	0.46	1-Vegetated Swale+Pervious Concrete Pavement	Complete					2					1		Minimal infiltration capacity. Would otherwise drain to Ely Basins.
62	PDEV03-009	Mag Inst., Bldg A & B	0113-414-42, 43, 44	4.50	2-CDS Clarifiers + Grassy Swale	C-8/27/04					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
63	PDEV03-011	Ponderosa Industrial	0210-212-39	0.86	Vegetated Swales + Kristar Flo-gard drain inserts	Complete					2							Minimal infiltration capacity
64	PDEV03-014	Carillo Privado Indust Park	0113-395-02	6.33	1-MaxWell IV/ 1 Flo-Gard Filter, porous channels	C-3/10/06			6.33	688	1		1					
65	PDEV03-017	Grove Ave Business Ctr	0113-361-54	1.00	3 Vortechnic Units, Swales	C- 6/17/05					2							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
66	PDEV03-019	Lakeview Ctr, Bldg A & B	0210-551-17	2.54	3-MaxWell Plus Drywells, 4- SunTree Tech filters	C - 7/8/05			6.00	688			3					
67	PDEV03-022	Concours Plaza, Phase 2	0210-521-01,02 to 09	5.02	Numerous landscaped swales + perforated landscaping drain lines+infiltration pockets	C-2/25/05					4							Minimal infiltration capacity
68	PDEV03-024	Haven Gateway No. 7	0218-071-60	2.41	3- Large grass swales + 7 Flo-Gard Plus+filters	C-5/16/05					3							Minimal infiltration capacity
69	PDEV03-025	Used Car Sales OfficeLot	1049-101-40	0.40	1- small gravel swale	C - 1/18/05					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
70	PDEV03-026	Del Rio Develop Partners	0210-311-02	1.22	1-Kristar Inlet filter + 2 Vegetated Swales	C-1/13/05					2							Minimal infiltration capacity. Would otherwise drain to Turner Basins.
71	PDEV03-029	ACCO Airport Ctr - II	0211-263-32	6.89	Vegetated Swales						2							Minimal infiltration capacity
72	PDEV03-031	Chick-Fil-A Restaurant	0238-041-18	1.31	Grass Swale/Rest Trash Enclosur/2 drain filters	C- 5/25/04					1							Minimal infiltration capacity
73	PDEV03-032	Ontario Dialysis Clinic	1008-471-38	1.02	2-vegetated/rock swales+ pervious concrete pavement	C-10/31/06					2					1		Minimal infiltration capacity. Would otherwise drain to Brooks Basin.
74	PDEV03-033	Retail ShopsforRosenblum	1048-563-07	0.20	1-Infiltration Trench	C-9/5/07	0.00	0.00	0.10	2	1			1				Minimal infiltration capacity
75	PDEV03-036	Haven Gateway Bldg 9	0211-281-45	2.61	Grassy Swale + 1 BioClean Filter insert	C - 5/6/05					1							Minimal infiltration capacity
76	PDEV03-040	CarMax	0210-211-46	14.00	Grass Swales/Vortechnic Clarifier	C-3/2/05					2							Minimal infiltration capacity
77	PDEV03-043	Trio Glen TM 16582	0110-021-04,05 to 29 0110-021-31,32 to 54 0110-261-18,19 to 39 0110-261-41,42 to 58 0110-261-60,62 to 80	16.00	2-110"Lx48"+1-70"x36" Infil Pipes + 3-Vortechs Model 1000 separators + 3-Drainpac filters	C-3/24/06	0.06	0.13	10.30	2					2			

**Table 5-8**  
City of Ontario Storm Water Recharge

Map No.	Project No.	Name of Project	APN	Project Acres	Structural BMP	Status	Approximate Surface Area (ac)	Storage Volume (af)	Tributary Drainage Area (ac)	Infiltration Capacity (ft/day)	Vegetated Swale	Infiltration/ Detention Basin	Drywell	Infiltration Trench	Underground Chamber Vault	Pervious Pavement	Roof Well	Notes
78	PDEV03-044	1175 E. D St Condos	1048-451-53, 54 to 58	0.14	Grass Swale + Underground Stormchamber Unit	C-9/27/07	0.00	0.00	0.14	2	1				1			Would otherwise drain to Ely Basins
79	PDEV03-045	La Galleria Retail Center	0238-014-49	1.98	Grass Swale+1-SunTree Filter+1-PMSU20_15 CDS Unit	C - 8/22/05					1							Minimal infiltration capacity
80	PDEV03-046	University Plaza Off Bldg	0210-551-10	6.54	PL Infiltration strips + C.B. filter inserts	C - 1/20/05												Minimal infiltration capacity
81	PDEV03-048	Andy's Burgers	1049-065-09	0.87	2-catch basin filters, Rest Trash enclos, swales	C-4/15/06					2							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
82	PDEV03-049	Inland Empire Office	0210-191-28	0.53	Stormfilter Cartridge Vault + 2-Drywells	C - 3/1/06		0.04	1.40	688		1	2					
83	PDEV03-050	Lockaway Self Storage	0108-501-50	4.48	1-MaxWell drywell, Percolation Pipe System, Swale	C-10/1/06	0.07	0.10	4.48	9	1	1	1		1			Would otherwise drain to Turner Basins
84	PDEV03-051	Warehouse/Office Bldg	1050-501-13	0.58	2- Infiltration Trenches + Pervious Concrete	Active	0.01	0.07	0.55	2		4		3		1		Would otherwise drain to Grove Basin
85	PDEV03-053	Tract # 16362	1011-562-11,12 to 23	2.52	1-Vegetated Swale + Infiltration Trench	C-11/22/04	0.05	0.07	3.20	2	1			1				
86	PDEV03-054	Kellogg Garden Prod	0216-313-05	23.03	Self Containment Basin	C - 9/20/05	0.28	0.99	23.03	2		1						
87	PDEV03-055	Sequoia Industrial Bldg	0210-212-42	0.87	2-Vegetated Swales + 1-Kristar Trash filter	C - 9/20/05					2							Minimal infiltration capacity
88	PDEV03-056	Sunkist Campus Ind Park	1049-354-08,09 to 12	5.02	Multiple Vegetated Swales	C-5/11/05					4							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
89	PDEV03-057	Bombay Partners LP- V	0218-061-59	2.67	Multiple Vegetated Swales + infiltration trenches	C-12/20/04	0.19	0.19	2.67	2	4							
90	PDEV03-060	Airport Corporate Center	0210-551-24,25 to 28 0210-551-38	18.00	9-BioClean Filter insert, Multiple Infiltration Trenches	C - 1/5/06	0.06	0.02	18.00	2	4			4				
91	PDEV03-061	Empire Center	0210-541-01,02 to 06	3.39	12-Drainpac Filter Inserts + 3 Infiltration Trenches	C - 9/19/05	0.00	0.01	3.39	2				3				
92	PDEV03-062	Food Distribution Facility	1049-371-07	0.45	1- continuous vegetated swale around project	C-1/23/07					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
93	PDEV03-063	Acacia Grove Bus Park	0113-351-16	1.74	3-Stormgate Separators+Veg Swales+ Perv Concrete	C-8/1/06					2					1		Minimal infiltration capacity. Would otherwise drain to Ely Basins.
94	M-392	H BIZCTR/Ontario	0113-631-01,02 to 09	5.34	4-Infiltration trenches+roof drain swales	C - 9/10/05	0.04	0.02	5.34	2	4			4				Would otherwise drain to Ely Basins
95	PDEV04-002	IH Campus Business	1050-111-14,15 to 24	4.39	12-BioClean Inlet filters + 470"x36" diam perf infilt pipe	C - 9/20/05	0.08	0.14	4.39	2	1			2				Would otherwise drain to Ely Basins
96	PDEV04-003	BCI Campus, LLC	1050-111-11	4.85	6-BioClean Inlet filters + 508"x36" diam perf infilt pipe	C - 9/20/05	0.11	0.19	4.85	2				1				Would otherwise drain to Ely Basins
97	PDEV04-005	Archibald Shop Bldg 1&2	0110-311-44,43	1.06	2-Stormfilter Cartridge Units+45 LF Stormtech SC-740	C - 5/17/05	0.02	0.03	1.06	2					1			
98	PDEV04-006	Shelby Office Pk, Phase1	0210-571-14,15 to 20 0210-571-23 & 24	3.47	2 -Stormgate SCS 610 + 4 infiltration basins	C - 1/15/06	0.07	0.20	2.90	2		4						
99	PDEV04-006	Shelby Office Pk, Phase2	0210-571-01,02 to 14 0210-571-22	6.52	Grass Swale/Retention Basin/Vortechnics	C-11/15/06	0.45	0.18	6.52	2	1	1						
100	PDEV04-008	Amrep Inc.	1050-161-01	9.23	1-Vortechnics Model 5000 + Vegetated Swales	C - 5/10/05					2							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
101	PDEV04-010	Akram Auto Electric	1011-121-21	1.06	1-BioClean Trench filter + 2 Veg Swales	C-11/20/07					1							Minimal infiltration capacity. Would otherwise drain to Brooks Basin.
102	PDEV04-015	Pacific Collision Center	0113-481-09	1.00	1-MaxWell Drywell + Vegetated Swale	C-11/15/05			1.00	688	1		1					Would otherwise drain to Ely Basins
103	PDEV04-017	Grove Lumber Storage Yd	1049-482-02,03	8.84	2-StormTreat Units+Perforated Infiltration Pipe Trench+Pervious Pavement+2-Veg Swales	C-8/29/08	0.03	0.06	8.84	2	1					1		Would otherwise drain to Ely Basins
104	PDEV04-018	Jack Jones Trucking	1049-401-10	11.23	1-CDS PMSU20_25+ Kristar Filter +1-Lg Veg Swale	C-1/15/06					2							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
105	PDEV04-020	Xtreme Image Off Road	1011-361-08	0.42	1-Veg Swale+Rainstore Infiltration Unit+Perv Pavement	Active	0.02	0.04	0.42	2	1				1	1		
106	PDEV04-021	Haven Airport Centre	0211-263-41	3.26	numerous vegetated swales + Rainstore 3	C-8/1/06	0.02	0.11	3.26	4	4				1			
107	PDEV04-022	Holiday Inn Hotel	0110-321-58	2.57	Stormfilter Media Cartridge Vault + Roof runoff controls	C-2/1/08												Minimal infiltration capacity
108	PDEV04-023	Archibald/Philad Ind Cmplx	0218-021-71	0.68	2-Vortechnics Units+ 2- StormTech galleries	C-11/13/06	0.11	0.31	7.40	2					2			
109	PDEV04-025	Eastside Water Facility	1053-111-01,03	13.44	Retention/Infiltration Basins	Plan Check			13.44			2						Files missing-City of Chino has copies
110	PDEV04-026	Vintage Apartments	0210-531-02	11.13	2-Stormgate-SGS 610 + 2-MaxWell Plus + 2-Veg Swale	C-3/21/07			11.13	688	2		2					
111	PDEV04-028	Phase 2 Mtn View Senior	1010-461-08,09 & 11	0.64	1-MaxWell Plus Drywell + Vegetated Swale	C-3/28/07			0.64	688	1		1					Would otherwise drain to Brooks Basin
112	PDEV04-032	WarmingtonHomesTM16901	0210-601-02,03 to 57	9.25	2-CDS Media Cartridge Vaults + 3-MaxWell Plus Drywells	Active			9.25	688			3					Would otherwise drain to Turner Basins
113	PDEV04-033	Crossroads Bus Pk Bldg 6	0238-021-74	12.25	1-Vortechnics 7000+Veg Swale+2-MaxWells+ 57 LF StormTech740 underground chambers	C-9/06	0.13	0.07	12.25	10	1		2					

**Table 5-8**  
City of Ontario Storm Water Recharge

Map No.	Project No.	Name of Project	APN	Project Acres	Structural BMP	Status	Approximate Surface Area (ac)	Storage Volume (af)	Tributary Drainage Area (ac)	Infiltration Capacity (ft/day)	Vegetated Swale	Infiltration/ Detention Basin	Drywell	Infiltration Trench	Underground Chamber Vault	Pervious Pavement	Roof Well	Notes
114	PDEV04-034	Cedar Business Park	1050-451-08 1050-511-07,08,09	6.12	3-Vortechs 1000+1-2000 VortUnits + 4 Cultec Chamber Syst.	C-4/14/08	0.63	1.36	4.60	2					4			Would otherwise drain to Grove Basin
115	PDEV04-035	Mag Inst., Corporate Ctr	0113-491-82	29.39	1-Vortechs Model 7000 + 1-MaxWell Drywell+7-Drainpac filters	C-3/30/05			29.39	688			1					
116	PDEV04-036	Hudson Industrial Bldg II	0238-121-29	1.49	2 Vegetated swales + 1-MaxWell IV	C- 8/19/05	0.03	0.06	1.49	18	2		1					
117	PDEV04-039	Cedar Oaks, TM16804	1014-571-42,43 to 51	4.39	Driveway drains to NDS Flo-Well units	Complete											1	Minimal infiltration capacity
118	PDEV04-041	Gateway Mountain Village	1008-272-02,03 to 09	8.00	Driveway drains to NDS Flo-Well units	C-7/30/06	0.10	0.20	6.83	2					1		1	Would otherwise drain to Brooks Basin
119	PDEV04-043	Corinthian Colleges	0211-272-12	4.60	2-Detention Basins+Infiltration Strips+ 1-CBSF-2S media cart filt.	C-4/24/06	0.05	0.07	3.05	2		2						
120	PDEV04-044	GSC Corporation	0211-275-05	4.41	Perv concrete parkng stalls +1-Vortechs 3000+ 1-MaxWell Plus	C-10/30/07			4.41				1			1		
121	PDEV04-045	Francis Rochstr Ind,Phas1	0238-152-32	19.78	Retention/Infiltration Basins	C-6/12/06	1.05	0.77	19.78	2		2						
122	PDEV04-046	Ontario Mills & Vintage	0238-051-34	6.57	4-CDS Units + drainage swale/retention basin	C-2/7/07					1							Minimal infiltration capacity
123	PDEV04-050	Yokin Business Center	0113-463-34,35,36	1.12	2-Contech CBSF-3SF media cart filt + 2-MaxWell Plus Drywells	C-8/31/07			1.12	69			2					Would otherwise drain to Grove Basin
124	PDEV04-051	H' Street Town Homes	1048-271-14	0.55	Pervious concrete park stalls + Vegetated swale	Active					1					1		Minimal infiltration capacity. Would otherwise drain to Ely Basins.
125	PDEV04-059	Diamante Terrace	1048-581-07	0.55	Vegetated Swales	Plan Check					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
126	PDEV04-060	San George Auto Sales	1011-131-17	0.63	Vegetated Swale+Pervious pavers	C-10/19/06					1					1		Minimal infiltration capacity
127	PDEV04-061	Inland Community Bank	0210-205-14	1.14	1-Stormfilter Cartridge Vault, Pervious Pav+ Roof runoff control	C-3/10/06					1					1		Minimal infiltration capacity
128	PDEV04-064	Francis/Rochester,Phas2	0238-152-31	9.82	StormTech SC-740 sys+Inf Basin+3-MaxWell IV+1-2000 Vortechs	C-2/02/06	0.03	0.08	9.82	53		1	3		1			
129	PDEV04-066	Patton's Warehouse	1049-181-01	3.04	1-Vegetated swale + 7-roof drain drywells	C-4/20/07			3.04	688	1		7					Would otherwise drain to Ely Basins
130	PDEV05-001	Marketplace On Grove	1051-151-07	12.44	2-Vortechs 5000 + 1-Large Retention Basin+ 6-MaxWell drywells	C-11/14/06	0.37	1.65	17.58	10		1	6					Would otherwise drain to Grove Basin
131	PDEV05-004	West Ontario Indust. Park	1011-201-14,15 to 25	10.50	5 Vortechs Units + 8 Infiltration pits + 5 Grate Inlet skimmers	C-11/30/06	0.13	0.67	10.50	2				5				
132	PDEV05-008	Rexxons Plaza	1049-268-11	0.48	1-MaxWell(on site)+1 Maxwell(off-site) + 1 Vegetated swale	Active			0.48	688	1		2					
133	PDEV05-009	Lot 42, Greystone Dr	0218-091-42	1.62	1-Grass Swale+ 1-MaxWell IV + pervious conc park stalls	C - 2/17/06			1.62	688	1		1					
134	PDEV05-019	Crown Business Center	0110-091-07,08 to 29 0110-091-34,35 to 40 0110-091-44,45	14.57	1-Vortechs 5000 + Pervious Paved parking stalls	Active										1		Minimal infiltration capacity
135	PDEV05-020	American Career College	0210-193-27	2.79	1-Vegetated swale + 2-retention basins + 8 drywells	C-8/25/08	0.52	0.39	7.00	9	1	1	8					
136	PDEV05-021	Legacy II	0211-275-51	2.78	1-CDS PMSU20_25 + 1-MaxWell Plus Drywell	C-12/20/07			2.78	688			1					
137	PDEV05-022	Office Depot	0216-081-21	1.49	2-CDS PMSU20_15 units + pervious swale	C-8/15/06					1							Minimal infiltration capacity. Would otherwise drain to Grove Basin.
138	PDEV05-024	Ontario Carwash	1011-131-02	0.30	1-BioClean filter+8-SC-740 Storm Tech Chambers	Active	0.01	0.02	0.30	2					1			Would otherwise drain to Brooks Basin
139	PDEV05-028	Majestic Milliken Bldg I&2	0238-152-34,33	8.05	1-Vortechs 3000 + 1-Detention Basin + Perc Pipe	C-3/16/07	0.25	0.05	8.05	2		1		1				
140	PDEV05-029	Ontario Center, Phase 2	0210-501-31,32,33	5.31	2-MaxWells + 1-Stormceptor STC 4800 Vault	C-1/7/08			5.31	1,375				2				
141	PDEV05-034	BNP Church	1052-141-03	9.20	1-Vortechs 1000 Unit + Pervious Pavement+ Infiltr. Strips	C-1/25/07								1		1		Minimal infiltration capacity
142	B200503873	Citizens Business Bank	0210-212-30	1.02	1-underground percolation pit	C-3/30/06	0.02	0.06	1.02	2	2	2		1				
143	PDEV05-036	Ontario Pines	0210-212-53	0.59	Veg Swale + BioClean Stormtreat Unit	C-5/1/07	0.01	0.02	0.59	2	2	2						
144	PDEV05-039	Riverarch Center	0218-041-15,16,23,29 to 32 0218-041-35,36	2.48	1-Stormfilter Cartridge Vault + Infiltration System	C-9/06	0.13	0.12	2.48	2				1				
145	PCUP05-039	Budget Rental Expansion	0110-131-08,09,13	3.43	3-Filter Cartridge Catch Basins+3 Swales	C-2008					3							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
146	PDEV05-044	Empire Towers Building V	0210-205-17	2.97	Numerous Infiltration Trenches + 1-1000 Vortechs Unit	C-2/22/07	0.01	0.09	4.13	2				9				
147	PDEV05-047	Emporia Development	1049-141-26	0.48	1-Retention Basin	C-3/16/07	0.06	0.02	0.48	2		3						Would otherwise drain to Ely Basins
148	PDEV05-048	HMC World Headqtrs	0210-204-05	3.96	1-MaxWell + 2 Vegetated swales	C-1/31/07			3.96	688			1					
149	PDEV05-049	H Street Townhomes	1048-271-14	0.55	Pervious concrete + Vegetated swale	Active					1					1		Minimal infiltration capacity
150	PDEV05-052	Defoe Furniture 4 Kids	1049-384-13,17 to 35	8.29	1-CDS PMSU20_20 + 2-Veg Swales + 1 Ret/Infiltr Pit	C-3/29/07	0.04	0.04	7.05	2	2	1						Would otherwise drain to Ely Basins
151	PDEV05-062	Oak Hill Drive residential	0218-971-02,03 to 37	2.81	2-BioClean filters + Infiltration Trench	C-6/10/08	0.05	0.01	2.81	2				1				
152	PDEV05-066	Sterling Center	0210-551-40,41 to 49	19.12	3-Vortechs Units + 5 D-Raintank Systems+Inf Trench	C-9/16/08	0.13	0.19	9.36	2				1	5			

**Table 5-8**  
City of Ontario Storm Water Recharge

Map No.	Project No.	Name of Project	APN	Project Acres	Structural BMP	Status	Approximate Surface Area (ac)	Storage Volume (af)	Tributary Drainage Area (ac)	Infiltration Capacity (ft/day)	Vegetated Swale	Infiltration/ Detention Basin	Drywell	Infiltration Trench	Underground Chamber Vault	Pervious Pavement	Roof Well	Notes
153	PDEV05-071	Tech Packaging Expansion	0211-232-24	3.78	Vegetated Swale	C -					1							Minimal infiltration capacity
154	PDEV06-001	Ont Airport Towers Phs1	0210-192-13	1.45	1- 2000 + 1- 7000 Vortechs+NSBB10-14-20+CultecRecharger	C-8/4/08	0.36	1.11	12.00	2					2			
155	PDEV06-006	Ontario HolidayInnExpress	0218-061-56	2.72	1-MaxWell Plus, 2-Contech Cartridge Vaults	C-6/4/08			2.72	688			1					
156	PDEV06-007	B & G Plaza Improvements	1049-065-10	0.31	1-PMSU20_15 CDS Unit + Veg Swale	C-6/30/08					1							Minimal infiltration capacity. Would otherwise drain to Ely Basins.
157	M-425	Ontario Town Ctr A3/A4	1048-547-04,05 to 27 1048-547-29,30 to 53	6.52	5 - 4-6.5-72 NSBB Clarifiers+5 Infiltration trenches	Complete	0.00	0.00	5.42	2				5				Would otherwise drain to Ely Basins
158	PDEV06-011	Archibald Business Ctr	0211-275-52	11.13	1-Vortechs 5000 + Retention Basin	C-10/24/07	0.10	0.17	11.13	0		1						
159	PDEV06-015	Marketplace/Grove Condos	1051-151-04	10.84	2-CDS PMSU 30_30+2 Stormtech galleries+1-MaxWell	Active		0.49	10.84	860			1		2			Would otherwise drain to Grove Basin
160	PDEV06-023	Home Depot Center	1051-511-16	10.64	1-CDS Unit + 2-MaxWell Plus Drywells+1 Veg Swale	C-12/17/08			10.64	688	1		2					
161	PDEV06-024	Oakmont Greystone	0218-091-44	9.29	3 Retention Basins	C-12/17/07	0.21	2.03	18.54	3		3						
162	PDEV06-028	Kaiser Hospital Expansion	0113-285-13	30.00	3-CDS Units + 4 Retention Basins	Active	2.07	1.76	20.28	2		4						
163	PDEV06-032	Hofer Ranch, Phase 1	0211-261-13	28.47	1-Retention Basin+2-NSBBs+Vegetated Swale	C-2/22/08	0.05	1.22	28.47	49	1	1						
164	PDEV06-040	Ontario Airport Plaza	0110-092-15,16,17	4.19	1-MaxWell, 2-Vortechs Units + Swales	C-2/12/09	0.42	0.04	4.19	1	2		1					
165	PDEV06-041	Ontario/Pacific Indust Park	1050-151-17	4.67	2-Retention Basins + 1-MaxWell Plus Drywell	Active	0.18	0.25	4.67	5		2	1					Would otherwise drain to Ely Basins
166	PDEV06-045	Haven Business Center	0211-301-02	1.98	Vegetated Swales, Infiltration Basins+Stormchambers	C-12/5/07	0.16	0.18	1.98	2	2	2						
167	PDEV06-049	Big Yards Industrial Park	1049-181-12	4.50	4-Vortechs Units + 4 Retention/Infiltration Pits	C-10/24/07	0.09	0.14	4.50	64		4	12					Would otherwise drain to Ely Basins
168	PDEV06-055	Apex Constuction Co, Ph 2	0113-383-08	2.24	Retention/Infiltration Basin + MaxWell Drywell unit	Active	0.13	0.08	3.12	6		1	1					Would otherwise drain to Ely Basins
169	PDEV06-065	Chablis Warehouse	0238-133-46	3.34	1-Vortechs 2000 + 2-24" roof runoff infiltration pipes	Active	0.10	0.22	3.34	2							2	
170	PDEV06-066	Calif Commerce Center, IV	0211-281-57,58,59	96.22	Mult Vortechs units, 9 MaxWells, Basins and swales	Complete	0.75	0.60	94.76	8	5	1	9					
171	PDEV06-071	Event Ctr Overflow Parking	0210-204-08	11.86	2-Vortechs 4000 + 4 MaxWell Drywells	C-10/6/08			11.86	688			4					
172	PDEV07-003	Taco Bell T-50	1010-201-14	0.51	Pervious Pavement- parking stalls +1- Infiltration Basin	C-1/20/09	0.01	0.02	0.51	2		1				1		Would otherwise drain to Brooks Basin
173	PDEV07-012	Commercial Building	0110-301-07	8.24	1-Infiltration Trench + Pervious Pavement-Park stalls	C-12/23/08	0.01	0.02	8.24	2				1		1		Would otherwise drain to Turner Basins
174	PDEV07-017	Phase 2 CSI Senior Housing	0110-254-78	0.00	2-MaxWell Drywells + Swales	Active			0.00	688	2		2					
175	PDEV07-032	24-Hour Fitness Center	0218-021-64	2.75	1-STC 2400 Stormceptor+ 3-MaxWell Drywells	Active			2.75	688			3					
176	B200701603	Valley Power Systems	1050-211-09	2.33	1-MaxWell IV Drywell + 1-Fossil Filter at drywell inlet	C-3/17/08			2.33	688			1					Would otherwise drain to Ely Basins
177	PDEV07-050	The Colonies Marketplace	1051-081-02	4.11	1-Lg Underground Ret/Infiltr Basin + CDS Clarifier	Active	0.21	0.59	4.11	2		1						
178			1050-181-03	9.07	1 Infiltration Basin		0.05	0.30	9.07	2		1						Would otherwise drain to Ely Basins
179			1050-451-06	20.01	1 Infiltration Basin		0.19	1.79	20.01	2		1						Would otherwise drain to Grove Basin
180			1048-131-01	0.18	1 Dry Well					688			1					Would otherwise drain to Ely Basins
181			1048-241-18	4.44	1 Dry Well					688			1					Would otherwise drain to Ely Basins
182			1050-615-15	0.21	1 Dry Well					688			1					
183			1014-551-17	0.50	1 Dry Well					688			1					
184			1011-581-17	0.38	1 Dry Well					688			1					
185			0218-161-06	36.97	1 Dry Well					688			1					
<b>Total</b>							<b>13.0</b>	<b>24.3</b>	<b>918</b>		<b>168</b>	<b>63</b>	<b>124</b>	<b>68</b>	<b>30</b>	<b>16</b>	<b>6</b>	



**Table 5-9**  
**City of Rancho Cucamonga Storm Water Recharge**

<b>Map ID</b>	<b>Basin Name</b>	<b>Approximate Surface Area (ac)</b>	<b>Storage Volume (af)</b>	<b>Typical Percolation Rate (ft/day)</b>	<b>Tributary Drainage Area (ac)</b>	<b>Notes</b>
1	Dry Creek MS	3.00	NA	1.0	18	Perc rate assumed to equal TR 13527. Outside of Chino Basin. Would likely otherwise drain to Victoria Basin.
2	City Basin DRWG 1357-D	1.00	NA	1.6	61	Perc rate assumed to equal TR 16776. Would otherwise drain to Hickory Basin.
3	Grapeland Elementary School	0.71	NA	1.6	22	Perc rate assumed to equal TR 16776. Would otherwise drain to Hickory Basin.
4	TR 13527	4.35	10.4	1.0	174	Elev from 1708-1714 for debris storage. Outside of Chino Basin. Would likely otherwise drain to Victoria Basin.
5	TR 14139 Lots 1-5	1.38	NA	1.0	49	Perc rate assumed to equal TR 13527. Outside of Chino Basin. Would likely otherwise drain to Victoria Basin.
6	TR 15711 & TR 15711-1	5.26	NA	NA	147	Would otherwise drain to Hickory Basin.
7	TR 15912 LOT A	1.91	12	1.6	253	Would otherwise drain to Hickory Basin.
8	TR 16114 Lot 13	0.87	1	NA	14	Would otherwise drain to Victoria Basin
9	TR 16227-1	5.27	18.5	1.8	129	Volume is $Q_{10}$ first flush design. Outside of Chino Basin. Would likely otherwise drain to Victoria Basin.
10	TR 16279 Lots 78-79	1.34	5.5	1.1	73	Perc rate based on max loss rate. Would otherwise drain to Hickory Basin.
11	TR 16776 Lots 56-59	1.05	3.2	1.6	58	Would otherwise drain to Hickory Basin.
<b>Total</b>		<b>26.13</b>			<b>999</b>	

**Table 5-10**  
**Potential Recharge Basins**

Site No.	Map ID	Approximate Surface Area (ac)	Approximate Tributary Drainage Area (ac)	Notes
1	1.A	7.5		
2	1.B	7.6	240	
3	2.A	15.1	200	
4	3.A	4.3	18	DA is within DA for 3.C
5	3.B	-	-	Blue Diamond/Holliday Pit
6	3.C	11.3	112	DA does not include 3.C DA
7	3.D	6.5		
8	3.E	44.9	167	
9	4.A	4.3		
10	4.B	6.8	702	
11	4.C	5.7	102	
12	4.D	2.1	63	
13	4.E	2.2	32	
14	5.A	14.1	30	
15	5.B	4.9	34	
16	5.C	2.8	17	
17	5.D	6.1	180	DA combined with 5.F
18	5.E	5.9	17	
19	5.F	15.1	-	DA combined with 5.D
20	5.G	3.7	109	
21	5.H	9.5	104	
22	5.I	5.1	24	
23	5.J	10.8	111	
24	5.K	4.4	16	
25	5.L	5.3	25	
26	5.M	10.0	53	
27	5.N	45.6	141	
28	5.O	8.5	78	
29	6.A	9.3		
30	6.B	6.3	1,062	DA does not include 6.A & B DA
31	6.C	5.0	77	DA is within DA for 6.A & B
32	7.1.A	18.6	100	
33	7.1.B	13.1	156	
34	7.1.C	9.0	100	
35	7.1.D	13.7	139	
36	7.A	10.1	124	
37	7.B	7.6	632	
38	7.C	14.0	152	
39	7.D	15.8	295	
40	7.E	5.4		
41	7.F	7.2	195	
42	7.G	20.7	147	
43	8.A	17.7	152	
44	8.B	17.8	268	
45	8.C	5.5	43	
46	8.D	13.5	294	
47	9.1.A	4.9		
48	9.1.B	6.7	521	
49	9.1.C	7.9	184	
50	9.1.D	4.9	159	
51	9.RC	70.7	403	
<b>Total</b>		<b>576</b>	<b>7,780</b>	

Note:

Sites identified by John Van Dyk of Beno, Van Dyk & Owens.  
(DA) = Drainage Area

**Table 5-11**  
**First Flush Opportunities Based on Reported Discharge Measured at**  
**USGS 11073300 San Antonio Creek at Riverside Drive near Chino, CA**  
**Excluding Contributions from the OC-59 Turnout**

<b>Water Year</b>	<b>First Flush Opportunity<sup>(1)</sup></b>	<b>Daily Discharge (af)</b>	<b>Water Year Total of Daily Discharge</b>	<b>2-Hour Discharge (af)</b>	<b>Water Year Total of 2-Hour Discharge</b>
1999	1/4/1999	5.0	46.6	0.9	0.9
	6/2/1999	41.7		NA	
2000	10/14/1999	19.8	247.9	NA	NA
	4/17/2000	228.1		NA	
2001	10/22/2000	6.0	54.5	NA	42.5
	1/8/2001	6.9		3.7	
	7/5/2001	41.7		38.8	
2002	11/12/2001	25.8	42.6	21.6	27.9
	4/24/2002	8.9		6.3	
	8/1/2002	7.9		NA	
2003	11/8/2002	184.5	325.3	12.9	25.3
	2/11/2003	130.9		12.5	
	8/16/2003	9.9		NA	
2004	10/6/2003	7.9	353.1	NA	42.2
	12/25/2003	277.7		7.5	
	4/1/2004	41.7		34.7	
	5/21/2004	11.9		NA	
	9/1/2004	13.9		NA	
2005	4/28/2005	146.8	152.1	23.7	24.5
	9/15/2005	5.4		0.8	
2006	12/9/2005	12.7	105.5	5.0	53.4
	2/17/2006	27.8		22.7	
	5/22/2006	57.5		18.9	
	8/1/2006	7.5		6.8	
2007	10/14/2006	5.6	164.8	3.0	38.3
	11/27/2006	12.5		9.0	
	4/20/2007	99.2		20.6	
	9/22/2007	47.6		5.7	
2008	11/30/2007	355.0	422.1	107.7	127.8
	5/22/2008	47.6		3.7	
	7/12/2008	15.5		15.6	
	8/29/2008	4.0		0.8	
<b>Average</b>		<b>59.8</b>	<b>191.5</b>	<b>16.6</b>	<b>42.5</b>

Notes:

<sup>(1)</sup> A first flush opportunity refers to the first storm event of the season or a storm following a 30 day period lacking rainfall runoff.

**Table 5-12**  
**Estimated San Antonio Creek Discharge at Montclair Basin Inlet During First Flush Opportunities**  
**Based on Reported Discharge Measured at USGS 11073300 San Antonio Creek at Riverside Drive near Chino, CA**  
**Excluding Contributions from the OC-59 Turnout**

Water Year	First Flush Opportunity <sup>(1)</sup>	Reported Discharge at Chino Gage <sup>(2)</sup>			Adjusted Discharge at Chino Gage <sup>(3)</sup>		Estimated Discharge at Montclair Inlet <sup>(4)</sup>			
		Daily Discharge (af)	2-Hour Discharge (af)	2-Hour/ Daily Ratio	Daily Discharge (af)	2-Hour Discharge (af)	Daily Discharge (af)	Water Year Total of Daily Discharge (af)	2-Hour Discharge Foregone (af)	Water Year Total 2-Hour Discharge Foregone (af)
		2005	4/28/2005	146.8	23.7	0.2	146.8	23.7	44.1	45.7
	9/15/2005	5.4	0.8	0.1	5.4	0.8	1.6	0.2		
2006	12/9/2005	12.7	5.0	0.4	15.7	6.2	4.7	78.4	1.8	45.1
	2/17/2006	27.8	22.7	0.8	120.8	98.7	36.3		29.6	
	5/22/2006	57.5	18.9	0.3	117.1	38.5	35.2		11.6	
	8/1/2006	7.5	6.8	0.9	7.5	6.8	2.3		2.0	
2007	10/14/2006	5.6	3.0	0.5	5.6	3.0	1.7	84.5	0.9	19.3
	11/27/2006	12.5	9.0	0.7	16.9	12.2	5.1		3.7	
	4/20/2007	99.2	20.6	0.2	203.6	42.3	61.1		12.7	
	9/22/2007	47.6	5.7	0.1	55.6	6.7	16.7		2.0	
2008	11/30/2007	355.0	107.7	0.3	451.0	136.9	135.4	157.3	41.1	48.9
	5/22/2008	47.6	3.7	0.1	47.6	3.7	14.3		1.1	
	7/12/2008	15.5	15.6	1.0	21.4	21.6	6.4		6.5	
	8/29/2008	4.0	0.8	0.2	4.0	0.8	1.2		0.2	
<b>Average<sup>(5)</sup></b>							<b>26.1</b>	<b>106.7</b>	<b>8.6</b>	<b>37.7</b>

Notes:

<sup>(1)</sup> A first flush opportunity refers to the first storm event of the season or a storm following a 30 day period lacking rainfall runoff.

<sup>(2)</sup> USGS 11073300 San Antonio Creek at Riverside Drive near Chino, CA without contributions from OC-59 turnout.

<sup>(3)</sup> Discharge is adjusted based on actual daily diversions to regional recharge basins in the San Antonio Creek System.

<sup>(4)</sup> Discharge at the Montclair Basin 1 inlet is estimated based on drainage area percentage. (about 30% of the gaged watershed downstream of San Antonio Dam)

<sup>(5)</sup> Water year averages include only water years 2006 through 2008.

**Table 5-13**  
**Estimated San Antonio Creek Discharge at**  
**Montclair Basin Inlet During First Flush Opportunities**  
**Based on Wildermuth Environmental, Inc. Modeled Discharge**

<b>Water Year</b>	<b>First Flush Opportunity<sup>(1)</sup></b>	<b>Daily Discharge (af)</b>	<b>Water Year Total of Daily Discharge (af)</b>
1950	11/9/1949	10.1	72.2
	3/24/1950	62.1	
1951	10/27/1950	2.2	33.9
	1/10/1951	10.7	
	4/4/1951	5.0	
	9/28/1951	16.1	
1952	9/19/1952	6.9	6.9
1953	11/8/1952	14.7	190.4
	2/23/1953	38.7	
	4/28/1953	137.1	
1954	10/22/1953	0.6	38.3
	1/12/1954	37.7	
1955	11/11/1954	109.3	141.0
	4/22/1955	31.7	
1956	11/14/1955	35.5	45.8
	4/1/1956	0.6	
	7/25/1956	9.7	
1957	10/4/1956	2.2	5.8
	12/5/1956	2.4	
	4/17/1957	1.2	
1958	10/11/1957	43.8	141.2
	12/5/1957	77.6	
	5/12/1958	6.9	
	8/15/1958	5.0	
	9/24/1958	7.9	
1959	1/6/1959	184.7	265.2
	2/8/1959	36.1	
	4/26/1959	44.4	
1960	11/2/1959	0.2	26.2
	12/21/1959	26.0	
1961	10/9/1960	6.9	18.8
	1/25/1961	11.9	
1962	11/20/1961	38.5	43.0
	5/14/1962	4.6	
1963	10/18/1962	1.4	19.4
	12/24/1962	0.8	
	9/4/1963	17.3	
1964	1/18/1964	0.4	1.0
	6/9/1964	0.6	
1965	10/29/1964	8.5	13.9
	12/20/1964	2.0	
	7/30/1965	3.4	

**Table 5-13**  
**Estimated San Antonio Creek Discharge at**  
**Montclair Basin Inlet During First Flush Opportunities**  
**Based on Wildermuth Environmental, Inc. Modeled Discharge**

<b>Water Year</b>	<b>First Flush Opportunity<sup>(1)</sup></b>	<b>Daily Discharge (af)</b>	<b>Water Year Total of Daily Discharge (af)</b>
1966	11/14/1965	8.1	12.1
	3/24/1966	3.6	
	5/11/1966	0.4	
1967	11/6/1966	2.8	3.6
	9/28/1967	0.8	
1968	11/19/1967	163.6	171.6
	7/29/1968	7.9	
1969	10/2/1968	0.2	1.2
	7/11/1969	1.0	
1970	11/6/1969	92.6	93.2
	12/8/1969	0.4	
	6/10/1970	0.2	
1971	11/6/1970	1.2	12.3
	2/16/1971	9.5	
	4/14/1971	1.6	
1972	10/17/1971	1.6	7.7
	4/18/1972	3.2	
	8/12/1972	3.0	
1973	10/18/1972	2.0	2.0
1974	11/17/1973	4.2	4.6
	2/28/1974	0.2	
	5/16/1974	0.2	
1975	10/8/1974	0.2	0.2
1976	10/12/1975	0.8	9.9
	2/4/1976	6.5	
	4/3/1976	1.6	
	9/3/1976	1.0	
1977	10/23/1976	3.6	110.9
	12/30/1976	46.4	
	5/8/1977	27.4	
	8/17/1977	33.5	
1978	11/5/1977	11.5	23.4
	12/16/1977	0.2	
	8/5/1978	0.6	
	9/5/1978	11.1	
1979	10/20/1978	0.2	0.4
	5/1/1979	0.2	
1980	12/21/1979	3.8	3.8
1981	10/17/1980	0.8	49.0
	12/4/1980	9.5	
	1/11/1981	2.2	
	9/27/1981	36.5	

**Table 5-13**  
**Estimated San Antonio Creek Discharge at**  
**Montclair Basin Inlet During First Flush Opportunities**  
**Based on Wildermuth Environmental, Inc. Modeled Discharge**

<b>Water Year</b>	<b>First Flush Opportunity<sup>(1)</sup></b>	<b>Daily Discharge (af)</b>	<b>Water Year Total of Daily Discharge (af)</b>
1982	12/30/1981	16.5	18.4
	8/26/1982	2.0	
1983	8/9/1983	0.6	0.6
	11/12/1983	38.9	
1984	3/13/1984	0.8	43.2
	7/27/1984	0.8	
	9/17/1984	2.8	
1985	6/3/1985	0.4	1.8
	9/4/1985	1.4	
1986	10/7/1985	2.4	161.3
	1/13/1986	6.1	
	9/24/1986	152.7	
1987	11/17/1986	5.8	6.0
	7/17/1987	0.2	
1988	10/12/1987	1.4	171.4
	4/15/1988	54.5	
	6/30/1988	115.2	
	8/24/1988	0.2	
1989	11/13/1988	14.5	23.8
	4/26/1989	5.6	
	9/17/1989	3.8	
1990	10/22/1989	7.1	24.2
	11/26/1989	16.9	
	12/28/1989	0.2	
1991	11/19/1990	6.3	246.3
	1/3/1991	49.4	
	2/27/1991	190.4	
	8/11/1991	0.2	
1992	10/26/1991	26.0	32.7
	12/19/1991	5.4	
	7/6/1992	1.4	
1993	10/23/1992	8.1	84.5
	12/4/1992	5.4	
	6/5/1993	71.0	
1994	11/11/1993	6.3	15.9
	1/24/1994	5.2	
	4/25/1994	4.4	
1995	10/4/1994	4.6	123.8
	11/10/1994	12.5	
	6/16/1995	106.7	
1996	1/30/1996	14.5	14.5

**Table 5-13**  
**Estimated San Antonio Creek Discharge at**  
**Montclair Basin Inlet During First Flush Opportunities**  
**Based on Wildermuth Environmental, Inc. Modeled Discharge**

<b>Water Year</b>	<b>First Flush Opportunity<sup>(1)</sup></b>	<b>Daily Discharge (af)</b>	<b>Water Year Total of Daily Discharge (af)</b>
1997	10/28/1996	1.0	1.2
	9/15/1997	0.2	
1998	11/10/1997	12.1	30.7
	8/31/1998	18.6	
1999	11/8/1998	27.0	54.7
	1/20/1999	13.3	
	3/15/1999	4.6	
	6/2/1999	9.9	
2000	11/8/1999	0.8	49.6
	12/31/1999	4.4	
	4/17/2000	42.6	
	9/22/2000	1.8	
2001	10/26/2000	1.6	7.1
	1/8/2001	0.8	
	7/5/2001	1.2	
	9/25/2001	3.6	
2002	11/6/2001	23.0	43.0
	12/14/2001	11.9	
	4/24/2002	8.1	
2003	11/8/2002	110.1	175.1
	2/11/2003	64.9	
	7/28/2003	0.2	
2004	11/1/2003	12.5	12.5
2005	10/17/2004	104.1	123.6
	4/24/2005	2.4	
	9/20/2005	17.1	
2006	12/9/2005	1.0	34.5
	2/17/2006	2.4	
	5/22/2006	26.6	
	11/27/2006	4.6	
<b>Average</b>		<b>19.8</b>	<b>53.8</b>

Notes:

<sup>(1)</sup> A first flush opportunity refers to the first storm event of the season or a storm following a 30 day period lacking rainfall runoff.







**Table 5-14**  
**Cost Estimate for Conceptual Project Evaluation of**  
**RP3 Basin (No Excavation)**

<b>Description</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$125,000
2 <u>Channel Modification</u>				
Modify Channel for Conduit Inlet	35	Cu. Yds.	\$1,200	\$42,000
Modify Channel for Pneumatic Gate	1	Job	\$380,500	\$380,500
Pneumatic Gate	1	Job	\$140,000	\$140,000
3 <u>Conduit to Cell 1</u>				
Excavation	22,200	Cu. Yds.	\$5.00	\$111,000
Replace Compacted Fill	8,300	Cu. Yds.	\$15.00	\$124,500
8' x 10' RCB	950	Lin. Ft.	\$830	\$788,500
Coarse Drain Material	550	Ton	\$23	\$12,650
Automated Gate	1	Job	\$130,000	\$130,000
Concrete Inlet Structure	1	Job	\$24,000	\$24,000
Energy Dissipation Structure	1	Job	\$48,000	\$48,000
Road Demolition & Replacement	1	Job	\$25,000	\$25,000
4 <u>Conduit to Cell 3</u>				
Excavation	1,720	Cu. Yds.	\$5.00	\$8,600
Replace Compacted Fill	1,720	Cu. Yds.	\$15.00	\$25,800
8' x 10' RCB	820	Lin. Ft.	\$830	\$680,600
Coarse Drain Material	460	Ton	\$23	\$10,580
Automated Gate	1	Job	\$162,500	\$162,500
Concrete Inlet Structure	1	Job	\$48,000	\$48,000
Energy Dissipation Structure	1	Job	\$48,000	\$48,000
Channel Demolition & Replacement	1	Job	\$17,800	\$17,800
5 <u>Conduit to Cell 4</u>				
Excavation	720	Cu. Yds.	\$5.00	\$3,600
Replace Compacted Fill	720	Cu. Yds.	\$15.00	\$10,800
48" Dia. RCP	360	Lin. Ft.	\$335	\$120,600
Automated Gate	1	Job	\$30,000	\$30,000
Concrete Inlet Structure	1	Job	\$23,500	\$23,500
Energy Dissipation Structure	1	Job	\$23,500	\$23,500
6 <u>Spillway from Cell 1</u>				
48" Dia. RCP	360	Lin. Ft.	\$335	\$120,600
Concrete Inlet Structure	1	Job	\$23,500	\$23,500
Energy Dissipation Structure	1	Job	\$1,400	\$1,400
7 <u>Spillway from Cell 3</u>				
Excavate & Haul Offsite	300	Cu. Yds.	\$12.50	\$3,750
Concrete Channel & Weir	125	Cu. Yds.	\$500	\$62,500
Energy Dissipation Structure	1	Job	\$17,000	\$17,000
8 <u>Spillway from Cell 4</u>				
Excavate & Haul Offsite	200	Cu. Yds.	\$12.50	\$2,500
Concrete Channel & Weir	105	Cu. Yds.	\$500	\$52,500
Energy Dissipation Structure	1	Job	\$17,000	\$17,000
9 <u>Tie-In to Jurupa Pipeline</u>				
36" Dia. RCP	2,300	Lin. Ft.	\$270	\$621,000
Butterfly Valve	3	Job	\$19,700	\$59,100
Energy Dissipation Structure	3	Job	\$46,200	\$138,600
<b>Subtotal Direct Construction</b>				<b>\$4,284,500</b>
<b>Contingency @ 25%</b>				<b>\$1,071,100</b>
<b>Total Construction</b>				<b>\$5,355,600</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				\$536,000
<b>Total Engineering and Administration</b>				<b>\$536,000</b>
<b>Total Estimated Cost</b>				<b>\$5,891,600</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$5,890,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$383,300</b>

**Table 5-15**  
**Cost Estimate for Conceptual Project Evaluation of**  
**RP3 Basin (With Excavation)**

<b>Description</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Cost</b>	<b>Total Cost</b>
<b>Direct Construction Costs</b>				
1 <u>Mobilization</u>	1	Job	Lump Sum	\$477,000
2 <u>Reservoir Excavation</u>				
Excavate & Haul Offsite	762,000	Cu. Yds.	\$12.50	\$9,525,000
3 <u>Channel Modification</u>				
Modify Channel for Conduit Inlet	35	Cu. Yds.	\$1,200	\$42,000
Modify Channel for Pneumatic Gate	1	Job	\$380,500	\$380,500
Pneumatic Gate	1	Job	\$140,000	\$140,000
4 <u>Conduit to Cell 1</u>				
Excavation	22,200	Cu. Yds.	\$5.00	\$111,000
Replace Compacted Fill	8,300	Cu. Yds.	\$15.00	\$124,500
8' x 10' RCB	950	Lin. Ft.	\$830	\$788,500
Coarse Drain Material	550	Ton	\$23	\$12,650
Automated Gate	1	Job	\$130,000	\$130,000
Concrete Inlet Structure	1	Job	\$24,000	\$24,000
Energy Dissipation Structure	1	Job	\$226,800	\$226,800
Road Demolition & Replacement	1	Job	\$66,000	\$66,000
5 <u>Conduit to Cell 3</u>				
Excavation	66,500	Cu. Yds.	\$5.00	\$332,500
Replace Compacted Fill	66,500	Cu. Yds.	\$15.00	\$997,500
8' x 10' RCB	820	Lin. Ft.	\$830	\$680,600
Coarse Drain Material	460	Ton	\$23	\$10,580
Automated Gate	1	Job	\$162,500	\$162,500
Concrete Inlet Structure	1	Job	\$48,000	\$48,000
Energy Dissipation Structure	1	Job	\$48,000	\$48,000
Channel Demolition & Replacement	1	Job	\$218,000	\$218,000
6 <u>Conduit to Cell 4</u>				
Excavation	23,400	Cu. Yds.	\$5.00	\$117,000
Replace Compacted Fill	23,400	Cu. Yds.	\$15.00	\$351,000
48" Dia. RCP	420	Lin. Ft.	\$335	\$140,700
Automated Gate	1	Job	\$30,000	\$30,000
Concrete Inlet Structure	1	Job	\$23,500	\$23,500
Energy Dissipation Structure	1	Job	\$23,500	\$23,500
7 <u>Spillway from Cell 1</u>				
48" Dia. RCP	440	Lin. Ft.	\$335	\$147,400
Concrete Inlet Structure	1	Job	\$23,500	\$23,500
Energy Dissipation Structure	1	Job	\$1,400	\$1,400
8 <u>Spillway from Cell 3</u>				
Excavate & Haul Offsite	300	Cu. Yds.	\$12.50	\$3,750
Concrete Channel & Weir	125	Cu. Yds.	\$500	\$62,500
Energy Dissipation Structure	1	Job	\$17,000	\$17,000
9 <u>Spillway from Cell 4</u>				
Excavate & Haul Offsite	200	Cu. Yds.	\$12.50	\$2,500
Concrete Channel & Weir	105	Cu. Yds.	\$500	\$52,500
Energy Dissipation Structure	1	Job	\$17,000	\$17,000
9 <u>Tie-In to Jurupa Pipeline</u>				
36" Dia. RCP	2,300	Lin. Ft.	\$270	\$621,000
Butterfly Valve	3	Job	\$19,700	\$59,100
Energy Dissipation Structure	3	Job	\$46,200	\$138,600
<b>Subtotal Direct Construction</b>				<b>\$16,377,600</b>
<b>Contingency @ 25%</b>				<b>\$4,094,400</b>
<b>Total Construction</b>				<b>\$20,472,000</b>
<b>Engineering and Administration Costs</b>				
Engineering, Construction Inspection and Contract Admin. @ 10%				\$2,047,000
<b>Total Engineering and Administration</b>				<b>\$2,047,000</b>
<b>Total Estimated Cost</b>				<b>\$22,519,000</b>
<b>Total Estimated Cost - Rounded</b>				<b>\$22,520,000</b>
<b>Annual Cost - 30 Years @ 5% Interest</b>				<b>\$1,464,900</b>




-  Existing Recharge Basin
-  Approximate Boundary of Chino Basin
-  Major Channel



Source: Existing Recharge Basins per Wildermuth Environmental, Inc. (WEI), acquired February 6, 2009.  
 Chino Basin Boundary per WEI, acquired February 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 3, 2009.  
 Digital Elevation Model (DEM) per WEI, acquired February 2009.

**FIGURE 5-1**  
**Existing Regional Basins**

**Wagner & Bonsignore**  
CONSULTING ENGINEERS AND ARCHITECTS

**Figure 5-2**  
**Identified Storm Water Management BMPs**










- City of Chino Retention Site
- Existing Recharge Basin
- Approximate Boundary of Chino Basin
- Approximate Boundary of City of Chino
- Major Channel

Source: Chino Basin Boundary per Wildermuth Environmental, Inc. (WEL), acquired February 2009.  
 Existing Recharge Basins per WEL, acquired February 6, 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 City of Chino Boundary per California Spatial Information Library (CaSIL), acquired June 2001.  
 City of Chino Retention Sites based on inventory provided by City of Chino, February 2009.  
 Aerial photograph per County of San Bernardino, flown April 1, 2007.

Figure 5-3  
 City of Chino  
 Storm Water Recharge

Wagner & Bonsignore  
Water Resources Engineers & Scientists

-  City of Fontana Retention Site
-  Existing Regional Basin
-  Approximate Boundary of Chino Basin
-  Approximate Boundary of City of Fontana
-  Major Channel

Source: Chino Basin Boundary per Wil dermuth Environmental, Inc. (WEI), acquired February 2009.  
 Existing Regional Basins per WEI, acquired February 2009.  
 City of Fontana Retention Basins per City of Fontana, acquired March 2009.  
 City of Fontana Boundary per California Spatial Information Library (CaSIL), acquired June 2001.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 3, 2009.  
 Aerial photograph per San Bernardino County, flown April 1, 2007.






Figure 5-4  
 City of Fontana  
 Storm Water Recharge  
 Wagner & Bonsignore  
 Civil, Survey, Geotechnical, & Construction




- City of Montclair Retention Site
- Existing Regional Basin
- Approximate Boundary of Chino Basin
- Approximate Boundary of City of Montclair
- Major Channel

Source: Chino Basin Boundary per Wildermuth Environmental, Inc. (WEI), acquired May 2009.  
 Existing Regional Basins per WEI, acquired February 2009.  
 City of Montclair Boundary per California Spatial Information Library (CaSIL), acquired June 2001.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 City of Montclair Retention Sites per City of Montclair, acquired April 2009.  
 Aerial photograph per County of San Bernardino, flown April 1, 2007.

Figure 5-5  
 City of Montclair  
 Storm Water Recharge

**Wagner & Bonsignore**  
 Consulting, Civil, and Environmental Engineers



- City of Ontario Retention Projects
- Existing Regional Basin
- Approximate Boundary of Chino Basin
- Major Channel

Source: Chino Basin boundary per Wil dermuth Environmental, Inc. (WEI), acquired February 2009.  
 Existing Regional Basins per WEI, acquired February 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 City of Ontario Retention Projects based on documents received from City of Ontario, June 2009.  
 City of Ontario Boundary per California Spatial Information Library (CaSIL), acquired June 2001.  
 Aerial photograph per County of San Bernardino, flown April 1, 2007.

Figure 5-6  
 City of Ontario  
 Storm Water Recharge





FIGURE 5-7

City of Rancho Cucamonga Storm Water Recharge

Wagner & Bonsignore  
Consulting Civil Engineers, Architects, Planners, Inc.

Source: Chino Basin boundary per Wildermuth Environmental, Inc. (WEL), acquired February 2009.  
 Existing Recharge Basins per WEL, acquired February 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 City of Rancho Cucamonga Retention Sites based on maps acquired from the City of Rancho Cucamonga, May 2009.  
 City of Rancho Cucamonga Boundary per California Spatial Information Library (CaSIL), acquired June 2001.  
 Aerial photograph per County of San Bernardino, flown April 1, 2007.

- Potential Recharge Site
- Approximate Boundary of Chino Basin
- Approximate City Boundary
- Existing Regional Basin
- Major Channel

Source: Chino Basin Boundary per Wildermuth Environmental, Inc. (WEI), acquired February 2009.  
 City Boundaries per California Spatial Information Library (CaSIL), acquired June 2001.  
 Potential Recharge Sites per Beno, Van Dyk & Owens, dated January 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 Aerial photograph per San Bernardino County, flown April 1, 2007.






Figure 5-8  
 Potential Recharge  
 Basin Locations  
 Wagner & Bonsignore


**Figure 5-9**  
**Upland and Montclair (1-4) Basin Positive Flow by Percentile**  
**October 1949 Through December 2006**








**Note:**

<sup>(1)</sup> Based on modeled data from Wildermuth Environmental Inc.

<sup>(2)</sup> Flows shown according to percentile of non-zero flows, 91.3% of the estimated daily flows for the period of record equal 0 cfs.




-  USGS Streamgage
-  Approximate Watershed Boundary of USGS 11073300
-  Approximate Watershed Boundary of the Montclair Basins
-  Approximate Boundary of Chino Basin
-  Major Channel

Note: Drainage area boundaries delineated include urban runoff from storm drains.

Source: USGS Streamgage per U.S. Geological Survey, April 2006.  
 Existing Recharge Basins per Wildernuth Environmental, Inc. (WEI), acquired February 2009.  
 Chino Basin Boundary per WEI, acquired February 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.


Figure 5-10  
 Chino Basin Water Conservation District  
 Approximate Drainage Area Boundaries below San Antonio Dam for USGS 11073300 and Montclair Basins  
 Wagner & Bonsignore  
 Consulting Geol. Engineers, & Co., Ltd.

FIGURE 5-11




ESTIMATED DISCHARGE OF SAN ANTONIO CREEK AT MONTCLAIR BASINS AND  
POTENTIAL MONTCLAIR BASIN DIVERSIONS  
WATER YEAR 2006

FIGURE 5-12




ESTIMATED DISCHARGE OF SAN ANTONIO CREEK AT MONTCLAIR BASINS AND  
POTENTIAL MONTCLAIR BASIN DIVERSIONS  
WATER YEAR 2007

FIGURE 5-13




ESTIMATED DISCHARGE OF SAN ANTONIO CREEK AT MONTCLAIR BASINS AND  
POTENTIAL MONTCLAIR BASIN DIVERSIONS  
WATER YEAR 2008

**Figure 5-14**  
**Increase in Capturable Runoff Resulting from Increased Inlet Capacity and/or Storage Capacity**  
**Montclair Basins 1 through 4**  
**Based on Data Modeled by Wildermuth Environmental, Inc.**







**Figure 5-15**  
**Increase in Capturable Runoff Resulting from Increased Storage Capacity**  
**Turner Basins 1 through 4**  
**Based on Daily Cucamonga Creek Runoff at Turner 1 Modeled by Wildermuth Environmental, Inc.**



**Figure 5-16**  
**Estimated Discharge Potentially Foregone in San Antonio Creek System**  
**for Each First Flush Opportunity from April 2005 through September 2008**  
**Based on San Antonio Creek Flow Estimated at the Montclair Basin Inlet**







**Figure 5-17**  
**Estimated Total Water Year Discharge of Storm Events**  
**Occurring on Days Corresponding to First Flush Opportunities**  
**Based on San Antonio Creek Flow Estimated at the Montclair Basin Inlet**




\* Data available April 2005 through September 2008.




-  USGS Stream Gauge
-  Existing Recharge Basin
-  Approximate Boundary of Chino Basin
-  Major Channel

Source: Existing Recharge Basins per Wildemuth Environmental, Inc. (WEI), acquired February 2009.  
 Chino Basin Boundary per WEI, acquired February 2009.  
 Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009.  
 Digital Elevation Model per WEI, acquired February 2009.  
 USGS Stream Gages per U.S. Geological Survey, Dated April 2006.

Figure 5-18  
 Chino Basin Water Conservation District  
 Map Showing  
 USGS 11073300  
 and  
 USGS 11073495



PLAN VIEW




SECTION

FIGURE 5-19  
CONCEPTUAL OFF-CHANNEL  
STORAGE RESERVOIR  
PROJECT SCHEMATIC

CHINO BASIN WATER  
CONSERVATION DISTRICT

Wagner & Bonsignore  
Consulting Civil Engineers, A Corporation

**Figure 5-20**  
**Measured Seasonal Discharge USGS 11073300 San Antonio Creek at Riverside Dr., near Chino, CA**  
**Excluding Contributions from OC-59 Releases**  
**(only complete seasons shown)**





**OPTION 1**




**OPTION 2**




**OPTION 3**



**OPTION 4**



Source: Major Channels per U.S. Geological Survey, National Hydrography Dataset (<http://nhd.usgs.gov>), accessed March 2009. Aerial photograph per San Bernardino County, flown April 1, 2007.



Existing Basins


Figure 5-21

Chino Basin Water Conservation District

Lower Cucamonga and Chris Basins Enhancement Options


Wagner & Bonsignore  
Consulting Civil Engineers, A Corporation

**Figure 5-22**  
**Measured Seasonal Discharge**  
**USGS 11073495 Cucamonga Creek near Mira Loma, CA**  
 (only complete seasons shown)






**Figure 5-23**  
**Total Inflow to Wineville Basin (NDY13)**  
**Positive Flow Daily Frequency Distribution**  
**October 1949 Through September 1999**




**Notes:**

- (1) Based on modeled data from Wildermuth Environmental Inc.
- (2) Flows shown according to percentile of non-zero flows, 47.8% of the estimated daily flows for the period of record equal 0 cfs.

**Figure 5-24**  
**Seasonal Wineville Basin Inflow**  
**Based on Runoff Modeled by Wildermuth Environmental, Inc.**




**Figure 5-25**  
**Inflow to Jurupa Basin (NSS72)**  
**Positive Flow Daily Frequency Distribution**  
**October 1949 Through September 1999**



**Notes:**

- (1) Based on modeled data from Wildermuth Environmental Inc.
- (2) Flows shown according to percentile of non-zero flows, 71.1% of the estimated daily flows for the period of record equal 0 cfs.

**Figure 5-26**  
**Seasonal Jurupa Basin Inflow**  
**Based on Runoff Modeled by Wildermuth Environmental, Inc.**






**OPTION 1**



**OPTION 2**



Aerial photograph per San Bernardino County; flown April 1, 2007.


Figure 5-27

Chino Basin Water  
Conservation District

RP3 Basin Enhancement Options

Wagner & Bonsignore  
Consulting Civil Engineers, A Corporation


**Figure 5-28**  
**Declez Channel at Diversion to RP3 Basin (NSS82)**  
**Positive Flow Daily Frequency Distribution**  
**October 1949 Through September 1999**




**Notes:**

- (1) Based on modeled data from Wildermuth Environmental Inc.
- (2) Flows shown according to percentile of non-zero flows, 90.8% of the estimated daily flows for the period of record equal 0 cfs.

**Figure 5-29**  
**Seasonal Flow in Declez Channel at RP3 Diversion**  
**Based on Runoff Modeled by Wildermuth Environmental, Inc.**




**Figure 5-30**





**Figure 5-31**




**LEGEND**  
 \_\_\_\_\_ PIPELINE  
 ..... EXISTING PIPELINE  
 --- EXISTING CHANNEL

Recharge Distribution System  
 Pumping Schematic


Phase I

**Wagner-Bonsignature**  
 Consulting Civil Engineers, Inc.

Figure 5-32



**Figure 5-33**



**LEGEND**  
 \_\_\_\_\_ PIPELINE  
 ..... EXISTING PIPELINE  
 - - - EXISTING CHANNEL

Recharge Distribution System  
 Pumping Schematic

Phase II

**Wagner** **Bonsignore**  
 Consulting Civil Engineers & Architects

Figure 5-34




Figure 5-35




Figure 5-36





Figure 5-37



**LEGEND**  
 \_\_\_\_\_ PIPELINE  
 ..... EXISTING PIPELINE  
 --- EXISTING CHANNEL

Recharge Distribution System  
 Pumping Schematic

Phase IV

**Wagner-Bonsignature**  
 Consulting Civil Engineers & Architects

Figure 5-38







Figure 5-39




Recharge Distribution System  
Pumping Schematic

Phase V

Wagner <sup>®</sup> Bonsignore  
Civil Engineers & Architects

- LEGEND**
- PIPELINE
  - ..... EXISTING PIPELINE
  - - - - EXISTING CHANNEL



NOTE:  
TOPOGRAPHY PROVIDED BY WILDERMUTH ENVIRONMENTAL INC., NOVEMBER 2009.



File: Preliminary Wineville Basin  
 Name: Embankment Rev2.dwg  
 Scale: Fraction 1  
 Plot Date: 04-21-2010

**PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

**DRAFT**

Designed By: *D.P. LOUNSBURY*  
 Drawn By: *J. HERBERT/  
P. INTARATH*  
 Checked By: *R.C. WAGNER*  
 Approved By:

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation

2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Fx: 916-448-3866



CHINO BASIN WATER CONSERVATION DISTRICT

CHINO BASIN RECHARGE MASTER PLAN UPDATE  
CONCEPTUAL PROJECT EVALUATION FOR


WINEVILLE BASIN

SHEET  
 1  
 OF  
 2  
 SHEETS

FIGURE 5-40



TYPICAL EMBANKMENT RECONSTRUCTION SECTION



CONCEPTUAL SPILLWAY GATE SECTION  
NOT TO SCALE

File: Preliminary Wineville Basin  
Name: Employment Rezoning  
Scale: 1  
Plot Date: 04-21-2010

PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

DRAFT

Designed By: D.P. LOUNSBURY  
Drawn By: J. HERBERT/  
P. INTARATH  
Checked By: R.C. WAGNER  
Approved By:

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation

2151 River Plaza,  
Suite 100  
Sacramento, CA 95833  
Ph: 916-441-6850  
Fx: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT

CHINO BASIN RECHARGE MASTER PLAN UPDATE  
CONCEPTUAL PROJECT EVALUATION FOR

WINEVILLE BASIN


SHEET  
2  
OF  
2  
SHEETS

**Figure 5-42**  
**DSOD – Dam Jurisdictional Size Chart**



**Figure 5-43**  
**Wineville Basin Evaluated Alternative Schematic**





NOTE:  
TOPOGRAPHY PROVIDED BY WILDERMUTH ENVIRONMENTAL, INC., NOVEMBER 2009.



File Name: Preliminary Lower Day Basin Enhancement Reviewing  
 Sheet Factor: 1  
 Date: 05-21-2010  
 DWG: DWG

**PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

DRAFT


Designed By: D.P. LOUNSBURY  
 Drawn By: J. HERBERT/  
 P. INTARATH  
 Checked By: R.C. WAGNER  
 Approved By:

**Wagner & Bonsignore**  
 Consulting Civil Engineers, A Corporation  
 2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Fx: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT  
 CHINO BASIN RECHARGE MASTER PLAN UPDATE  
 CONCEPTUAL PROJECT EVALUATION  
 LOWER DAY BASIN

SHEET  
**1**  
 OF  
 2  
 SHEETS


FIGURE 5-44




TYPICAL EMBANKMENT RECONSTRUCTION SECTION




AREA/CAPACITY CURVES



PLAN




PROFILE



SECTION A

SECTION B

DIVERSION CHANNEL IMPROVEMENTS



DRAFT

Designed By: D.P. LOUNSBURY  
 Drawn By: J. HERBERT/  
 P. INTARATH  
 Checked By: R.C. WAGNER  
 Approved By:

**Wagner & Bonsignore**  
 Consulting Civil Engineers, A Corporation

2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Fx: 916-448-3866

CHINO BASIN WATER CONSERVATION DISTRICT

CHINO BASIN RECHARGE MASTER PLAN UPDATE  
 CONCEPTUAL PROJECT EVALUATION

LOWER DAY BASIN


SHEET  
 2  
 OF  
 2  
 SHEETS

File: Preliminary Lower Day Basin Enhancement Rev.dwg  
 Scale: 1"=40'  
 Date: 05-21-2010

PRELIMINARY  
 NOT FOR CONSTRUCTION  
 AND  
 SUBJECT TO REVISION


REVISIONS			
REF.	DESCRIPTION	APVD.	DATE


**Figure 5-46**  
**Lower Day Basin Evaluated Alternative Schematic**





**Figure 5-47**  
**Jurupa Basin Evaluated Alternative Schematic**





NOTE:  
TOPOGRAPHY PROVIDED BY WILDERMUTH ENVIRONMENTAL INC., NOVEMBER 2009.



**DRAFT**

File Name: RP3 Design Rev3.dwg  
Scale: As Shown  
Plot Date: 04-21-2010  
Plot Time: 1:00:00

**PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE


Designed By: D.P. LOUNSBURY  
Drawn By: J. HERBERT/  
P. INTARATH  
Checked By: R.C. WAGNER  
Approved By: \_\_\_\_\_

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation  
2151 River Plaza,  
Suite 100  
Sacramento, CA 95833  
Ph: 916-441-6850  
Fx: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT  
CHINO BASIN RECHARGE MASTER PLAN UPDATE  
CONCEPTUAL PROJECT EVALUATION  
RP3 BASIN

SHEET  
**1**  
OF  
2  
SHEETS


FIGURE 5-48




PROFILE OF DECLEZ CREEK DIVERSION CONDUIT  
NOT TO SCALE




CONCEPTUAL DECLEZ CHANNEL GATE SECTION  
NOT TO SCALE




CAPACITY CURVES (WITH BASIN EXCAVATION)



CAPACITY CURVES (NO BASIN EXCAVATION)



CONVEYANCE SYSTEM SCHEMATIC - NO EXCAVATION  
NOT TO SCALE



CONVEYANCE SYSTEM SCHEMATIC - WITH EXCAVATION  
NOT TO SCALE

RP3 Design Rev3.dwg  
1  
04-21-2010  
PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

DRAFT


Designed By: D.P. LOUNSBURY  
Drawn By: J. HERBERT/  
P. INTARATH  
Checked By: R.C. WAGNER  
Approved By:

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation  
2151 River Plaza,  
Suite 100  
Sacramento, CA 95833  
Ph: 916-441-6850  
Fx: 916-448-3866

CHINO BASIN WATER CONSERVATION DISTRICT  
CHINO BASIN RECHARGE MASTER PLAN UPDATE  
CONCEPTUAL PROJECT EVALUATION  
RP3 BASIN


SHEET  
2  
OF  
2  
SHEETS

**Figure 5-50**  
**RP3 Basin Evaluated Alternative Schematic**



**Figure 5-51**  
**Vulcan Pit Evaluated Alternative Schematic**





PROPERTY BOUNDARY ESTIMATED FROM AERIAL PHOTOGRAPH. BASIN EXCAVATIONS AND FILLS SET BACK FROM PROPERTY BOUNDARY ±20'.

DAM CREST ELEV. 740 EMBANKMENT TO BE UNDER JURISDICTION OF CALIFORNIA DIVISION OF SAFETY OF DAMS

EMERGENCY OUTLET AS REQUIRED BY CALIFORNIA DIVISION OF SAFETY OF DAMS

BASIN OUTFLOW SPILLWAY TO CUCAMONGA CREEK CHANNEL

CHRIS BASIN INLET REMOVE AND RELOCATE

BENCHES REQUIRED FOR SLOPES GREATER THAN 30' NOT SHOWN FOR CONCEPTUAL PROJECT EVALUATION

GRADING-BASIN BOTTOM FOR STORAGE OR RECHARGE TO BE DETERMINED

EXISTING LOWER CUCAMONGA BASINS

DEMOLISH EXISTING CHANNEL

CUCAMONGA CREEK CHANNEL

SOUTHERN CALIFORNIA-EDISON HIGH VOLTAGE TOWERS

EXISTING BURROWING OWL MITIGATION SITE

MAINTAIN 50' CLEARANCE TYPICAL

PUMP STATION

REVIEW EXISTING DRAIN INLET TO DETERMINE OPERATIONAL RESTRICTIONS

CUCAMONGA CREEK CHANNEL BASIN INFLOW SPILLWAY

CHINO AVENUE


CHRIS BASIN

RECONSTRUCT EXISTING EMBANKMENT AS REQUIRED, TYPICAL

MAXIMUM STORAGE ELEV. 731

TRANSMISSION PIPELINE TO WENTVILLE

PLAN



NOTE:

TOPOGRAPHY BASED ON DIGITAL ELEVATION MODEL OBTAINED FROM WILDERMUTH ENVIRONMENTAL, INC., NOVEMBER 2009.

File: LC\_Conceptual\_Basin\_Enhancement  
Name: Option 1 (FINAL-PCET).dwg  
Scale: 1  
Plot Date: 05-21-2010

**PRELIMINARY  
NOT FOR CONSTRUCTION  
AND  
SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

**DRAFT**

Designed By	D.P. LOUNSBURY
Drawn By	J. HERBERT/ P. INTARATH
Checked By	R.C. WAGNER
Approved By	

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation

2151 River Plaza,  
Suite 100  
Sacramento, CA 95833  
Ph: 916-441-6850  
Ex: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT

CHINO BASIN RECHARGE MASTER PLAN UPDATE  
CONCEPTUAL PROJECT EVALUATION


LOWER CUCAMONGA BASIN

SHEET  
1  
OF  
2  
SHEETS

FIGURE 5-52




AREA/CAPACITY CURVES




\* CHANNEL FLOW RATE UNKNOWN. FLOW RATE OF 20,000 CFS USED FOR CONCEPTUAL EVALUATION PURPOSES ONLINE.


PLAN OF OUTFLOW SPILLWAY



PLAN OF INFLOW SPILLWAY



OUTFLOW SPILLWAY HYDRAULIC SCHEMATIC



INFLOW SPILLWAY HYDRAULIC SCHEMATIC

File: LC Conceptual Basin Enhancement  
 Name: Division 1 (DMA-1607).dwg  
 Scale: 1  
 Plot Date: 05-21-2010

**PRELIMINARY  
 NOT FOR CONSTRUCTION  
 AND  
 SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

**DRAFT**

Designed By: D.P. LOUNSBURY  
 Drawn By: J. HERBERT/  
 P. INTARATH  
 Checked By: R.C. WAGNER  
 Approved By: NAME

**Wagner & Bonsignore**  
 Consulting Civil Engineers, A Corporation

2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Ex: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT

CHINO BASIN RECHARGE MASTER PLAN UPDATE  
 CONCEPTUAL PROJECT EVALUATION


LOWER CUCAMONGA BASIN

SHEET  
 2  
 OF  
 2  
 SHEETS

**Figure 5-54**  
**Lower Cucamonga Basin Evaluated Alternative Schematic**







NOTE:  
 TOPOGRAPHY BASED ON DIGITAL ELEVATION MODEL OBTAINED FROM  
 WILDERMUTH ENVIRONMENTAL, INC., NOVEMBER 2009.



Title: Proposed San Sevaire  
 Channel Basin Recharge  
 Scale: 1" = 100'  
 Plot Date: 04-21-2010

**PRELIMINARY  
 NOT FOR CONSTRUCTION  
 AND  
 SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

DRAFT

Designed By: D.P. LOUNSBURY  
 Drawn By: J. HERBERT/  
 P. INTARATH  
 Checked By: R.C. WAGNER  
 Approved By:


**Wagner & Bonsignore**  
 Consulting Civil Engineers, A Corporation

2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Ex: 916-448-3866


CHINO BASIN WATER CONSERVATION DISTRICT  
 CHINO BASIN RECHARGE MASTER PLAN UPDATE  
 CONCEPTUAL PROJECT EVALUATION  
 LOWER SAN SEVAIRE BASIN

SHEET  
 1  
 OF  
 2  
 SHEETS

FIGURE 5-55




TYPICAL SECTION




PLAN OF BASIN OUTFLOW SPILLWAY


\* FLOW VALUES AS SHOWN ON RECORD DRAWING OF SBCFCD, PLANS FOR THE CONSTRUCTION OF "SAN SEVAINE & ETIWANDA CREEK CHANNELS FROM VICTORIA AVENUE TO FOOTHILL BOULEVARD"




PLAN OF BASIN INLET CHANNEL ENERGY DISSIPATION STRUCTURE



AREA/CAPACITY CURVES



BASIN OUTFLOW SPILLWAY HYDRAULIC SCHEMATIC



BASIN INLET CHANNEL HYDRAULIC SCHEMATIC

File: Proposed San Sevaire  
 Name: Chino Basin Rev.2.dwg  
 Scale: 1  
 Printer: 1  
 Date: 04-21-2010

**PRELIMINARY  
 NOT FOR CONSTRUCTION  
 AND  
 SUBJECT TO REVISION**

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

**DRAFT**

Designed By: D.P. LOUNSBURY  
 Drawn By: J. HERBERT/  
 P. INTHARATH  
 Checked By: R.C. WAGNER  
 Approved By:



**Wagner & Bonsignore**  
 Consulting Civil Engineers, A Corporation  
 2151 River Plaza,  
 Suite 100  
 Sacramento, CA 95833  
 Ph: 916-441-6850  
 Fx: 916-448-3866

CHINO BASIN WATER CONSERVATION DISTRICT  
 CHINO BASIN RECHARGE MASTER PLAN UPDATE  
 CONCEPTUAL PROJECT EVALUATION  
 LOWER SAN SEVAINE BASIN


SHEET  
 2  
 OF  
 2  
 SHEETS

**Figure 5-57**  
**Lower San Sevaive Basin Evaluated Alternative Schematic**





TYPICAL EMBANKMENT RECONSTRUCTION SECTION



AREA/CAPACITY CURVES

File Name Declez.dwg	Sheet F001	Date 04-21-2010
-------------------------	---------------	--------------------

REVISIONS			
REF.	DESCRIPTION	APVD.	DATE

Designed By D.P. LOUNSBURY
Drawn By J. HERBERT/ P. INTARATH
Checked By R.C. WAGNER
Approved By

**Wagner & Bonsignore**  
Consulting Civil Engineers, A Corporation

2151 River Plaza,  
Suite 100  
Sacramento, CA 95833  
Ph: 916-441-6850  
Fx: 916-448-3866

CHINO BASIN WATER CONSERVATION DISTRICT
CHINO BASIN RECHARGE MASTER PLAN UPDATE CONCEPTUAL PROJECT EVALUATION FOR
DECLEZ BASIN

SHEET 1 OF 1 SHEETS
---------------------------------

**Figure 5-59**  
**Declez Basin Evaluated Alternative Schematic**



## Section 6 – Supplemental Water Recharge Enhancement Opportunities

---

### 6.1 Introduction

This section describes the existing supplemental water recharge conditions, challenges to meeting future replenishment obligations, and ways to meet future replenishment obligations that are consistent with the Judgment and the Peace Agreement. This section specifically addresses the RMPU requirements set forth in items 1, 5, 6, 8 and 9 of the November 2007 Special Referee’s report to the Court:

1. Baseline conditions must be clearly defined and supported by technical analysis. The baseline definition should encompass factors such as pumping, demand, recharge capacity, total Basin water demand, and availability of replenishment water.
5. Total demand for groundwater should be forecast for 2015, 2020, 2025, and 2030. The availability of imported water for supply and replenishment, and the availability of recycled water should be forecast on the same schedule. The schedules should be refined in each Recharge Master Plan update. Projections should be supported by thorough technical analysis.
6. The Recharge Master Plan must include a detailed technical comparison of current and projected groundwater recharge capabilities and current and projected demands for groundwater. The Recharge Master Plan should provide guidance as to what should be done if recharge capacity cannot meet or is projected not to be able to meet replenishment needs. This guidance should detail how Watermaster will provide sufficient recharge capacity or undertake alternative measures so that Basin operation in accordance with the Judgment and the Physical Solution can be resumed at any time.
8. Contain recharge estimations and summaries of the projected water supply availability as well as the physical means to accomplish the recharge projections.
9. Reflect an appropriate schedule for planning, design, and physical improvements as may be required to provide reasonable assurance that sufficient Replenishment capacity exists to meet the reasonable projections of Desalter Replenishment obligations following the implementation of Basin Re-Operation.

For item 1, all issues except recharge capacity and the availability of replenishment water were discussed in Section 4. The recharge capacity of existing recharge basins and ASR wells and the availability of replenishment water are discussed in this section. For item 5, the demand for groundwater was presented in Section 4. The availability of recycled and imported water is discussed in this section. Items 6, 8, and 9 are addressed completely in this section.

## 6.2 Replenishment Requirement

Watermaster purchases replenishment water when one or more of the parties overproduces. Watermaster has traditionally met its replenishment obligations by purchasing imported water from Metropolitan (replenishment water service) and unproduced groundwater from the appropriators. In the recent past, Metropolitan was typically able to supply all of the replenishment needs in its service area with replenishment water service, which was estimated to be available seven out of ten years.<sup>3</sup> Recent court rulings regarding endangered species and the drought have severely limited the ability of Metropolitan and other SWP contractors to obtain SWP water. In 2008, Metropolitan provided a revised replenishment water service forecast, projecting that replenishment water would be available three out of ten years.<sup>4</sup> In response to the current drought and environmental limitations on Delta exports, Metropolitan has depleted the water stored in its various storage programs, and it is likely that when surplus water is available, some or all of it will be used to refill Metropolitan's storage assets prior to being used for groundwater replenishment.<sup>5</sup> The Chino Basin and the other major groundwater basins that depend on replenishment water service within Metropolitan's service area may become seriously overdrafted in the next ten to twenty years unless other replenishment supplies are acquired, groundwater production is reduced, or both. Watermaster has an unbounded obligation to acquire replenishment water (literal reading of the Judgment, confirmed at the Watermaster 2006 and 2009 Strategic Planning Meetings) to satisfy replenishment obligations. Because of the projected shortfall in replenishment water service from Metropolitan, Watermaster will have to acquire new non-traditional supplemental water supplies for replenishment. These non-traditional supplemental water supplies could consist of Metropolitan Tier 1 and Tier 2 service waters, non-IEUA recycled water, and other imported supplies from the Central Valley, the Colorado River, and other areas.

The following assumptions were made regarding the availability of non-traditional supplemental water supplies:

- Non-traditional imported supplemental water supplies will be conveyed to the Chino Basin through Metropolitan infrastructure and the ADC Pipeline.
- Non-traditional imported supplemental water supplies from the Central Valley and the Colorado River will be available six out of ten years, corresponding to years when State Water Project allocation is less than or equal to 75 percent.
- Deliveries to the Chino Basin through Metropolitan infrastructure and the ADC Pipeline will be limited to a part of the facilities unused capacity.
- New non-traditional imported supplemental water supplies will not be available until 2013 to allow adequate time for planning and acquisition.

Traditionally, Watermaster has purchased replenishment water in arrears to satisfy its replenishment obligation. That is, Watermaster determines the replenishment obligation after

---

<sup>3</sup> Based on Metropolitan's IRPSIM analysis using the SWP Delivery Reliability Report, 2005 (DWR, 2005).

<sup>4</sup> Based on Metropolitan's IRPSIM analysis using the SWP Delivery Reliability Report, 2007 (DWR, 2008).

<sup>5</sup> See Appendix E.

the conclusion of a fiscal year and purchases replenishment water to cover this obligation in the subsequent year. Given the current and expected future constraints on the availability of supplemental water for replenishment, it is possible that a large cumulative unmet replenishment obligation (CURO) will occur and could grow so large that Watermaster may not be able to catch up. This possibility was first predicted in the original engineering work for the Peace II process and reported in *2007 CBWM Groundwater Model Documentation and Evaluation of the Peace II Project Description* (WEI, 2007b). Furthermore, it was discussed at Watermaster’s 2009 Strategic Planning Meeting, and the consensus opinion of the Watermaster parties at that meeting was that Watermaster would do whatever it takes to ensure that projected groundwater production could be sustained with acquisitions of supplemental water for replenishment. In implementation, this means that Watermaster will have to purchase and recharge supplemental water when available and in advance of replenishment obligations, referred to herein as “preemptive replenishment.” This will require Watermaster to use some of the available storage space in the Chino Basin to store supplemental water in advance of overproduction.

Table 6-1 shows the projected MZ1 recharge requirement and replenishment obligation from Table 4-2 and an assumed recharge schedule based on imported water being available six out of ten years and the CURO. Watermaster will have to acquire about 710,000 acre-ft of imported water for recharge between 2010 and 2035 to meet its projected recharge obligations. Figure 6-1 shows an example of recharge water deliveries to the Chino Basin, using the assumptions described above. The recharge water delivery pattern illustrated in Figure 6-1 is not an adopted recharge plan of the Watermaster; it is an illustration that demonstrates the concept of recharging when water is available and in quantities that can manage the CURO to a sustainable level.

Figure 6-2 shows the projected recharge time series and the corresponding CURO. A positive CURO indicates an outstanding replenishment obligation, and a negative CURO indicates that Watermaster has recharged more supplemental water than required to meet the annual replenishment obligation and that this water is in storage in the Chino Basin. The replenishment delivery scheme shown in Table 6-1 and Figure 6-1 was designed to avoid a significantly positive CURO. Minimizing the CURO ensures sustainability and minimizes impacts on producers from excessive drawdown during dry periods.

## **6.3 Existing Supplemental Recharge Capacity**

### **6.3.1 Spreading Basins**

Figure 6-3 shows the locations of the recharge facilities used by Watermaster, the CBWCD, and the IEUA for storm and supplemental water recharge. At most of these recharge facilities, supplemental water can only be recharged during non-storm periods. At dedicated conservation basins, supplemental water may be recharged during storm periods, but there is a risk that it may be lost due to overflow. Precipitation records were reviewed to determine the availability of recharge facilities for the recharge of supplemental water. The operating rules



regarding supplemental water recharge for each basin were assumed as follows:

- One day prior to a forecasted precipitation event, the delivery of supplemental water to a recharge basin would cease.
- No supplemental deliveries to a recharge basin would occur during a precipitation event.
- Supplemental water deliveries would resume the next day, following a precipitation event.

Long precipitation time histories of four areas in the Chino Basin—Claremont, Ontario, Fontana, and Chino—were evaluated to determine the number and duration of precipitation events. The longest record, 1900 through 2008, was developed by combining data from two precipitation stations located in the Claremont area. This record was evaluated to develop statistics to characterize when the recharge facilities would be operated in flood control management/stormwater recharge mode and, thus, unavailable for supplemental water recharge. Table 6-2 summarizes this analysis. A precipitation event was assumed to occur when measureable precipitation equaled or exceeded 0.04 inches. The duration of an event is the number of contiguous days with measurable precipitation. Table 6-2 provides, by month and year, statistics for the number of days with precipitation, the number of precipitation events, the mean duration of events, precipitation, and the mean facility availability for supplemental water recharge. Using the mean number and duration of precipitation events per month, the mean availability of the recharge facilities for supplemental water recharge can be calculated as:

$$\text{Mean Availability} = \frac{[\text{Number of Days in Month} - \text{Days Reserved for Flood Control}]}{\text{Number of Days in Month}}$$

The average availability of the existing recharge facilities for supplemental water recharge varies from a low of about 71 percent of the time in January and February to a high of about 94 percent of the time in July and August. The mean availability is about 87 percent. All basins were assumed to be out of service for two months in the summer for maintenance purposes.

Table 6-3 lists the spreading basins, their operational availability for supplemental water recharge, their supplemental water recharge capacities, and the theoretical maximum recharge capacities for supplemental water recharge. The table is organized as follows:

- The first column lists the recharge facilities and aggregates them by OBMP management zone.
- The next twelve columns (columns 2 through 13) show the estimated availability of the recharge facilities by month, based on the mean availability of the recharge facilities in consideration of the number of storm events each month (see Table 6-2). Availability in any one year is dependent upon operation and maintenance schedules as well as actual and forecasted precipitation.
- Column 14 contains the average recharge rate for each recharge facility or group of facilities. These rates were provided by the IEUA and are based on recent operational

performance.

- Column 15 lists the supplemental water recharge capacity.
- Column 16 indicates which Metropolitan turnout is tributary to each basin.
- Columns 17 and 18 provide the turnouts' maximum and useful discharge rates to the recharge facilities. The useful discharge rate is the discharge rate that doesn't adversely impact the Rialto pipeline's hydraulics.
- Column 19 indicates whether a turnout's capacity limits the recharge capacity of a facility; a "no" value means that the capacity of the turnout exceeds the recharge capacity of the facility, and a "yes" value means that the recharge capacity is limited by turnout capacity.
- Column 20 shows the annual theoretical imported water recharge capacity constrained by turnout capacity, which is estimated as the sum of the products of operational availability for each month times the number of days in each month times the average recharge rate of a given basin or the useful discharge rate for a given basin. As the table shows, CB13 and CB18 are the only turnouts that limit recharge capacity.

The last five columns summarize the theoretical maximum supplemental water recharge capacity per year and per quarter. The total maximum supplemental water recharge capacity of the recharge basins available to Watermaster is about 99,000 acre-ft/yr. The total maximum supplemental water recharge capacity for the Chino Basin, constrained by turnout capacity, is about 83,100 acre-ft/yr.

### **6.3.2 Aquifer Storage and Recovery Wells**

The Monte Vista Water District (MVWD) has five ASR wells with an estimated injection capacity of about 5,600 acre-ft/yr. Figure 6-4 shows the locations of these ASR wells. At present, there is no formal agreement that would allow Watermaster to use the MVWD's ASR wells for replenishment.

### **6.3.3 In-Lieu Recharge Capacity**

In lieu recharge occurs when a water purveyor with production rights in the Chino Basin elects to use supplemental water in lieu of its production rights. The un-produced production rights are reclassified as supplemental water pursuant to the Judgment and can be used to satisfy a replenishment obligation by an equal amount. The current in-lieu recharge capacity ranges from about 25,000 to 40,000 acre-ft/yr (B&V, 2008).

### **6.3.4 Supplemental Water Recharge Capacity Requirements**

The supplemental water recharge capacity of the spreading basins available to Watermaster and the existing ASR wells is about 88,700 acre-ft/yr. With in-lieu recharge, the supplemental water recharge capacity ranges from 113,700 to 128,700 acre-ft/yr. Pursuant to the Peace Agreement, Watermaster needs to have enough wet-water recharge capacity to meet its

replenishment needs and reserves in-lieu recharge capacity for other recharge programs. Watermaster may use in-lieu recharge for replenishment, but it must also have the ability to do wet-water recharge exclusively. Watermaster prepared a report entitled *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b) that evaluated, among other things, the supplemental water recharge capacity of the Chino Basin and the ability to meet Watermaster’s replenishment obligations through 2030. The report:

- Concluded that Watermaster could meet its replenishment obligations with existing spreading basins and existing and planned ASR wells, provided that Watermaster was able to acquire supplemental water for replenishment and that Watermaster used preemptive replenishment to manage the CURO to about 100,000 acre-ft;
- Assumed that replenishment would occur in about six out ten years and that the required supplemental water recharge capacity ranged between 78,000 acre-ft/yr to 86,000 acre-ft/yr, which is within the supplemental water recharge capacity currently available to Watermaster;
- And did not include new stormwater recharge created by compliance with the 2010 MS4 permit and future development or other new stormwater recharge projects.

## **6.4 Existing Supplemental Water Sources**

### **6.4.1 Metropolitan Water District of Southern California**

Metropolitan is a consortium of 26 cities and water districts that provides drinking water to about 19 million people in parts of Los Angeles, Orange, Riverside, San Bernardino, and Ventura Counties—a service area of about 5,200 square miles. Metropolitan currently delivers about 2 million acre-ft/yr of imported water to its service area from the State Water Project and the Colorado River<sup>6</sup> and conveys this water across the Chino Basin. Figure 6-3 shows Metropolitan’s pipelines, turnouts, and existing recharge basins in the Chino Basin area.

#### **6.4.1.1 State Water Project**

The SWP is owned by the State of California and operated by the Department of Water Resources. The SWP transports Feather River water stored in and released from Lake Oroville and unregulated flows diverted directly from the Delta south via the California Aqueduct to the Metropolitan service area (Metropolitan, 2009). In Antelope Valley, the California Aqueduct divides into the East and West Branches. The East Branch carries water to Silverwood Lake and Lake Perris (DWR, 2009). From Silverwood Lake, SWP water is conveyed to the San Bernardino area at the Devil Canyon Afterbay. Metropolitan supplies SWP water to the Chino Basin area from its Rialto Pipeline, which starts at the Devil Canyon Afterbay and traverses westward across the northern part of the Chino Basin towards Los Angeles. In a 100-percent allocation year, Metropolitan’s SWP contract with the DWR will

---

<sup>6</sup> <http://www.mwdh2o.com/mwdh2o/pages/about/about01.html>

provide Metropolitan with 1,911,500 acre-ft of water (Table A amount). SWP deliveries to Metropolitan, pursuant to Metropolitan’s SWP contract, for the last ten years are listed below.

<b>SWP Deliveries to Metropolitan</b>					
<b>Year</b>	<b>Metropolitan's SWP Supplies</b>				<b>Total</b>
	<b>Table A</b>	<b>Article 21</b>	<b>Turnback Pool</b>	<b>Carrover</b>	
	<b>acre-ft</b>	<b>acre-ft</b>	<b>acre-ft</b>	<b>acre-ft</b>	
1999	830,000	23,000	0	0	853,000
2000	1,274,000	103,000	0	170,000	1,547,000
2001	687,000	10,000	8,000	200,000	905,000
2002	1,273,000	10,000	14,000	98,000	1,395,000
2003	1,550,000	18,000	17,000	135,000	1,720,000
2004	1,196,000	92,000	10,000	215,000	1,513,000
2005	1,247,000	168,000	7,000	106,000	1,528,000
2006	1,104,000	238,000	12,000	136,000	1,490,000
2007	1,147,000	167,000	9,000	28,000	1,351,000
2008	654,000	0	2,000	0	656,000

Source – Draft State Water Project Delivery Reliability Report, 2009

SWP contracts define several classifications of water available to contractors under specific circumstances, as described below. All classifications are considered “project” water.

- **Table A Water.** Each SWP contract’s “Table A” is the amount of water, in acre-ft, that is used to determine the portion of available supply to be delivered to the contractor. Table A water is water delivered according this apportionment methodology and is given first priority for delivery.
- **Article 21 Water.** Article 21 of the SWP contract permits the delivery of water in excess of Table A deliveries and some other water types to those contractors requesting it. This water is available under specific conditions:
  - Water is available only when it does not interfere with SWP Table A allocations and SWP operations.
  - Water is available only when excess water is available in the Delta.
  - Water is available only when capacity is not being used for SWP purposes or scheduled SWP deliveries.
  - The water cannot be stored in the SWP system. In other words, the contractors must be able to use Article 21 water directly or be able to store it in their own systems.
- **Turnback Pool Water.** Contractors may choose to offer their allocated Table A water in excess of their needs to other contractors through two pools in February and March.
- **Carryover Water.** Pursuant to the long-term water supply contracts, contractors have the opportunity to carry over a portion of their allocated water approved for delivery

in the current year for delivery during the next year. Normally, carryover water is water that has been exported from the Delta but is not delivered to the contractor that year; instead, this water is stored in the SWP's share of the San Luis Reservoir for delivery the following year.

#### **6.4.1.2 SWP Delivery Reliability**

In January 2010, the DWR published the *Draft State Water Project Delivery Reliability Report* (DWR, 2009). This report updates the DWR's estimate of current (2009) and future (2029) SWP water delivery reliability. The report is produced every two years as part of a settlement agreement that was signed in 2003. The 2009 report shows that future SWP deliveries will be impacted by two significant factors: 1) a significant restriction on the SWP and Central Valley Project (CVP) Delta pumping, as required by the biological opinions issued by the U.S. Fish and Wildlife Service (December 2008) and the National Marine Fisheries Service (June 2009); and 2) climate change, which is altering hydrologic conditions in the state.

The report represents the state of affairs if no Delta improvements are made. It shows the continued erosion of SWP water delivery reliability under the current method of moving water through the Delta. In the 2007 report, the average Table A delivery was about 63 percent for 2007 conditions and about 66 to 69 percent for 2027 conditions. In the 2009 report, the average Table A delivery is about 60 percent for 2009 conditions and about 60 percent for 2029 conditions. Most of the reduced reliability is caused by the export limitations resulting from the two biological opinions—the first factor discussed above. Figure 6-5a shows the SWP delivery reliability from the 2005, 2007, and 2009 SWP Delivery Reliability Reports (DWR, 2005; 2008; & 2010 [respectively]). As the figure shows, the delivery probability curve for 2007 drops completely below the 2005 delivery probability curve, showing a drop in average current reliability from 72 percent to 63 percent; and the delivery probability curve for 2009 drops significantly below the 2007 delivery probability curve 68 percent of the time for higher allocations and climbs above the 2007 delivery probability curve 32 percent of the time, corresponding to lower allocations. The significance of the most recent projected delivery reliability is that there is a relative decrease in deliveries during wetter (higher allocation) years and a slight increase in deliveries during dry years. Metropolitan will have less SWP water available in wet years to refill its storage assets and for groundwater replenishment and slightly more water in dry years to meet its firm demand. In response to the *2007 State Water Project Delivery Reliability Report*, Metropolitan reduced its forecast of replenishment service water, as noted earlier in this section, from seven out of ten years to three out of ten years. With the further erosion of SWP reliability projected in the draft *2009 SWP Delivery Reliability Report*, the availability of replenishment water service from Metropolitan is seemingly more limited in the current period than was thought just two years ago.

Figure 6-5b compares the predicted reliability for 2025, 2027, and 2029.<sup>7</sup> The projected future change in SWP delivery reliability is even more restrictive in wet years, indicating that, in the

---

<sup>7</sup> Figure 6-5b is not a straight apples to apples comparison due to changes in modeling capabilities and the assumptions associated with climate change in the out years. That said, the conclusion reached from examining the reliability projection is still valid.

future, Metropolitan will receive less SWP water during wet periods than projected in the past. The eroding SWP reliability has major implications: replenishment water service will not be available from Metropolitan in the future, and Watermaster will have to purchase Tier 1 and Tier 2 water if available and possibly other imported water. In the latter case, Watermaster will need to have those waters wheeled through Metropolitan and the IEUA.

#### 6.4.1.3 Colorado River Aqueduct (CRA)

The CRA is owned and operated by Metropolitan. The CRA transports water from the Colorado River approximately 242 miles to its terminus at Lake Mathews in Riverside County. The Colorado River was the initial imported water supply for Metropolitan. Metropolitan acquires Colorado River water from the Bureau of Reclamation (BOR) and is limited to the capacity of the CRA, which is approximately 1.2 million acre-ft/yr. The BOR supplies water to Metropolitan based on a priority system that was created in 1931. Colorado River water is provided under a permanent service contract and an interstate compact. For California, the allocation is as follows:

Priorities Under the 1931 California Seven Party Agreement		
Priority 1	Palo Verde Irrigation District	3,850,000
Priority 2	Imperial Irrigation District	(included above)
Priority 3	Coachella Valley Water District	(included above)
Priority 4	Metropolitan Water District	550,000
<b>California Basic Apportionment</b>		<b>4,400,000</b>
Priority 5(a)	Metropolitan Water District	550,000
Priority 5(b)	Metropolitan Water District	112,000
Priority 6(a)	Imperial Irrigation District	300,000
Priority 6(b)	Palo Verde Irrigation District	(included above)
<b>Total Surplus Allocation</b>		<b>962,000</b>
<b>Total</b>		<b>5,362,000</b>
Priority 7	Agricultural Use in the Colorado River Basin	Remaining Surplus

For Metropolitan, only Priority 4 is part of the basic apportionment of the 4.4 million acre-ft of Colorado River water for California. Metropolitan can only divert Priorities 5(a) and (b) if there is surplus water and apportioned but unused water within the Colorado River system (surplus to Priorities 1, 2, and 3). Metropolitan has stated that it was able to take delivery of 1.2 million acre-ft of the Colorado River water through 2002 and that it averaged 762,000 acre-ft/yr from 2003 through 2008. This is due to the drought on the Colorado River system and the increase in water diversions by Nevada and Arizona.<sup>8</sup>

<sup>8</sup> Metropolitan Water District of Southern California Waterworks General Obligation Refunding Bonds, 2009 Series, dated December 1, 2009, Appendix A, page A-13

The amount of Colorado River water available to Metropolitan’s service area was augmented with the long-term transfer agreement between the Imperial Irrigation District (IID) and the San Diego County Water Authority (SDCWA). The transfer agreement provides up to 200,000 acre-ft of water per year for a seventy-five year term. The transfer agreement is dependent upon the Quantification Settlement Agreement (QSA), which was invalidated on January 14, 2010 when a Sacramento Superior Judge issued a final ruling.<sup>9</sup> If the ruling survives an appeal, the IID-SDCWA transfer agreement may have to be revised and renegotiated.

Small amounts of CRA water were used to recharge the Chino Basin prior to the implementation of the Chino Basin Judgment and the 1975 Basin Plan. The TDS concentration of CRA water far exceeds the TDS concentration objectives for the Chino Basin Management Zones. Also, as Figure 6-3 shows, very few recharge basins in the Chino Basin are located such that CRA water could be used for recharge without the construction of pump stations and pipelines. The 2004 Basin Plan contains a requirement that states Watermaster and the IEUA must “[...] optimize the recharge of imported water in the Chino Basin based on the goal of maximizing recharge of SWP water when the TDS of that water is lowest.”<sup>10</sup> The use of CRA water for replenishment would likely require a Basin Plan amendment and a demonstration that the increased TDS loading from using CRA water for replenishment could be offset.

#### 6.4.1.4 Metropolitan as a Source of Water for Replenishment

Metropolitan will most likely not be able to supply replenishment service water to the Watermaster in the future. The projected growth in Watermaster replenishment demands has not been considered a firm supply in Metropolitan’s planning, and therefore the use of Tier 1 and Tier 2 service water for replenishment is problematic. Watermaster will likely be purchasing Tier 1 and Tier 2 service water for replenishment when it is available and may be required to look outside of Metropolitan for supplemental water for replenishment. The current and projected costs (\$/acre-ft) of water purchased from Metropolitan are shown below.

	Effective 1/1//2010	Effective 1/1/2011	Effective 1/1/2012
Replenishment Rate	\$366	\$409	\$442
Tier 1 Rate	\$484	\$527	\$560
Tier 2 Rate	\$594	\$652	\$686
Wheeling Rate	\$314	\$372	\$396

<sup>9</sup> Superior Court of California, County of Sacramento, Judge Roland L. Candee, Case No.: JC4353, QSA Coordinated Cases, issued January 14, 2010

<sup>10</sup> Santa Ana Regional Water Quality Control Board resolution amending the Basin Plan (R8-2004-0001) [http://www.waterboards.ca.gov/santaana/board\\_decisions/adopted\\_orders/orders/2004\\_orders.shtml](http://www.waterboards.ca.gov/santaana/board_decisions/adopted_orders/orders/2004_orders.shtml)

Analysis of Metropolitan’s historical water rates indicates that Metropolitan’s rates have increased at a compounded rate of about 6 percent per year. By comparison, the increase from January 2010 to January 2012 is about 10 percent for the replenishment rate and about 7.5 percent for the Tier 1 and Tier 2 rates.

#### 6.4.2 IEUA Recycled Water

The IEUA initiated an aggressive recycled water reuse program for its service area. Under this program, most of the recycled water produced in the IEUA’s service area will be reused. Moreover, the IEUA plans to recharge recycled water at selected spreading basins. Historical and projected recycled water recharge in the Chino Basin is shown below.

**Historical<sup>1</sup> and Projected Recycled Water Recharge**  
(acre-ft)

Year	Recycled Water Recharge		
	Low Range	Mid Range	High Range
2005 - 2006	1,304	1,304	1,304
2006 - 2007	2,989	2,989	2,989
2007 - 2008	2,237	2,237	2,237
2008 - 2009	2,684	2,684	2,684
2009 - 2010	8,056	8,056	8,056
2010 - 2011	12,505	14,090	20,431
2011 - 2012	12,500	15,960	23,142
2012 - 2013	12,500	17,835	24,000
2013 - 2014	12,500	10,985	24,000
2014 - 2015	12,500	20,048	24,000
2015 - 2016	12,500	20,689	24,000
2016 - 2017	12,500	21,000	24,000
2017 - 2018	12,500	21,000	24,000
2018 - 2019	12,500	21,000	24,000
2019 - 2020	12,500	21,000	24,000
2020 - 2021	12,500	21,000	24,000
2021 - 2022	12,500	21,000	24,000
2022 - 2023	12,500	21,000	24,000
2023 - 2024	12,500	21,000	24,000
2024 - 2025	12,500	21,000	24,000
2025 - 2026	12,500	21,000	24,000
2026 - 2027	12,500	21,000	24,000
2027 - 2028	12,500	21,000	24,000
2028 - 2029	12,500	21,000	24,000
2029 - 2030	12,500	21,000	24,000

Source: IEUA May 2010

1 –Historical values in italics



Recycled water recharge is not used to satisfy replenishment obligations. Instead, it is recharged into the basin and subsequently assigned to certain appropriator parties, thereby increasing the appropriators' production rights and reducing their future replenishment liabilities. The recharge of recycled water has the important effect of reducing current and future replenishment obligations. For planning purposes, the mid-range projection was used in Section 4 to determine future replenishment obligations, as it is most consistent with the planning assumptions in this investigation. The assumptions embedded in the IEUA mid-range projection include:

- Recycled water recharge is at 90 percent of the spreading basin capacity from April 16<sup>th</sup> to October 14<sup>th</sup>.
- Recycled water recharge is at 60 percent of the spreading basin capacity from October 15<sup>th</sup> to April 15<sup>th</sup>.
- Recycled water turnout capacity limitations were considered.
- Spreading basin maintenance is assumed to provide at least 50 percent of the post-cleaning infiltration at all times.
- Recycled water conveyance enhancements to the RP-3 Basins, Turner Basin, and the Banana/Hickory Basins will be complete by 2012-13.
- Although permitted, the Lower Day Basin, the Etiwanda Debris Basin, and the Etiwanda Conservation Basin are not included in the mid-range projection.
- Imported water supply (for recharge and replenishment purposes) is assumed to be 708,000 acre-ft, distributed throughout the Chin Basin between 2015 to 2030, which is consistent with the projections in the draft 2010 Recharge Master Plan Update (WEI, 2010c).

## **6.5 Other Supplemental Water**

### **6.5.1 Imported Water**

Imported water, as discussed herein, means water that does not originate in the Chino Basin or from watersheds that historically contribute recharge to the Chino Basin. Sources of imported water, other than Metropolitan, that may potentially be available to Watermaster include:

- groundwater and surface water supplies from the Central Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities;
- groundwater from the Antelope Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities;
- groundwater and surface water supplies from the Colorado River Basin, conveyed to the Chino Basin through Metropolitan facilities;
- groundwater and surface water supplies in the Santa Ana Watershed that can be

supplied to the Chino Basin directly or by exchange;

- recycled water from the Rapid Infiltration Extraction Treatment Plant (RIX) in Colton, from the City of Riverside, and from others.

The use of these supplies is not limited to replenishment: these supplies could be used in lieu of Chino Basin groundwater, thereby reducing Watermaster's replenishment obligation. Each source is summarized below.

**Groundwater and Surface Water from the Central Valley.** There is, at times, surplus<sup>11</sup> groundwater and surface water in the Sacramento Valley north of the Delta and in the San Joaquin Valley south of the Delta. Watermaster could acquire water from these sources and have it wheeled to the Chino Basin. Watermaster would provide the acquired water to Metropolitan for conveyance to the Chino Basin within its SWP capacity and subsequently its Rialto pipeline for delivery to spreading basins. In addition to acquisition costs, Watermaster would pay the current Metropolitan wheeling cost and IEUA administrative costs. Appendix E, prepared by the Sierra Water Group, explains this type of transaction in detail. As an alternative to spreading the water, Watermaster could have the replenishment supply delivered directly to treatment plants in the Chino Basin for subsequent injection or in-lieu replenishment.

**Groundwater from the Antelope Valley.** Antelope Valley water users are currently involved in groundwater rights litigation. It may be possible to acquire groundwater from right holders in the Antelope Valley when this dispute is resolved and to have that water conveyed to the Chino Basin through the East Branch of the SWP. Watermaster would provide the acquired water to Metropolitan for conveyance to the Chino Basin within its SWP capacity and subsequently its Rialto pipeline for delivery to spreading basins. In addition to acquisition costs, Watermaster would pay the current Metropolitan wheeling cost and IEUA administrative costs. As an alternative to spreading the water, Watermaster could have the replenishment supply delivered directly to treatment plants in the Chino Basin for subsequent injection or in-lieu replenishment.

**Groundwater and Surface Water from the Colorado River Basin.** There is, at times, surplus surface water in the Colorado River Basin. Watermaster could acquire water from this source and have it wheeled to the Chino Basin. Watermaster would provide the acquired water to Metropolitan for conveyance to Southern California in the CRA. Metropolitan would then deliver this water directly to the Chino Basin through its Upper Feeder Pipeline or provide an equal amount of SWP water through the Rialto Pipeline, the latter being the preferred approach for the Chino Basin. In addition to acquisition costs, Watermaster would pay the current Metropolitan wheeling cost and IEUA administrative costs. Appendix E explains this type of water transaction in detail. As an alternative to spreading the water, Watermaster could have the replenishment supply delivered directly to treatment plants in the Chino Basin for subsequent injection or in-lieu replenishment.

---

<sup>11</sup> The surplus occurs because local and other supplies are greater than the current need or because the price of water is great enough to encourage transfers.

**Groundwater and Surface Water from the Non-Chino Basin Parts of the Upper Santa Ana Watershed.** Virtually all of the groundwater and surface water sources in the upper Santa Ana Watershed are being used, and the various parties' rights to use those waters have been established. The exceptions to this statement are infrequent and seasonal stormwater discharges and some recycled water. With the exception of recycled water, it is unlikely that these supplies could be obtained by Watermaster for replenishment. These sources are not considered further in this RMPU.

**Recycled Water from the Rapid Infiltration Extraction Treatment Plant (RIX) in Colton.** The City of San Bernardino manages the RIX facility for itself and the City of Colton. The City of San Bernardino has expressed an interest in marketing some of its recycled water and completed a program EIR for this marketing program in 2002 (Tom Dodson and Associates, 2005). One of the projects evaluated in the program EIR was the sale of recycled water to water purveyors in the Chino Basin for direct use and recharge. This supply is evaluated later in this section.

**Recycled Water from the City of Riverside.** The City of Riverside currently produces about 35,000 acre-ft/yr of effluent and may have surplus recycled water that can be conveyed to the Chino Basin. Obtaining water from this source is similar in concept to obtaining water from RIX. Because of its elevation and TDS concentration, this source is not considered further in this RMPU.

## **6.5.2 Other Water Sources**

Two other water sources were evaluated in this update: recycled water produced at the Western Riverside County Regional Wastewater Authority Plant (WRCRWAP) and a surface water diversion from the Santa Ana River located between the Riverside Narrows and the upstream limits of the Prado Reservoir.

**Recycled Water from the WRCRWAP.** Currently, the WRCRWAP produces about 4,500 acre-ft/yr of recycled water and discharges it to the Santa Ana River. The WRCRWAP is planned to produce about 16,000 acre-ft/yr by 2020. Some or all of this water could be reused in the Chino Basin, reducing Watermaster's replenishment obligation. This supply is evaluated later in this section. Currently, the JCSD is investigating recycled water produced at the WRCRWAP for direct use. The project evaluated herein would use recycled water produced at the WRCRWAP that is surplus to JCSD needs.

**Diversion of Santa Ana River Water between the Riverside Narrows and the Upstream Limits of the Prado Reservoir.** The discharge in the Santa Ana River below the City of Riverside's point of discharge averages about 158 cfs (115,000 acre-ft/yr) and will likely remain at this level through 2020, based on the recent projections of the Basin Monitoring Task Force (WEI, 2010b). The TDS concentration in this reach of the Santa Ana River is comparable to CRA water and is currently too high for recharge in the Chino Basin without a Basin Plan amendment. Santa Ana River water is not considered further in this RMPU.

## 6.6 Replenishment Water Supply Portfolio

Table 4-2 contains the current best estimate of the future Watermaster recharge requirements, including the 6,500 acre-ft/yr requirement for MZ 1 and replenishment obligations. This projection assumes future development will create new stormwater recharge and that the IEUA will recharge recycled water per its mid-range projection, discussed in its May 2010 Technical Memo (IEUA, 2010). For the planning purposes of the RMPU, it has been assumed herein that Watermaster will acquire supplemental water for recharge when it is available and in a manner that will limit the CURO to no more than 100,000 acre-ft. Watermaster will maximize its purchase of water from Metropolitan prior to looking at other imported water sources from outside the Santa Ana River Watershed. Watermaster will attempt to develop local projects—including stormwater recharge and, potentially, the acquisition of non-IEUA recycled water—to minimize the purchase of highly variable and unreliable imported supplies.

## 6.7 New Supplemental Water Recharge Improvement Projects

Black & Veatch (B&V) completed an investigation of *Supplemental Water Recharge Concept Development* (B&V, 2010), which is included with this report as Appendix F. The B&V report describes the development of an initial palette of projects that could be used either to increase supplemental water recharge capacity or to develop more supplemental water supply. B&V developed screening criteria and applied these criteria to the initial palette of projects, reducing the number of projects to only those that were most promising. As a result of this process, five concepts were selected. Section 3 of the B&V report summarizes the initial project palette, the screening process, and the results of the screening process.

Following the pre-screening process, two additional concepts were developed that had not previously been considered, including (1) a new recycled water supply via a connection from the RIX Facility to the IEUA's recycled water distribution system and (2) a new recycled water supply via a connection from the WRCRWAP to the IEUA's recycled water distribution system.

In total, seven projects were carried forward into conceptual design. The table below summarizes the project concepts, estimated recharge capacities, cost opinions, and specific contributions to the recharge master plan.

Concept	Potential Recharge Capacity (acre-ft)/yr	Estimated Capital Cost	Estimated Annual Cost	Unit Water Cost (\$/acre-ft) <sup>1</sup>	Contribution to Recharge Master Plan
Delivery of Recycled Water from RIX to IEUA <sup>(3)</sup>	4,400	\$52,604,000	\$4,123,000	\$937	New supplemental water supply
	10,000		\$4,715,000	\$472	
Delivery of Recycled Water from WRCRWAP to IEUA <sup>(3)</sup>	2,000	\$11,619,000	\$999,000	\$495	New supplemental water supply
	4,500		\$1,193,000	\$265	
CVWD ASR Wells	6,433	\$25,844,000	\$1,857,000	\$289	Improves winter time recharge capacity and groundwater levels
JCSD ASR Wells <sup>(2)</sup>	3,228	\$32,200,000	\$2,222,000	\$688	Improves winter time recharge capacity and groundwater levels
Ontario ASR Wells	5,020	\$27,636,000	\$1,949,000	\$388	Improves winter time recharge capacity and groundwater levels
Turnout to San Sevaine Basin No. 1 from Azusa Devil Canyon (ADC) Pipeline	10,000	\$7,112,000	\$507,000	\$51	Improves capacity to move imported water into the Chino Basin
Turnout to San Antonio Channel from ADC Pipeline	10,000	\$2,636,000	\$172,000	\$17	Improves capacity to move imported water into the Chino Basin

**Notes:**

- (1) These unit costs do not include the cost of the water supply.
- (2) This estimated cost includes a 36,000-foot conveyance pipeline in addition to the wells.
- (3) This estimated cost includes conveyance facilities to connect to the IEUA's system only and does not include an evaluation of the system compatibility or modifications to the treatment plants. A more detailed analysis of the treatment processes is recommended.

### **6.7.1 New Local Supplemental Water Sources**

Two new sources of supplemental water were identified that could be used to reduce Watermaster’s replenishment obligation and for replenishment supply. These two supplies include recycled water from the RIX Facility in Colton and from the WRCRWAP, which is located in the southern part of the Chino Basin. The project descriptions and the costs to connect these supplies to existing recycled water infrastructure are described below.

#### **6.7.1.1 RIX Facility Connection to the IEUA’s Recycled Water Distribution System**

This concept includes the construction of a new connection from the RIX facility to the IEUA’s recycled water distribution system in the vicinity of the RP3 Spreading Basins. The San Bernardino Regional Tertiary & Water Reclamation Authority (Authority) owns and operates the 40-mgd RIX facility, which is located on Agua Mansa Road within the City of Colton. The RIX plant treats secondary effluent from the Cities of San Bernardino and Colton to tertiary standards, using rapid infiltration followed by well extraction and disinfection, and ultimately discharges the treated effluent to the Santa Ana River. Based on discussions with San Bernardino Municipal Water Department (SBMWD) staff during the development of the RMPU, the SBMWD could sell up to 10,000 acre-ft/yr of recycled water for use in the Chino Basin. After review of the April 2010 B&V draft Technical Memorandum, the IEUA commented that they could not take 10,000 acre-ft/yr into their non-potable system due to physical and operational limitations; therefore, B&V reduced the capacity of this project to 4,400 acre-ft/yr. Should the IEUA’s recycled water supply become insufficient in the out years or should additional capacity become available, the B&V proposed conveyance capacity would allow delivery of up to 10,000 acre-ft/yr.

A new pipeline and booster pump station would be constructed to connect the RIX facility to the IEUA recycled water distribution system. The pipeline would be approximately nine miles long and 24 inches in diameter. The connection would include a flowmeter, a check valve to prevent backflow, and isolation valves. A 1,500 horsepower booster pump station would also be required to overcome elevation changes and pipeline losses and to meet the hydraulics within the IEUA distribution system. The facilities are shown on Figure 6-6. The estimated capital cost to construct the facilities is about \$52,604,000, and the annual cost<sup>12</sup> will range from about \$4,123,000 with a delivery of 4,400 acre-ft/yr to about \$4,715,000 with a delivery of 10,000 acre-ft/yr. The unit cost of building and operating this facility would range from about \$937/acre-ft with a delivery of 4,400 acre-ft/yr to about \$472/acre-ft with a delivery of 10,000 acre-ft/yr.

Coordination with the IEUA and the RWQCB will be necessary to develop new recycling and discharge permits and to develop and operate the project. A water sales agreement between the SBMWD, the IEUA, and perhaps other Chino Basin entities will have to be developed and executed.

---

<sup>12</sup> Annual cost, as used herein, includes amortized capital (30-year term at 5 percent) plus annual O&M.

This project provides a completely new supplemental water supply to the Chino Basin. And, this water supply could be provided in constant amounts each year, thus reducing the impacts of highly variable imported water supplies from outside of the basin. Furthermore, the cost of this supply may be more predictable over time and may therefore contribute to more stable replenishment assessments.

### **6.7.1.2 WRCRWAP Connection to the IEUA's Recycled Water Distribution System**

This concept includes the construction of a new connection from the WRCRWAP to the IEUA's recycled water distribution system. The Western Municipal Water District (WMWD) owns and operates the 8-mgd WRCRWAP, which is located on River Road within the City of Corona. Recent planning information suggests that the WRCRWAP capacity will be expanded to 16 mgd by 2020. The WRCRWAP treats secondary effluent from the City of Norco, the Jurupa Community Services District, and the Home Gardens Sanitary District to tertiary standards, and ultimately discharges the treated effluent to the Santa Ana River. This concept would provide up to 4,500 acre-ft/yr of recycled water to supplement the IEUA's supply for direct use and groundwater recharge. A new pipeline and booster pump station would be constructed to connect the WRCRWAP to the IEUA's recycled water distribution system. The pipeline would be approximately three miles long and 16 inches in diameter. The facilities would include metering and flow control, a check valve to prevent backflow, and isolation valves. A 500-horsepower booster pump station would be required to overcome elevation changes and pipeline losses and to meet the hydraulics within the IEUA distribution system. The facilities are shown in Figure 6-7.

Coordination with the IEUA and the RWQCB will be necessary to develop new recycling and discharge permits and to develop and operate the project. A water sales agreement between the WRCRWAP, the IEUA, and perhaps other Chino Basin entities will have to be developed and executed.

This project provides a completely new supplemental water supply to the Chino Basin. And, this supply could be provided in constant amounts each year, thus reducing the impacts of highly variable imported water supplies from outside of the Chino Basin. Furthermore, the cost of this supply may be more predictable over time and may therefore contribute to more stable replenishment assessments.

The estimated capital cost to construct the facilities is about \$11,619,000, and the annual cost will range from about \$999,000 with a delivery of 2,000 acre-ft/yr to about \$1,193,000 with a delivery of 4,500 acre-ft/yr. The unit cost of building and operating this facility will range from about \$495/acre-ft with a delivery of 2,000 acre-ft/yr to about \$265/acre-ft with a delivery of 4,500 acre-ft/yr. Water acquisition costs are not included.

## **6.7.2 Increase in Supplemental Recharge Capacity**

B&V identified three new ASR projects that could be used to increase the supplemental water recharge capacity of the Chino Basin, to provide Watermaster additional recharge capacity during the rainy season, and to provide Watermaster with another tool to balance recharge and discharge pursuant to the Peace Agreement. The project descriptions and costs for these ASR projects are described below.

### **6.7.2.1 Cucamonga Valley Water District (CVWD) Aquifer Storage and Recovery (ASR) Wells**

This concept includes the construction and operation of several ASR wells within the CVWD service area. These facilities would be owned by the CVWD. This project fills two roles in the RMPU: it increases the supplemental water recharge capacity of the Chino Basin, and it reduces the groundwater level impacts of reoperation in the CVWD service area. In addition, it provides Watermaster with more wintertime recharge capacity when its recharge basins are being used to recharge stormwater.

To accomplish basin recharge, imported SWP water deliveries via Metropolitan's Rialto Pipeline to the CVWD's LMWTP would be increased when Watermaster takes water for replenishment. The additional treated water from the LMWTP would be conveyed through the CVWD service area, using existing CVWD infrastructure, to the ASR wells. This concept would require the conversion of up to three existing extraction wells to ASR wells and the construction of up to four new ASR wells. The new recharge capacity of this project is about 6,400 acre-ft/yr. The following table provides the proposed ASR well locations and assumed injection rates. The well locations are shown in Figure 6-8.



Well <sup>(1)</sup>	Location	Project Type	Assumed Injection Rate, gpm	Assumed Injection Capacity, acre-ft/yr <sup>(2)</sup>
CB-38	Southeast corner of Acacia Street and Archibald Avenue	ASR Conversion	750	605
CB-39	North of Wochase Court, west of East Avenue, and east of Interstate 15	ASR Conversion	1,275	1,028
CB-46	Utica Avenue, south of 7 <sup>th</sup> Street	ASR Conversion	1,700	1,371
ASR 1	West of Day Creek, south of Foothill Boulevard, and east of Rochester Avenue	New ASR Well	1,250	1,008
ASR 2	West of Day Creek, south of Foothill Boulevard, and east of Rochester Avenue	New ASR Well	1,000	807
ASR 3 (48)	West Liberty Parkway and Miller Avenue	New ASR Well	1,000	807
ASR 4 (47)	East of Etiwanda between Highland Avenue and Carnesi Drive	New ASR Well	1,000	807
<b>TOTAL</b>			<b>7,975</b>	<b>6,433</b>

Notes:

(1) Well locations determined via conversations between WEI and CVWD staff.

(2) Assumes injection over a six-month period.

The estimated capital cost to construct the facilities is about \$25,844,000, and the annual cost is about \$999,000/yr. The unit cost of building and operating this facility is estimated to be about \$289/acre-ft with a recharge capacity of 6,400 acre-ft/yr. Water acquisition costs are not included in the above cost.

### **6.7.2.2 Jurupa Community Services District (JCSD) Aquifer Storage and Recovery (ASR) Wells**

This concept includes the use of several ASR wells owned and operated by the JCSD. Treated water from WMWD's future Riverside-Corona (RC) Feeder Central Reach would be conveyed to the ASR wells for injection into the Chino Basin. This project fills two roles in the Recharge Master Plan: it increases the supplemental water recharge capacity of the basin, and it reduces the groundwater level impacts of reoperation in the JCSD service area. In addition, it provides Watermaster with more wintertime recharge capacity when its recharge basins are being used to recharge stormwater.

This concept includes the conversion of up to four extraction wells to ASR wells and the

construction of a new pipeline connecting the RC Feeder to the ASR wells or the use of these facilities if constructed by others. As of the time this report was drafted, the extraction wells had not been constructed; it has been assumed that they will be constructed and available for ASR well conversion in the future. The wells would be located within the JCSD's service area near the intersection of Interstate 15 and State Route 60. This project could recharge about 3,200 acre-ft/yr. The following table provides the ASR well locations and assumed injection rates. The well locations are shown in Figure 6-9.

Well <sup>(1)</sup>	Location	Project Type	Assumed Injection Rate, gpm	Assumed Injection Capacity, acre-ft/yr <sup>(2)</sup>
IDI-3A	Wineville Avenue 2,000 feet south of Riverside Drive	ASR Conversion	1,000	807
IDI-5A	Northeast corner of Interstate 15 and Cantu-Galleano Ranch Road	ASR Conversion	1,000	807
Oda	Northwest corner of Riverside Drive and 280 feet west of Wineville Avenue	ASR Conversion	1,000	807
Galleano	2,700 feet west of the intersection of Etiwanda Avenue and San Sevaine Way	ASR Conversion	1,000	807
<b>TOTAL</b>			<b>4,000</b>	<b>3,228</b>

Notes:

(1) Well locations determined via conversations between WEI and JCSD staff.

(2) Assumes injection over a six-month period.

The new pipeline would be approximately 36,000 feet long and 30 inches in diameter and would include a metering and flow control facility at its connection to the RC Feeder. The turnout vault would contain a flowmeter, isolation valves, and a check valve to prevent backflow.

The estimated capital cost to construct the facilities is about \$32,200,000, and the annual cost is about \$2,222,000/yr. The unit cost of building and operating this facility is estimated to be about \$688/acre-ft with a recharge capacity of 3,200 acre-ft/yr. Water acquisition costs are not included in the above cost.

### 6.7.2.3 City of Ontario Aquifer Storage and Recovery (ASR) Wells

This concept includes construction of up to five new ASR wells and the conversion of one existing extraction well to an ASR well. These facilities would be owned and operated by the City of Ontario. This project fills two roles in the Recharge Master Plan: it increases the supplemental water recharge capacity of the Basin, and it reduces the groundwater level impacts of reoperation in the City of Ontario service area. In addition, it provides Watermaster with more wintertime recharge capacity when its recharge basins are being used to recharge stormwater.

Imported water is currently conveyed to the Ontario distribution system via the WFA Agua de Lejos WTP, which currently serves the Cities of Ontario, Upland, Chino, and Chino Hills, and the Monte Vista Water District. The WTP, which is located on Benson Avenue in the City of Upland, has unused capacity during the winter months and could be used to treat surplus imported water for distribution throughout the Ontario service area, thereby allowing injection at the ASR wells. Another source for treated imported water would be the CVWD's Lloyd Michael WTP, which is located on Etiwanda Avenue in Rancho Cucamonga. This variant would be dependent on the construction of a connection between the Ontario distribution system and the CVWD's existing 30-inch transmission main that runs along Rochester Avenue.

For this project, it was assumed that one of the above options would be feasible and that only the construction of ASR wells would be required. The following table provides the ASR well locations and assumed injection rates. The well locations are shown in Figure 6-10.

Well (1)	Location	Project Type	Assumed Injection Rate, gpm	Assumed Injection Capacity, acre- ft/yr <sup>(2)</sup>
No. 27	South of Jurupa Street and east of Milliken Avenue	ASR Conversion	550	444
No. 51	West of Carnegie Avenue and Santa Ana Street	New ASR Well	800	645
No. 106	Southwest corner of Milliken Avenue and Chino Avenue	New ASR Well	1,250	1,008
No. 109	South of East G Street and west of Corona Avenue	New ASR Well	1,250	1,008
No. 119	South of East State Street and west of South Grove Avenue	New ASR Well	1,250	1,008
No. 138	North of 8 <sup>th</sup> Street and east of Campus Avenue	New ASR Well	1,125	907
<b>TOTAL</b>			<b>6,225</b>	<b>5,020</b>

Notes:

(1) Well locations determined via conversation between WEI and City of Ontario staff.

(2) Assumes injection over a six-month period.

The estimated capital cost to construct the facilities is about \$27,636,000, and the annual cost is about \$1,949,000/yr. The unit cost of building and operating this facility is estimated to be about \$388/acre-ft with a recharge capacity of 5,000 acre-ft/yr. Water acquisition costs are not included in the above cost.

#### **6.7.2.4 Current Need for ASR Wells for Replenishment**

In the recent *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b), the CVWD's and the City of Ontario's proposed ASR wells were not included in the groundwater simulations of the Peace II project description because their production was projected to be sustainable through 2030. The JCSD ASR wells have been included in the RMPU due to the projected need for supplemental water recharge in the JCSD well field area to sustain production. It would be substantially more cost-effective for the JCSD and Watermaster to conduct in-lieu recharge in the JCSD area than it would be to construct ASR facilities: the same magnitude of recharge could occur with in-lieu as with ASR wells. Watermaster could conduct in-lieu recharge with the CVWD and the City of Ontario to increase groundwater levels in their service areas instead of spreading imported water in the existing basins.

#### **6.7.3 Increase in Supplemental Water Delivery Capacity**

B&V also investigated the potential to increase the delivery capacity of supplemental water to the Chino Basin through new spreading basin turnouts. Recall that there is a turnout capacity limitation for the San Sevaine spreading grounds and that there may be times during the summer when the Rialto Pipeline is full, making firm water deliveries, and not available for delivering water to Watermaster for replenishment purposes. The project descriptions and costs for these new turnout projects are described below.

##### **6.7.3.1 Turnout to San Sevaine Basin No. 1 via the Azusa Devil Canyon (ADC) or Etiwanda Pipelines**

This concept includes the construction of a new turnout on either the ADC pipeline or the Etiwanda pipeline. The SGVMWD and Metropolitan own and operate the ADC and Etiwanda pipelines, respectively. Both pipelines convey SWP water from Silverwood Lake to the Districts' respective service areas. Water from either the ADC pipeline or the Etiwanda pipeline would be diverted north to San Sevaine Recharge Basin No. 1 through a turnout, metering structure, and conveyance pipeline. The proposed facilities are shown in Figure 6-11. A new pipeline would be constructed, connecting the selected supply pipeline near the intersection of Cherry Avenue and South Highland Avenue to San Sevaine Basin No. 1. At this location, the ADC and Etiwanda pipelines run parallel in close proximity to each other, and connection to either pipeline would require approximately the same length of new pipe. The pipeline would be approximately 6,000 feet long and 36 inches in diameter and would include a flow control and air gap structure at the connection to San Sevaine Basin No. 1. The turnout vault would contain a flowmeter to accurately measure flow to the basin, a fixed

orifice sleeve to reduce pressure head, and a check valve to prevent backflow.

The ADC pipeline has a capacity of 55 cfs (39,800 AFY), which would only be available during three winter months when the SGVMWD has met the delivery requirements of its service area. Therefore, the maximum assumed capacity of this concept, for the purposes of the RMPU, would be approximately 10,000 AFY (assuming a delivery of 55 cfs for three months, uninterrupted). Selection of the supply pipeline (ADC or Etiwanda pipeline) would be determined by the available capacity during the design phase of the project.

The project would recharge Management Zone 2 and would benefit the southern CVWD service area, the northeastern Ontario service area, and the western end of the Fontana Water Company service area. This project fills two roles in the Recharge Master Plan: it increases the delivery capacity of imported water to the spreading basins on San Sevaine Creek where the recharge capacity is limited by the existing turnouts, CB-13 and CB-18, and it provides a redundant means to deliver water to the spreading basins on San Sevaine Creek. This project increases supplemental water recharge capacity by 10,000 acre-ft/yr and improves the reliability of this part of the recharge system.

The estimated capital cost to construct the facilities is about \$7,712,000, and the annual cost is about \$507,000/yr. The unit cost of building and operating this facility is estimated to be about \$51/acre-ft with a recharge capacity of 10,000 acre-ft/yr. Water acquisition costs are not included in the above cost.

### **6.7.3.2 Turnout to San Antonio Channel via the Azusa Devil Canyon (ADC) Pipeline**

This concept includes the construction of a new turnout along the ADC pipeline. The SGVMWD owns and operates the ADC pipeline, which conveys SWP water from Silverwood Lake to its retail agencies. Water from the ADC pipeline would be diverted to the San Antonio Channel through a turnout and metering structure and flow south to several Chino Basin recharge facilities, including the College Heights, Upland, Montclair, and Brooks Basins. The proposed facilities are shown in Figure 6-12. The project would recharge MZ1 and would benefit the service areas of the MVWD, the San Antonio Water Company, and the Cities of Upland, Ontario, Chino, and Chino Hills. A new pipeline would be constructed, connecting the ADC pipeline on West 16th Street to the San Antonio Channel. The pipeline would be approximately 800 feet long and 36 inches in diameter and would include a flow control and air gap structure at its connection to the channel. The turnout vault would contain a flowmeter, a fixed orifice sleeve to reduce pressure head, and a check valve to prevent backflow. The water would then enter an air gap structure to ensure that stormwater from the channel would not enter into the turnout vault during high flow events and to maintain a constant discharge head from the turnout. From this structure, a connection would be made to the San Antonio Channel and a flap gate would be installed to further prevent backflow and to protect the conveyance facility from debris. Within the channel, energy dissipation head walls may be constructed instead of the fixed sleeve as a barrier from high velocity streams exiting the structure. Coordination with the Army Corps of Engineers would be

necessary to ensure compliance with all codes and standards.

The ADC pipeline has a capacity of 55 cfs (39,000 acre-ft/yr) and would only be available during the winter months after the SGVMWD has met the delivery requirements of its service area. The assumed capacity of this concept for the purposes of the RMPU is approximately 10,000 acre-ft/yr.

This project fills two roles in the RMPU: it increases the delivery capacity of imported water to the spreading basins on San Antonio Creek, and it provides a redundant means to deliver water to spreading basins on San Antonio Creek. Moreover, this project increases the supplemental water recharge capacity and improves the reliability of this part of the recharge system. The estimated capital cost to construct the facilities summarized herein is about \$2,636,000, and the annual cost, including O&M, is about \$172,000.

## **6.8 Master Plan Implementation Items**

Section 6.2 presented Watermaster's replenishment and recharge requirements over the period of 2010 to 2035. Watermaster is projected to require about 710,000 acre-ft of imported water to meet its replenishment and recharge obligations over this period. Most of the replenishment requirement will occur in the second half of this period. Preemptive replenishment will be required to control the CURO. At the September 2009 Watermaster Strategic Planning meeting, the Watermaster parties agreed to support preemptive replenishment and to purchase enough imported water to meet its recharge and replenishment obligations.

Section 6.3 presented a rigorous analysis of the supplemental water recharge capacity in the Chino Basin. The supplemental water recharge capacity of the existing spreading basins is about 99,000 acre-ft/yr but is limited to about 83,100 acre-ft/yr due to turnout limitations on the Rialto Pipeline. Existing ASR capacity for supplemental water recharge is about 5,600 acre-ft/yr. The total wet-water recharge capacity is 88,700 acre-ft yr. With preemptive replenishment, Watermaster has enough wet-water recharge capacity to meet its projected recharge and replenishment obligations. In-lieu recharge capacity ranges from about 25,000 to 40,000 acre-ft/yr. In-lieu recharge can be used to improve the balance of recharge and discharge in the basin. The total supplemental water recharge capacity ranges from 113,700 to 128,700 acre-ft yr.

Section 6.4 describes the existing or traditional sources of supplemental water available to the Watermaster for recharge, including imported water from Metropolitan and recycled water from the IEUA. CRA water from Metropolitan is not used for recharge in the Chino Basin due to its high TDS. In fact, the 2004 Basin Plan amendment requires that Watermaster and the IEUA recharge SWP water when its TDS is lowest. SWP water from Metropolitan has become less reliable and more expensive. Due to recent Federal Court rulings, Article 21 water has essentially disappeared, which is the type of SWP water that Metropolitan has traditionally used for replenishment service. Other issues, such as drought and Delta levee reliability, exacerbate the reliability challenge. On the positive side, the IEUA has been very successful in its recycled water recharge program. The recharge of recycled water increases

the production rights of several of the appropriator parties and reduces the demand for supplemental water for replenishment.

Section 6.5 discusses other supplemental water supplies that Watermaster could use in addition to Metropolitan and IEUA supplies. These nontraditional supplies include groundwater and surface water supplies from the Central Valley, groundwater from the Antelope Valley, groundwater and surface water supplies from the Colorado River Basin, and groundwater and surface water supplies in the Santa Ana Watershed, including a surface water diversion from the Santa Ana River located between the Riverside Narrows and the upstream limits of the Prado Reservoir. The issues related to acquiring these supplies is described in this Section and in more detail in Appendix D. Section 6.5 also discusses recycled water from RIX in Colton, from the City of Riverside, and from the WRCRWAP.

Section 6.6 contains recommendations regarding future supplemental supplies to meet Watermaster's recharge obligation: Watermaster will acquire supplemental water for recharge when it is available and in a manner that will limit the CURO to no more than 100,000 acre-ft. Watermaster will maximize its purchase of water from Metropolitan prior to looking at other imported water sources from outside the Santa Ana River Watershed. Watermaster will attempt to develop local projects—including stormwater recharge and potentially the acquisition of non-IEUA recycled water—to minimize the purchase of highly variable and unreliable imported supplies.

Section 6.7 contains descriptions of the three types of projects that either increase supplemental recharge capacity or supply, including improvements to turnouts from the Rialto or ADC pipelines (increase recharge capacity and reliability); the expansion of ASR capacity in the CVWD, JCSD, and Ontario service areas (increase recharge capacity, reliability, and improve the balance of recharge and discharge); and the importation of recycled water into the Chino Basin for direct recharge and to replace groundwater production (increase supplemental water supply and reliability). Given the groundwater production projections described in Section 4, there is no pressing need as of 2010 for the CBWCD, Watermaster, or the IEUA to implement any of the projects described in this section.

The conclusions and recommendations developed from this analysis are provided below.

1. Watermaster needs to acquire supplemental water to meet its replenishment and Peace Agreement obligations and the dilution requirements for the recharge of recycled water. These sources will include unused production rights from members of the Appropriative Pool, imported water from Metropolitan, and, if necessary, other non-Metropolitan imported water.
2. Because of the environmental and legal challenges involved in importing water from the Sacramento and San Joaquin Delta and the Colorado River, Watermaster should consider preemptive replenishment. Preemptive replenishment would limit the CURO to a sustainable level. Under such a scheme, Watermaster would estimate replenishment obligations for some future period, purchase supplemental water when available in advance of a replenishment obligation, bank that water in

the Chino Basin, and use that water for subsequent replenishment. Watermaster would revise the replenishment projection every year based on planning information provided by the parties and actual overproduction and replenishment. Watermaster should set an upper limit on the CURO and use this limit with the replenishment projections to guide its water acquisition activities.

3. Watermaster, upon reviewing the 2010 UWMPs and supply projections from Metropolitan, should make a determination of the need for non-Metropolitan imported water. This review should take place between July 2011 and December 2011, and this RMPU should be updated in January 2012.
4. If a need for non-Metropolitan imported water is determined, Watermaster should take action to acquire that water. Watermaster should go through this process at the conclusion of each UWMP report period or more frequently if statewide water supply conditions change significantly from those assumed in the then current RMPU. Potential sources of non-Metropolitan imported water are summarized in Section 6.5 of this RMPU and include: groundwater and surface water supplies from the Central Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities; groundwater from the Antelope Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities; groundwater and surface water supplies from the Colorado River Basin, conveyed to the Chino Basin through Metropolitan facilities; groundwater and surface water supplies in the Santa Ana Watershed that can be supplied to the Chino Basin directly or by exchange; and recycled water from RIX and the WRCRWAP. The importation of non-Metropolitan water is a very complex and expensive proposition—the planning of which is beyond the scope of this RMPU. The process to acquire and move imported water from the Central Valley is described in Appendix D, *Sierra Water Group Task Report for Supplemental Water Sources* (SWG, 2010).
5. Under the 2008 IEUA/Watermaster groundwater production projection, Watermaster will need to begin preemptive replenishment to manage the CURO to less than 100,000 acre-ft and to meet the MZ1 6,500 acre-ft/yr requirement. Significant replenishment water acquisition will be necessary after 2014/15—about five years from now.
6. No new recharge facilities will be required to meet Watermaster’s replenishment obligations through the planning period, provided that the Riverside Corona Feeder is completed within the next ten years. The Riverside Corona Feeder could supply treated SWP water to the JCSD in lieu of groundwater production, which would achieve replenishment and improve the balance of recharge and discharge in the JCSD area. Watermaster should monitor the progress of the Riverside Corona Feeder and adjust future RMPUs to reflect its efficacy.
7. Provided that the Parties construct ASR wells for their own use, Watermaster should consider the use of these wells for replenishment purposes to achieve an improved balance of recharge and discharge in the specific areas identified in the



*2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b). Specifically, this ASR replenishment should be targeted in the Pomona-MVWD production depression area and the Ontario-CVWD production depression area. Currently, the MVWD has four ASR wells that could be used for this purpose, and the CVWD and Ontario have plans to eventually construct ASR wells.

8. Watermaster should use in-lieu recharge to achieve an improved balance of recharge and discharge in the specific areas identified in the *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b), including the MZ1 managed area, the Pomona-MVWD production depression area, the JCSD well field area, and the Ontario-CVWD production depression area.

**Table 6-1**

**Projected Watermaster Recharge Obligation and an Example of Meeting the Recharge Obligation with Temporally Variable Supplemental Water Supplies and Preemptive Replenishment<sup>1</sup>**

(acre-ft)

Year	Watermaster Recharge Requirements				Example Watermaster Recharge Plan					Cumulative Unmet Replenishment Obligation <sup>2</sup>
	MZ1 Recharge Requirement	Net Replenishment Obligation	Total Recharge Obligation	Cumulative Recharge Obligation	Unproduced Production Rights	MZ1 Recharge <sup>3</sup>	Replenishment Obligation	Total Recharge	Cumulative Recharge	
2009 - 2010	6,500	0	6,500	6,500	36,199	5,000	0	41,199	41,199	-24,699
2010 - 2011	6,500	0	6,500	13,000	30,717	0	0	30,717	71,916	-48,916
2011 - 2012	6,500	0	6,500	19,500	27,077	0	0	27,077	98,994	-69,494
2012 - 2013	6,500	0	6,500	26,000	0	12,070	0	12,070	111,064	-75,064
2013 - 2014	6,500	2,794	9,294	35,294	0	12,070	0	12,070	123,134	-77,840
2014 - 2015	6,500	9,710	16,210	51,504	0	12,070	0	12,070	135,204	-73,699
2015 - 2016	6,500	8,420	14,920	66,424	0	12,070	0	12,070	147,274	-70,849
2016 - 2017	6,500	7,649	14,149	80,574	0	12,070	0	12,070	159,344	-68,770
2017 - 2018	6,500	12,675	19,175	99,748	0	12,070	0	12,070	171,414	-61,665
2018 - 2019	6,500	13,072	19,572	119,321	0	0	0	0	171,414	-42,093
2019 - 2020	6,500	13,782	20,282	139,602	0	0	0	0	171,414	-21,812
2020 - 2021	6,500	17,154	23,654	163,257	0	0	0	0	171,414	1,843
2021 - 2022	6,500	20,412	26,912	190,169	0	0	0	0	171,414	28,755
2022 - 2023	6,500	23,727	30,227	220,396	0	12,070	42,000	54,070	225,484	4,913
2023 - 2024	6,500	27,218	33,718	254,115	0	12,070	42,000	54,070	279,554	-15,439
2024 - 2025	6,500	30,858	37,358	291,473	0	12,070	42,000	54,070	333,624	-32,151
2025 - 2026	6,500	33,841	40,341	331,813	0	12,070	42,000	54,070	387,694	-45,880
2026 - 2027	6,500	36,766	43,266	375,079	0	12,070	42,000	54,070	441,764	-56,684
2027 - 2028	6,500	39,520	46,020	421,099	0	12,070	42,000	54,070	495,834	-64,734
2028 - 2029	6,500	42,114	48,614	469,713	0	0	0	0	495,834	-16,120
2029 - 2030	6,500	44,504	51,004	520,717	0	0	0	0	495,834	34,884
2030 - 2031	6,500	54,704	61,204	581,921	0	0	0	0	495,834	96,088
2031 - 2032	6,500	54,904	61,404	643,325	0	6,500	70,000	76,500	572,334	80,991
2032 - 2033	6,500	55,104	61,604	704,929	0	6,500	70,000	76,500	648,834	66,095
2033 - 2034	6,500	55,304	61,804	766,733	0	6,500	70,000	76,500	725,334	51,399
2034 - 2035	6,500	55,504	62,004	828,737	0	6,500	70,000	76,500	801,834	36,903
Totals	169,000	659,737	828,737		93,994	175,840	532,000	801,834		

1 -- Recharge requirements from Table 4-2

2 -- Assumes starting CURO is +10,000 acre-ft. Assumes unproduced appropriator rights are banked and eventually used to offset Watermaster's replenishment obligation.

3 -- Projected actual delivery for 2009-10.

**Table 6-2**  
**Calculation of the Availability of Spreading Basins for Supplemental Water Recharge**  
**Based on Precipitation Records at the Montclair/Claremont Gage Composite (1034 and 1137)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Total
<b>Days with Precipitation</b>													
Mean	5.06	4.91	5.02	3.02	1.27	0.32	0.17	0.19	0.59	1.51	2.50	3.68	28.23
Standard Deviation	3.71	3.33	3.54	2.37	1.45	0.58	0.40	0.48	1.06	1.50	2.04	2.69	9.35
Mean+Standard Deviation	8.77	8.24	8.56	5.39	2.72	0.90	0.57	0.68	1.65	3.01	4.54	6.37	37.58
Coefficient of Variation	73%	68%	71%	79%	114%	178%	239%	248%	179%	99%	82%	73%	33%
Skew	0.83	0.31	0.60	0.91	1.76	1.91	2.26	2.51	2.13	1.27	0.83	0.72	0.48
<b>Number of Precipitation Events</b>													
Mean	2.85	2.54	2.95	2.10	0.94	0.31	0.17	0.19	0.45	1.14	1.76	2.44	17.83
Standard Deviation	1.74	1.49	1.72	1.50	0.92	0.52	0.40	0.48	0.75	1.04	1.26	1.55	4.68
Mean+Standard Deviation	4.59	4.03	4.67	3.60	1.86	0.83	0.57	0.66	1.21	2.18	3.02	4.00	22.52
Coefficient of Variation	61%	59%	58%	71%	98%	170%	239%	257%	166%	91%	72%	64%	26%
Skew	0.42	0.29	0.29	0.69	0.79	1.45	2.26	2.62	1.83	1.00	0.55	0.23	0.33
<b>Number of Days per Event</b>													
Mean	1.77	1.93	1.70	1.44	1.36	1.06	1.00	1.05	1.31	1.33	1.42	1.50	1.58
Mean+Standard Deviation	1.91	2.04	1.83	1.50	1.47	1.09	1.00	1.02	1.37	1.38	1.50	1.59	1.67
<b>Precipitation per Month (in inches)</b>													
Mean	3.70	3.77	3.22	1.40	0.48	0.11	0.03	0.08	0.30	0.67	1.52	2.53	17.80
Standard Deviation	3.60	3.54	2.95	1.46	0.88	0.35	0.07	0.29	0.77	1.10	1.81	2.45	7.69
Mean+Standard Deviation	7.30	7.31	6.17	2.86	1.36	0.46	0.09	0.37	1.07	1.77	3.32	4.98	25.49
Coefficient of Variation	97%	94%	92%	104%	184%	323%	260%	358%	262%	163%	119%	97%	43%
Skew	1.44	1.16	1.22	1.96	3.06	6.42	3.69	5.79	3.92	3.75	2.29	1.16	0.57
<b>Basin Availability</b>													
Mean (days)													
Drawdown	3	3	3	3	1	1	1	1	1	2	2	3	18
Event	6	5	6	4	2	1	1	1	1	2	3	4	29
Total	9	8	9	7	3	2	2	2	2	4	5	7	47
Availability (fraction of the month)	<u>0.71</u>	<u>0.71</u>	<u>0.71</u>	<u>0.77</u>	<u>0.90</u>	<u>0.93</u>	<u>0.94</u>	<u>0.94</u>	<u>0.93</u>	<u>0.87</u>	<u>0.83</u>	<u>0.77</u>	<u>0.87</u>
Mean+Standard Deviation (days)													
Drawdown	5	5	5	4	2	1	1	1	2	3	4	4	23
Event	9	9	9	6	3	1	1	1	2	4	5	7	38
Total	14	14	14	10	5	2	2	2	4	7	9	11	61
Availability (fraction of the Month)	<u>0.55</u>	<u>0.50</u>	<u>0.55</u>	<u>0.67</u>	<u>0.84</u>	<u>0.93</u>	<u>0.94</u>	<u>0.94</u>	<u>0.87</u>	<u>0.77</u>	<u>0.70</u>	<u>0.65</u>	<u>0.83</u>

**Table 6-3  
Supplemental Water Recharge Capacity Estimates<sup>1</sup>**


(1)  Basin	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18)	(19)	(20)	(21)	(22)	(23)	(24)	
	Supplemental Water Recharge																							
	Operational Availability for Supplemental Water Recharge												Average Recharge Rate <sup>2</sup>	Supplemental Water Recharge Capacity	Turn Out Capacity				Theoretical Maximum Imported Water Recharge Capacity					
	Quarter 3			Quarter 4			Quarter 1			Quarter 2					Turn Out Name	Max Discharge Rate	Useful Discharge Rate	Turn Out Limited <sup>3</sup> ?	Annual	Q3	Q4	Q1	Q2	
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(cfs)	(acre-ft/yr)										(cfs)
Brooks Street Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	5	2,474				No	2,474	652	794	281	746	
College Heights Basins	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	15	7,421				No	7,421	1,957	2,383	843	2,238	
Montclair Basin 1	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
Montclair Basin 2	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77			OC59	300	300							
Montclair Basin 3	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	40	19,789				No	19,789	5,219	6,355	2,247	5,968	
Montclair Basin 4	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
Seventh and Eighth Street Basins	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	5	2,474	CB20	30	30	No	2,474	652	794	281	746	
Upland Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	20	9,895	OC59	80	80	No	9,895	2,610	3,177	1,124	2,984	
<b>Subtotal Management Zone 1</b>														<b>42,052</b>					<b>42,052</b>	<b>11,091</b>	<b>13,504</b>	<b>4,775</b>	<b>12,682</b>	
Ely Basins	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	5	2,474	CB20	30	30	No	2,474	652	794	281	746	
Etiwanda Spreading Area (Joint Use of Etiwanda Debris Basin)	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	7	3,463	CB14	30	30	No	3,463	913	1,112	393	1,044	
Hickory Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	5	2,474	CB18	30	30	Yes	2,061	544	662	234	622	
Lower Day Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	9	4,453	CB15	30	20	No	4,453	1,174	1,430	506	1,343	
San Sevaine No. 1	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
San Sevaine No. 2	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
San Sevaine No. 3	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	50	24,736	CB13	30	23	Yes	11,379	3,001	3,654	1,292	3,432	
San Sevaine Nos. 4 and 5	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
Turner Basins Nos. 1 and 2	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	3	1,484	CB11	40	9	No	1,484	391	477	169	448	
Turner Basins Nos. 3 and 4	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77												
Victoria Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	6	2,968	CB14	30	30	No	2,968	783	953	337	895	
<b>Subtotal Management Zone 2</b>														<b>42,052</b>					<b>28,282</b>	<b>7,459</b>	<b>9,082</b>	<b>3,211</b>	<b>8,529</b>	
Banana Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	5	2,474					2,061	544	662	234	622	
Decluz Basin	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	6	2,968	CB18	30	30	Yes	2,474	652	794	281	746	
IEUA RP3 Ponds	0.71	0.71	0.74	0.80	0.90	0.93	0.00	0.00	0.93	0.87	0.83	0.77	20	9,895					8,245	2,175	2,648	936	2,487	
<b>Subtotal Management Zone 3</b>														<b>15,337</b>					<b>12,780</b>	<b>3,371</b>	<b>4,104</b>	<b>1,451</b>	<b>3,854</b>	
<b>Total</b>														<b>99,440</b>					<b>83,114</b>	<b>21,920</b>	<b>26,690</b>	<b>9,438</b>	<b>25,066</b>	

1 -- Historical recharge estimates provided by IEUA. Recharge basins not optimized for storm water recharge; actual recharge performance could be improved.


2 -- Per Andy Campbell of IEUA, August 2007


3 -- Turn Out Capacity for the San Sevaine Basins is 30 cfs but is limited to 23 cfs due to operational considerations on the Rialto Feeder; 23 cfs assumed.

**Figure 6-1  
Projected Recharge Obligation Pursuant to the Judgment and the Peace Agreement**



**Figure 6-2**  
**Example of a Future Watermaster Recharge Scenario with Temporally Variable Supplemental**  
**Water Supplies and Preemptive Replenishment**





Recharge Basins (Symbolized by Improvements)

- Chino Basin Facilities Improvement Project
- Improvement By Others
- No Improvements

Imported Water Facilities

- Service Connection/Turnout
- Imported Water Pipeline

Drainage Areas

- San Antonio Creek System
- West Cucamonga Creek System
- Cucamonga and Deer Creek Systems
- Lower Cucamonga Creek System
- Day Creek System
- San Sevaine and Etiwanda Creek Systems

Faults

- Location Certain
- Location Uncertain
- Location Approximate
- Approximate Location of Groundwater Barrier
- Location Concealed


Other Features

- MODFLOW Groundwater Flow Model Boundary
- Streams, Rivers, and Channels




Produced by:  
 WILDERMUTH ENVIRONMENTAL INC.  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100409  
 File: Figure\_6-3.mxd



Groundwater Recharge and Imported Water Facilities

Figure 6-3



**Aquifer Storage and Recovery Wells**

- City of Ontario
- Monte Vista Water District
- Cucamonga Valley Water District
- Jurupa Community Services District

**Existing Production Wells**

- Production Wells

**Geology**

- Water-Bearing Sediments**
- Quaternary Alluvium
- Consolidated Bedrock**
- Undifferentiated Pre-Tertiary to Early Pleistocene Igneous, Metamorphic, and Sedimentary Rocks

**Faults**

- Location Certain
- Location Uncertain
- Location Approximate
- Approximate Location of Groundwater Barrier
- Location Concealed


**Other Features**

- Groundwater Divides
- Flood Control/Conservation Basins
- Streams, Rivers, and Channels



Produced by:  
**WILDERMUTH**  
 ENVIRONMENTAL INC.  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100409  
 File: Figure\_6-4.mxd




2010 Recharge Master Plan Update

**Existing and Proposed Aquifer Storage and Recovery Wells**


**Figure 6-4**




**Figure 6-5a**  
**SWP Table A Delivery Probability under Current Conditions**







**Figure 6-5b**  
**SWP Table A Delivery Probability under Future Conditions**






**Main Features**

-  Existing IEUA Recycled Water Distribution Pipeline
-  Proposed Pipeline
-  Planned Riverside Corona Feeder
-  Streams, Rivers, and Channels




Produced by:  
  
 23692 Bircher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100409  
 File: Figure\_6-6.mxd






**RIX Recycled Water Connection to the IEUA Distribution System**

**Figure 6-6**



Main Features

-  Existing IEUA Recycled Water Distribution Pipeline
-  Proposed Pipeline
-  Streams, Rivers, and Channels




Produced by:



23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com


Author: MJC  
 Date: 20100409  
 File: Figure\_6-7.mxd



2010 Recharge Master Plan Update

WRCRWAP Recycled Water Connection to the IEUA Distribution System

Figure 6-7



Author: MJC Date: 20100409 File: Figure 6-8.mxd

Produced by:


**WILDERMUTH**  
ENVIRONMENTAL INC.

23692 Birtcher Drive  
Lake Forest, CA 92630  
949.420.3030  
www.wildermuthenvironmental.com







- ASR Well
- Imported Water Pipeline



Cucamonga Valley Water District ASR Wells



**Main Features**

-  Imported Water Pipeline
-  Proposed Pipeline
-  Planned Riverside Corona Feeder
-  ASR Well
-  Streams, Rivers, and Channels
-  Turnout Vault



Produced by:




23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC

Date: 20100409

File: Figure\_6-9.mxd



2010 Recharge Master Plan Update


**Jurupa Community Services District  
 ASR Wells**

**Figure 6-9**



Author: MJC  
 Date: 20100409  
 File: Figure 6-10.mxd








Produced by:  
  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

 ASR Well





**Main Features**

-  Imported Water Pipeline
-  Proposed Pipeline
-  Proposed Turnout
-  Existing MWDSC Turnout
-  Flood Control/Conservation Basins
-  Streams, Rivers, and Channels
-  Flow Control and Air Gap Structures




Produced by:



23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100409  
 File: Figure\_6-11.mxd



2010 Recharge Master Plan Update






**Turnout to San Sevaine Basin No.1  
 via ADC or Etiwanda Pipelines**

**Figure 6-11**






Main Features

-  ADC Pipeline
-  Proposed Pipeline
-  Proposed Turnout
-  Streams, Rivers, and Channels
-  Flow Control and Air Gap Structures



Produced by:  
  
 23692 Birtcher Drive  
 Lake Forest, CA 92630  
 949.420.3030  
 www.wildermuthenvironmental.com

Author: MJC  
 Date: 20100409  
 File: Figure\_6-12.mxd



2010 Recharge Master Plan Update

Turnout to San Antonio Channel via ADC

Figure 6-12

## Section 7 – Recharge Master Plan Update

---

This section contains the conclusions and recommendations of the RMPU. These conclusions and recommendations are grouped under the following subsections: Stormwater Management, Regional Stormwater Recharge Facilities, Supplemental Water for Replenishment, Supplemental Water Recharge Facilities, and Future RMPU Process. The nexus between the Court’s Requirement for the RMPU and the information presented in this report is summarized in Table 7-1.

### **7.1 Local Stormwater Management and Mitigation of the Loss of Safe Yield**

Section 3 describes the range of new stormwater recharge that could result from implementing the 2010 MS4 permit. Based on the requirements of the permit, the expected new stormwater recharge could range from about 5,300 acre-ft/yr (if 50 percent of the stormwater required to be managed by the permit is recharged) to about 10,500 acre-ft/yr (if 100 percent of the stormwater required to be managed by the permit is recharged).

Section 3 also describes the new recharge potential of existing developed areas. Applying the same criteria from the MS4 permit to the developed areas yields, on average, between 19,000 acre-ft/yr and 38,000 acre-ft/yr of new recharge. Watermaster, working with the landuse control entities, should encourage development practices that will maximize the capture and recharge of stormwater. New recharge, as used herein, means the net new recharge created by the project. The following should be implemented by the CBWCD, the IEUA, Watermaster, and other stakeholders.

1. Watermaster should allocate new yield that is created by new recharge above that required by MS4 permit compliance to the owners of those projects that create new recharge. This will require the development of (a) new agreements involving the Watermaster, project owners, and others, and (b) the development of new practices and procedures that can quantify new recharge during project development and subsequently verify that the new recharge is occurring during the project lifetime.
2. Watermaster, working with the Parties, should encourage the construction of local recharge projects in developed areas that will increase the capture and recharge of stormwater. The recommendations for local stormwater recharge projects in developed areas are the same as those for newly developed areas, articulated above.
3. In implementing the above, Watermaster should form a committee—consisting of itself, the landuse control entities, the County Flood Control Districts, the CBWCD, the IEUA, and others—to develop the monitoring, reporting, and accounting practices that will be required to estimate local project stormwater recharge and new yield. This committee should be formed immediately, and the monitoring, reporting, and accounting practices should be developed as soon as possible.

## 7.2 Regional Stormwater Recharge Facilities

Section 3 describes the existing long-term average stormwater recharge from existing stormwater management facilities, including the CBFIP facilities constructed as part of the implementation of the OBMP. The long-term average annual stormwater recharge with the recharge facilities existing in 2009-10 is estimated to be about 13,600 acre-ft/yr, and this recharge will increase slightly over time with new development (See Table 3-8). This estimate is based on the *2006 Chino Basin Recharge Facilities Operation Procedures Manual* (GRCC, 2006) with some operating procedure modifications, provided by the IEUA. Section 5 describes the existing and potential stormwater management facilities and demonstrates that more new stormwater recharge is possible; although, the cost for some future recharge projects will be significant. WBE, the firm that authored Section 5, developed and analyzed several individual new and enhanced projects and project configurations. The embedded table in Section 5.5.8 summarizes the recharge performance and associated costs of the proposed new stormwater projects. WBE grouped these projects and configurations into five phases with the total recharge and unit cost of new stormwater recharge increasing with each phase. The recharge and unit cost of recharge for each phase is summarized below.

Phase	Range of Recharge		Range of Annual Cost		Range of Unit Cost	
	75% of Theoretical	Theoretical	WBE Cost Opinion	WBE Cost Opinion + 15%	Min	Max
	(ac-ft/yr)	(ac-ft/yr)			(\$/ac-ft)	(\$/ac-ft)
I	5,800	7,700	\$1,652,000	\$1,900,000	\$215	\$328
II	6,000	8,100	\$2,601,000	\$2,991,000	\$321	\$499
III	8,400	11,300	\$5,605,000	\$6,446,000	\$496	\$767
IV	10,200	13,600	\$14,800,000	\$17,039,000	\$1,088	\$1,670
Va	11,900	15,900	\$19,306,000	\$22,202,000	\$1,214	\$1,866
Vb	11,900	15,900	\$14,692,000	\$17,206,000	\$924	\$1,446

Through the RMPU workshop process, the stakeholder's expressed interest in pursuing Phases I through III as the unit cost of new stormwater recharge is comparable to the cost of imported supplies and new stormwater recharge will be more reliable than imported water. The implementation of Phases IV and V will be deferred until a future time as the projects in these phases are significantly more expensive.

Based on the most current information, the recharge projects described in Phases I through III are estimated to produce a long-term average annual stormwater recharge increase of 8,400 acre-ft/yr to 11,300 acre-ft/yr at cost of about \$500 to \$800 per acre-ft. The new yield from these projects will reduce the future replenishment obligation by the amount of new yield.

Several issues will need to be resolved to refine, design, and implement these projects. Substantial planning work will be required to implement the Phase I through III projects to ensure that the recharge potential of the projects can be realized. In addition to environmental documentation, this planning work will involve the development of a financing plan, engineering investigations, and the development of an agreement with the SBCFCD regarding the modification and operation of stormwater facilities. The CBWCD, IEUA, and

Watermaster should conduct further analyses of the Phase I through III projects to refine the projects, to develop a financing plan, and to develop an implementation plan. This planning work should begin as soon as practical and could be accomplished within three years. The schedule to implement the Phase I through III projects would be developed during the proposed planning work, and the construction of these projects could be completed within five years of completing the proposed planning work.

During the preparation of the RMPU, an independent effort to develop a new multipurpose stormwater management and recreation facility East of Archibald Avenue and south of Deer Creek commenced. Herein, this project is referred to as the Turner Basins/Guasti Park project. The specifics of this project are still unknown. However, hydrologic simulations were conducted, based on a project description that was received in April 2010 using the same model and procedure (see Appendix C, *Summary of the R4 Model for the Chino Basin*) that was used to analyze the potential new stormwater recharge projects described in Section 5. Based on the April 2010 project concept drawings, the potential new stormwater recharge was estimated to be about 1,300 acre-ft/yr. This basin could also be used to recharge supplemental water. A cost opinion to construct and operate this proposed project is not available. Recharge in this location will help manage groundwater levels in the Ontario-CVWD production depression area.

### **7.3 Supplemental Water for Replenishment**

The RMPU must be submitted to the Court by July 1, 2010, which is one year earlier than when retail water agency UWMPs are due and six months earlier than when wholesale water agency UWMPs are due. In lieu of having updated groundwater projections from the 2010 UWMPs, two groundwater production projections were developed in the RMPU to bound the possible groundwater production projections. These production projections are discussed in Section 4 of this report and are shown in Tables 4-1 through 4-2. The means to satisfy these estimated replenishment projections are described in Section 6. Section 6 also discusses the availability and reliability of the traditional water supplies used for replenishment and the possibility of new supplemental water sources. The conclusions and recommendations developed from this analysis are described below.

1. Watermaster needs to acquire supplemental water to meet its replenishment and Peace Agreement obligations and the dilution requirements for the recharge of recycled water. These sources will include unused production rights from members of the Appropriative Pool, imported water from Metropolitan, and, if necessary, other non-Metropolitan imported water.
2. Because of the environmental and legal challenges involved in importing water from the Sacramento and San Joaquin Delta and the Colorado River, Watermaster should consider preemptive replenishment. Preemptive replenishment would limit the CURO to a sustainable level. Under such a scheme, Watermaster would estimate replenishment obligations for some future period, purchase supplemental water when available in advance of a replenishment obligation, bank that water in the Chino Basin, and use that water for subsequent replenishment. Watermaster

would revise the replenishment projection every year based on planning information provided by the parties and actual overproduction and replenishment. Watermaster should set an upper limit on the CURO and use this limit with the replenishment projections to guide its water acquisition activities.

3. Watermaster, upon reviewing the 2010 UWMPs and supply projections from Metropolitan, should make a determination of the need for non-Metropolitan imported water. This review should take place between July 2011 and December 2011, and this RMPU should be updated in January 2012.
4. If a need for non-Metropolitan imported water is determined, Watermaster should take action to acquire that water. Watermaster should go through this process at the conclusion of each UWMP report period or more frequently if statewide water supply conditions change significantly from those assumed in the then current RMPU. Potential sources of non-Metropolitan imported water are summarized in Section 6 of this RMPU and include: groundwater and surface water supplies from the Central Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities; groundwater from the Antelope Valley, conveyed to the Chino Basin through SWP and Metropolitan facilities; groundwater and surface water supplies from the Colorado River Basin, conveyed to the Chino Basin through Metropolitan facilities; groundwater and surface water supplies in the Santa Ana Watershed that can be supplied to the Chino Basin directly or by exchange; and recycled water from RIX and the WRCRWAP. The importation of non-Metropolitan water is a very complex and expensive proposition—the planning of which is beyond the scope of this RMPU. The process to acquire and move imported water from the Central Valley is described in Appendix D, *Sierra Water Group Task Report for Supplemental Water Sources* (SWG, 2010).
5. Under the 2008 IEUA/Watermaster groundwater production projection, Watermaster will need to begin preemptive replenishment to manage the CURO to less than 100,000 acre-ft and to meet the MZ1 6,500 acre-ft/yr requirement. Significant replenishment water acquisition will be necessary after 2014/15—about five years from now.

## **7.4 Supplemental Water Recharge Facilities**

1. No new recharge facilities will be required to meet Watermaster’s replenishment obligations through the planning period, provided that the Riverside Corona Feeder is completed within the next ten years. The Riverside Corona Feeder could supply treated SWP water to the JCSD in lieu of groundwater production, which would achieve replenishment and improve the balance of recharge and discharge in the JCSD area. Watermaster should monitor the progress of the Riverside Corona Feeder and adjust future RMPUs to reflect its efficacy.
2. Provided that the Parties construct ASR wells for their own use, Watermaster should consider the use of these wells for replenishment purposes to achieve an improved balance of recharge and discharge in the specific areas identified in the

*2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b). Specifically, this ASR replenishment should be targeted in the Pomona-MVWD production depression area and the Ontario-CVWD production depression area. Currently, the MVWD has four ASR wells that could be used for this purpose, and the CVWD and Ontario have plans to eventually construct ASR wells.

3. Watermaster should use in-lieu recharge to achieve an improved balance of recharge and discharge in the specific areas identified in the *2009 Production Optimization and Evaluation of the Peace II Project Description* (WEI, 2009b), including the MZ1 managed area, the Pomona-MVWD production depression area, the JCSD well field area, and the Ontario-CVWD production depression area.

## **7.5 Future RMPU Process**

The December 21, 2007 Court order requires the completion of this RMPU by July 1, 2010 and, at a minimum, every five years thereafter. The RMPU process is very sensitive to projected groundwater production. By statute, groundwater production projections are prepared for UWMPs every five years and in years ending in “0” or “5.” Watermaster, the CBWCD, and the IEUA should review the groundwater production projections from the retail water purveyors’ 2010 UWMPs after their completion in June 2011<sup>13</sup> to update the groundwater production projections included herein and revise the conclusions and recommendations of the 2010 RMPU to comport with the 2010 UWMPs. The conclusions in Section 6 regarding the acquisition of supplemental water for replenishment and new supplemental water recharge facilities should be updated in fiscal 2011-12. Decisions regarding the acquisition of supplemental water for replenishment and new supplemental water recharge facilities should be deferred until that time.

The next RMPU should be completed no later than December 2016, and subsequent RMPUs should be completed, at a minimum, every five years thereafter. This will ensure that the most up-to-date groundwater production estimates are included in future RMPUs.

---

<sup>13</sup> The deadline for completing the 2010 UWMPs for retail water agencies was extended by special legislation to June 30, 2011 for the 2010 UWMP. Subsequent UWMPs are required to be submitted to the DWR by December 31<sup>st</sup> of the year due.

**Table 7-1  
Comparison of the Court's RMPU Requirements and How Those Requirements are Addressed in the RMPU**

Requirement		How Requirement is Met in the RMPU	
		Where in RMPU	Specific Actions
1	Baseline conditions must be clearly defined and supported by technical analysis. The baseline definition should encompass factors such as pumping, demand, recharge capacity, total Basin water demand, and availability of replenishment water.	Sections 4, 6, and 7	Section 4 describes total projected water demand and the associated water supply plans based on projections by the IEUA and Watermaster. Section 6 describes the supplemental water recharge capacity and the availability of supplemental water for replenishment and, in particular, reviews the ability to acquire water for replenishment from Metropolitan. Section 7 contains specific recommendations for the acquisition of supplemental water through the next recharge master plan update.
2	Safe Yield should be estimated annually, though it is recognized that it is not to be formally recalculated until 2011. Watermaster should develop a technically defensible approach to estimating Safe Yield annually.	Section 3	Section 3 describes the computation of safe yield and presents a recommended method to compute safe yield during 2010-11 and subsequent years. Watermaster will likely use its discretion to determine when to recompute safe yield after 2010-11.
3	Measures should be evaluated to lessen or stop the projected Safe Yield decline. All practical measures should be evaluated in terms of their potential benefits and feasibility.	Sections 3, 5, and 7	Section 3 describes the causes of a declining safe yield and suggests that the safe yield could drop from the current value of 140,000 acre-ft/yr to 129,000 acre-ft/yr by 2030. Section 3 also describes the expected increase in safe yield of 5,300 acre-ft/yr to 10,500 acre-ft/yr due to compliance with the 2010 MS4 permits. Section 5 includes descriptions of new stormwater recharge projects that could yield between 10,000 to 15,000 acre-ft/yr. Most of the projects described in Section 5 will require more detailed planning and new agreements with the Counties to determine their ultimate feasibility. Section 7 summarizes the recommended next steps in estimating and crediting the new recharge from the implementation of MS4 and in the implementation of the proposed new stormwater recharge projects.
4	Evaluations and reporting of the impact of Basin Re-Operation on groundwater storage and water levels should be done on an annual basis.		Strictly speaking, this is not an RMPU issue and is not covered in the 2010 RMPU. Watermaster analyzes the impact of Basin Re-Operation on groundwater storage and water levels in the southern part of the Basin annually and basin wide every two years. The data and results of these analyses are published in the Hydraulic Control Monitoring Report each year (on or before April 15) and the State of the Basin Report every two years.
5	Total demand for groundwater should be forecast for 2015, 2020, 2025, and 2030. The availability of imported water for supply and replenishment, and the availability of recycled water should be forecast on the same schedule. The schedules should be refined in each Recharge Master Plan update. Projections should be supported by thorough technical analysis.	Sections 4 and 6	Section 4 contains the demand for groundwater forecasted for 2010, 2015, 2020, 2025, 2030, and 2035. Section 6 describes the availability of imported water for supply and replenishment as forecasted through 2030, based on the draft <i>2009 SWP Delivery Reliability Report</i> (DWR, 2010). Section 6 also describes the current and future recycled water recharge projections from the IEUA.
6	The Recharge Master Plan must include a detailed technical comparison of current and projected groundwater recharge capabilities and current and projected demands for groundwater. The Recharge Master Plan should provide guidance as to what should be done if recharge capacity cannot meet or is projected not to be able to meet replenishment needs. This guidance should detail how Watermaster will provide sufficient recharge capacity or undertake alternative measures so that Basin operation in accordance with the Judgment and the Physical Solution can be resumed at any time.	Section 6	Section 6 describes the recharge capacity of existing spreading basins, existing ASR wells, future ASR wells, and existing in-lieu recharge capacity. Section 6 concludes that Watermaster, given present knowledge and agreements, will not be replenishment constrained by recharge capacity. That is, Watermaster has enough installed recharge capacity to meet current and future replenishment obligations through 2030.
7	Address how the Basin will be contemporaneously managed to secure and maintain Hydraulic Control and subsequently operated at a new equilibrium at the conclusion of the period of Re-Operation.		The technical work to make this demonstration was done in 2009 and is reported separately in <i>2009 Production Optimization and Evaluation of the Peace II Project Description</i> (WEI, 2009), which has been posted to the RMPU website <a href="http://rmp.wildermuthenvironmental.com">rmp.wildermuthenvironmental.com</a> .
8	Contain recharge estimations and summaries of the projected water supply availability as well as the physical means to accomplish the recharge projections.	Sections 3, 4, 5, and 6	Section 3 contains recharge projections for stormwater for existing facilities and new recharge from the 2010 MS4 permit. Section 4 contains a schedule of the future recharge requirements for Watermaster to meet its replenishment obligations. Section 5 contains descriptions of new recharge projects, recharge performance, and cost and implementation issues. Section 6 describes the supplemental water supplies available to Watermaster to meet its replenishment obligation and new supplemental water recharge projects that could be implemented to provide Watermaster with additional recharge capacity and supplemental water, and flexibility in meeting its replenishment obligation.
9	Reflect an appropriate schedule for planning, design, and physical improvements as may be required to provide reasonable assurance that sufficient Replenishment capacity exists to meet the reasonable projections of Desalter Replenishment obligations following the implementation of Basin Re-Operation.	Section 7	Section 7 describes the recommended recharge master plan. This section describes the means to stop the projected loss of safe yield, increase stormwater recharge, and acquire supplemental water for replenishment purposes. No new recharge facilities are required to meet replenishment obligations. Detailed scheduling of new stormwater recharge facilities should be deferred until additional planning information is developed to refine these projects. The decision to acquire new supplemental water sources should be deferred until updated groundwater production projections become available in late 2011-12. The RMPU should be updated in the second half of 2011-12 and subsequent years ending in "1" and "6."

## Section 8 – References

---

- Albert Webb and Associates. (1969). *Analysis of the Flow of the Santa Ana River at the Riverside Narrows in Riverside County, San Diego*. (Per Wagner & Bonsignore)
- Asta Construction Inc., S. Schmitt, personal communication, 2009. (Per Wagner & Bonsignore)
- Beno, Van Dyk & Owens. (2009). *CBWCD Basin Search*. January 25, 2009. (Per Wagner & Bonsignore)
- Black & Veatch. (2008). *Chino Basin Dry-Year Yield Program Expansion, Project Development Report*, (Vols. I-IV). Prepared for the Inland Empire Utilities Agency.
- Black & Veatch. (2010). *Chino Basin Recharge Master Plan Update Technical Memorandum: Supplemental Water Recharge Concept Development*.
- Black & Veatch, & Wildermuth Environmental, Inc. (2009). *2010 Recharge Master Plan Update Technical Memorandum: Task 3 Planning Criteria*. Prepared for the Chino Basin Watermaster.
- California Department of Transportation. C. Jochai, R. King, & C. Kuo, personal communication. (Per Wagner & Bonsignore)
- California Department of Water Resources. (2005). *The State Water Project Delivery Reliability Report, 2005*. Retrieved from [http://baydeltaoffice.water.ca.gov/swpreliability/SWPre105\\_final.pdf](http://baydeltaoffice.water.ca.gov/swpreliability/SWPre105_final.pdf)
- California Department of Water Resources. (2009). *The State Water Project Delivery Reliability Report, 2005*. Retrieved from [http://baydeltaoffice.water.ca.gov/swpreliability/Final\\_DRR\\_2007\\_011309.pdf](http://baydeltaoffice.water.ca.gov/swpreliability/Final_DRR_2007_011309.pdf)
- California Department of Water Resources. (2009). *Using Future Climate Projections to Support Water Resources Decision Making in California*.
- California Department of Water Resources. (2009). *Draft – The State Water Project Delivery Reliability Report, 2009*. Retrieved from <http://baydeltaoffice.water.ca.gov/swpreliability/DRAFT-DelRelRep2009.pdf>
- California Regional Water Quality Control Board, Santa Ana Region. (2009). *Order No. R8-2009-057, Amending Order No. R9-2007-0039, Water Recycling Requirements for the Inland Empire Utilities Agency and Chino Basin Watermaster, Chino Basin Recycled Water Groundwater Recharge Program Phase I and Phase II Projects, San Bernardino County*.
- California Storm Water Quality Association. (2003). *Stormwater Best Management Practice Handbooks – New Development and Redevelopment, Industrial and Commercial, Municipal*. (Per



- Wagner & Bonsignore)
- Chicago Bridge and Iron. M. Scott, personal communication, 2010. (Per Wagner & Bonsignore)
- Chino Basin Municipal Water District vs. City of Chino, et al. (1977). Case No. 164327. Superior Court of California, County of San Bernardino.
- Chino Basin Water Conservation District. E. Ulloa, Personal communication, 2009. (Per Wagner & Bonsignore)
- Chino Basin Watermaster. (1978-2008). *Annual Reports, Fiscal Years 1977-78 through 2007-08*. (Per Wagner & Bonsignore)
- Chino Basin Watermaster. (2001). *Rules and Regulations*. Retrieved from <http://www.cbwm.org/docs/rulesregs/CBWM%20Rules%20and%20Regulations.pdf>
- Chino Basin Watermaster. (2009). *CBWM Small Basins*. (Project binder, February 2, 2009.) (Per Wagner & Bonsignore)
- Chino Basin Watermaster. B. Pak, personal communication, 2009. (Per Wagner & Bonsignore)
- City of Chino. Detention basin and swale inventory, data and information provided February 2009. Additional data and information provided April through June 2009. Personal communication with Jesus Plasencia, 2009. (Per Wagner & Bonsignore)
- City of Chino Hills. *Storm Drain Inlet/Outlet and Detention Basin Maintenance Book*. Provided April 28, 2009. (Per Wagner & Bonsignore)
- City of Chino Hills. S. Nix, personal communication, April and May 2009. (Per Wagner & Bonsignore)
- City of Fontana. Storm water and detention basin data and information provided March 18, 2009. J. Tesley Personal communication, March 2009. (Per Wagner & Bonsignore)
- City of Montclair. Storm water and detention basin data and information provided April 2009. WQMP Template and NPDES Permit (provided July 2009). J. Rosales, personal communication, 2009. (Per Wagner & Bonsignore)
- City of Ontario. Storm water and detention basin data and information provided March 2009. Updates provided in May and June 2009. S. Wilson, & R. Lee, personal communication, 2009. (Per Wagner & Bonsignore)
- City of Rancho Cucamonga. Storm water and detention basin data and information provided May and June 2009. J. Stofa, & C.A. Cambare, personal communication, 2009. (Per Wagner & Bonsignore)

- City of Upland. Storm water and detention basin data and information provided March and August 2009. S. Martinez, personal communication, 2009. (Per Wagner & Bonsignore)
- County of Los Angeles Department of Public Works. Bid Summary, Termino Avenue Drain, Bid Opened 4/21/2009; Bid Summary, Rio Hondo Coastal Basin Spreading Ground Interbasin Repair, Bid Opened 5/12/2009; Bid Summary, Avenue K, 36-Inch Transmission Main, Phase 1, Bid Opened 7/7/2009. (Per Wagner & Bonsignore)
- Freeze, A., & Cherry, J. (1979). *Groundwater*. Englewood Cliffs: Prentice-Hall.
- G3 Engineering. Pump Quote, 1/18/2010. J. Bly, personal communication, 2010. (Per Wagner & Bonsignore)
- Ghilotti Construction Co. Inc. J. Moreira, personal communication, 2010. (Per Wagner & Bonsignore)
- Groundwater Recharge Coordinating Committee. (2006). *2006 Chino Basin Recharge Facilities Operation Procedures Manual*.
- HDD Company, Inc. R. Evans, personal communication, 2010. (Per Wagner & Bonsignore)
- Inland Empire Utilities Agency. *Chino Basin Groundwater Recharge Program – Recharge Basin Spill Points*, provided January 2009. Storm water and detention basin physical and operational data provided 2009. Chino Basin Facilities Improvement Project, Bid Package 3 – Jurupa Basin Force Main, Bid Open 7/10/2003. Chino Basin Facilities Improvement Project, Bid Package 4 – Jurupa Basin Pump Station, Bid Open 11/21/2003. A. Campbell, personal communication, 2009. (Per Wagner & Bonsignore)
- Inland Empire Utilities Agency. (2008). *Final Water Demand and Supply Forecasts for the Chino Basin Dry Year Yield Expansion Project CEQA Analysis – Technical Memo #2, Supplement to the April 16, 2008 IEUA Tech Memo #1 – Net Groundwater Replenishment Obligations through 2015 Based Upon Projected Water Demand and Available Supplies in the Chino Basin*.
- Inland Empire Utilities Agency. (2010). *Integrated Review of Water Supply Plans Used for the Chino Basin Recharge Master Plan Update – Technical Memo #3*.
- Jensen Precast. Box Culvert Quote. J. Merrill, personal Communication, 2010. (Per Wagner & Bonsignore)
- J. M. Squared Associates Inc. M. Vesely, personal communication, 2010. (Per Wagner & Bonsignore)
- Joint Engineering Committee. (1969). *Appendix A, Basic Data* (Vol. I).

- Metropolitan Water District of Southern California. (2009). *\$45,515,000: The Metropolitan Water District of Southern California Waterworks General Obligation Refunding Bonds, 2009 Series A*. Retrieved from [http://www.mwdh2o.com/mwdh2o/pages/finance/fos\\_01.pdf](http://www.mwdh2o.com/mwdh2o/pages/finance/fos_01.pdf)
- MS Construction Management Group. M. Saghafi, personal communication, 2010. (Per Wagner & Bonsignore)
- Obermeyer Hydro Inc. *Flow Characteristics of Spillways Equipped With Obermeyer Hydro, Inc. Pneumatic Crest Gates*. Model test data for pneumatic gate panel under high velocity flow conditions. R. Eckman, personal communication, 2010. (Per Wagner & Bonsignore)
- Peace Agreement, Chino Basin. SB 240104 v 1:08350.0001. 29 June 2000.
- R.S. Means Company, Inc. *Heavy Construction Cost Data* (23<sup>rd</sup> ed.). . (Per Wagner & Bonsignore)
- San Bernardino Flood Control District. Detention Basin Design Criteria for San Bernardino County, unknown date. Zone 1 Project Systems Inventory, Revised October 1975. SBCFCD Zone 1 facility drawings provided March 2009. J. McKenzie, Jr., personal Communication, 2009. (Per Wagner & Bonsignore)
- Santa Ana River Watermaster. *Annual Reports of the Santa Ana River Watermaster*. (Per Wagner & Bonsignore)
- Schneider, A. (2007). *Final Report and Recommendations on Motion for Approval of Peace II Documents*.
- Sierra Water Group. (2010). *Water Transfers Report*.
- StormTech. *Design Manual – StormTech Chamber Systems for Stormwater Management*. Retrieved from [www.stormtech.com](http://www.stormtech.com) (accessed March 2009). (Per Wagner & Bonsignore)
- Tom Dodson & Associates. (2005). *RIX Facility Recycled Water Sales Program – Program Environmental Impact Report*. Prepared for City of San Bernardino Municipal Water Department.
- Torrent Resources, Inc. *BMP Description, Design and Installation Features – The MaxWell Plus Drainage System* (unknown date). *MaxWell Plus – Drainage system Product Information and Design Features, November 2004*. R. Williams (Technical Marketing Representative), personal communication, June 2009. (Per Wagner & Bonsignore)
- University of New Hampshire Stormwater Center (Roseen, R. M., Ph.D., Ballesterio, T. P., Ph.D., Houle, J. P., Avellaneda, P., Wildey, R., & Briggs, J.). (2006). ASCE EWRI World Environmental and Water Resources Congress 2006: *Transportation Runoff BMP Performance*. (Per Wagner & Bonsignore)
- U.S. Department of the Interior, Bureau of Reclamation. *Construction Cost Trends*. Retrieved from [http://www.usbr.gov/pmts/estimate/cost\\_trend.html](http://www.usbr.gov/pmts/estimate/cost_trend.html). (Per Wagner & Bonsignore)

- U.S. Department of Transportation Federal Highway Administration. *Storm Water Best Management Practices in an Ultra-Urban Setting: Selection and Monitoring*. Retrieved from <http://www.fhwa.dot.gov/environment/ultraurb/index.htm> (accessed March 2009). (Per Wagner & Bonsignore)
- U.S. Environmental Protection Agency. *Storm Water Technology Fact Sheets*. Retrieved from <http://www.epa.gov/owm/mtb/mtbfact.htm> (accessed March 2009). (Per Wagner & Bonsignore)
- Wildermuth Environmental, Inc. (1998). *Recharge Master Plan Phase I Final Report*. Prepared for the Chino Basin Water Conservation District and the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (1999). *Optimum Basin Management Program – Draft Phase I Report*. Prepared for the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (2001). *Optimum Basin Management Program – Recharge Master Plan Phase II Report*. Prepared for the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (2004). *Technical Memorandum – Recharge Basin Performance*. Prepared for the Chino Basin Water Conservation District and the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (2006). *Draft Reconnaissance-Level Feasibility Assessment of Recharge at the Vulcan Pit*.
- Wildermuth Environmental, Inc. (2007a). *Optimum Basin Management Program, 2006 State of the Basin Report*.
- Wildermuth Environmental, Inc. (2007b). *Final Report, 2007 CBWM Groundwater Model Documentation and Evaluation of the Peace II Project Description*. Prepared for the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (2008). *Response to Condition Subsequent No. 3 from the Order Confirming Motion for the Approval of the Peace II Agreement*.
- Wildermuth Environmental, Inc. (2009a). *2010 Recharge Master Plan Update, Technical Memorandum: Task 5 Replenishment Projections, Task 7.1 Supplemental Water Recharge Capacity*. Prepared for the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. (2009b). *2009 Production Optimization and Evaluation of the Peace II Project Description*. Prepared for the Chino Basin Watermaster.
- Wildermuth Environmental, Inc. Annual Average Recharge estimates for project basins, March 2010. Wildermuth, M., P.E., Hwang, J., Ph.D., McCarthy, T., P.E., P.G., & Boushaki, F., Ph.D., personal communication. (Per Wagner & Bonsignore)
- Wildermuth Environmental, Inc. (2010a). *White Paper: Recent Changes in Santa Ana River Discharge*. Prepared for the Basin Monitoring Task Force.

Wildermuth Environmental, Inc. (2010b). *Draft Completion Memorandum – Wasteload Allocation Simulations for the Santa Ana River, May 2010*. Prepared for the Basin Monitoring Task Force.

Wildermuth Environmental, Inc. (2010c). *Draft 2010 Chino Basin Recharge Master Plan Update*.

Wildermuth Environmental, Inc. (2010d). *Summary of the R4 Model for the Chino Basin*.