

Table 4-2
Time History of Annual Stormwater Recharge in Chino Basin Recharge Facilities, 1989/90 to 2000/01(acre-ft/yr)
(acre-ft/yr)

Year	----- Recharge Facility -----											Unlined Channel Recharge			Total Stormwater Recharge
	San Sevaine 1 through 5	Victoria	Declez	Lower Day	Wineville	Upland	Montclair 1 through 4	Brooks	Turner 1	Ely	Subtotal	San Sevaine 1	Above: Victoria	Subtotal	
1989 / 90	130	21	2	0	0	182	488	639	101	917	2,480	379	274	652	3,133
1990 / 91	359	41	9	1	33	445	744	1,361	108	1,355	4,456	841	639	1,479	5,936
1991 / 92	455	0	7	1	10	647	1,208	1,531	164	2,171	6,194	946	749	1,695	7,889
1992 / 93	3,350	186	78	3	272	1,260	2,364	2,508	255	3,075	13,352	5,020	5,131	10,152	23,504
1993 / 94	115	0	2	0	0	148	298	694	136	1,777	3,170	677	466	1,143	4,313
1994 / 95	1,667	41	54	1	91	778	1,480	1,869	212	1,968	8,162	3,188	2,651	5,839	14,001
1995 / 96	445	21	15	1	19	402	870	1,017	111	1,389	4,289	706	536	1,242	5,531
1996 / 97	591	0	4	1	0	414	860	1,509	122	2,659	6,162	1,166	874	2,041	8,202
1997 / 98	1,633	41	8	2	30	1,074	2,145	2,667	287	3,667	11,553	3,967	3,456	7,423	18,975
1998 / 99	104	0	2	0	0	96	244	304	90	917	1,756	486	337	823	2,579
1999 / 0	71	0	1	0	0	255	392	428	143	1,225	2,516	586	411	996	3,512
2000 / 1	27	0	1	0	0	266	404	584	151	1,255	2,689	378	266	644	3,333
Total	8,947	351	182	12	456	5,968	11,497	15,111	1,880	22,375	66,779	18,338	15,790	34,128	100,907
Average	746	29	15	1	38	497	958	1,259	157	1,865	5,565	1,528	1,316	2,844	8,409
Max	3,350	186	78	3	272	1,260	2,364	2,667	287	3,667	13,352	5,020	5,131	10,152	23,504
Min	27	0	1	0	0	96	244	304	90	917	1,756	378	266	644	2,579
Standard Deviation	997	53	25	1	78	373	712	791	63	880	3,744	1,591	1,572	3,159	6,835
Coefficient of Variation	134%	179%	162%	90%	206%	75%	74%	63%	40%	47%	67%	104%	119%	111%	81%