

**Draft No. 1**

**Table 5-1  
Sample Annual Report to be Produced by Watermaster**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18)
Project Name	Date of Entry	Existence (or not) of Signed Maintenance Agreement	Ongoing Maintenance Verified (every 3 years)	MS4- Required Capture Volume (cubic feet)	Constructed Capture Volume (cubic feet)	Long-Term Average Annual Runoff from Site (acre-ft/yr)	Estimate of Pre-Project On-Site Incidental Recharge (acre-ft/yr)	Decrease in Recharge at Downstream Stormwater Management Facilities (acre-ft/yr)		Long-Term Average Annual Recharge <sup>1</sup> (acre-ft/yr)		Long-Term Average Annual Net New Recharge (acre-ft/yr)		Chino Basin MZ	County	Land Use Control Agency	Service Provider (Appropriator)
								=(11)-(8)-(9)		=(12)-(8)-(10)							
								MS4- Required Capture Volume	Constructed Capture Volume	MS4- Required Capture Volume	Constructed Capture Volume	MS4- Required Capture Volume	Constructed Capture Volume				
Chino Fire Station No. 1				15,857	24,243	3.17	1.33	0	0	2.12	2.55	0.79	1.22	1	SB	City of Chino	City of Chino

<sup>1</sup>The long-term average annual recharge assumes an infiltration rate of 0.5 ft/day.